

---

**Britt Surveying and Mapping, LLC**  
2086 SW Main Blvd Ste 112 • Lake City, FL 32025  
386-752-7163 P • 386-752-5573 F • [www.brittsurvey.com](http://www.brittsurvey.com)

5/28/2020

L-26616

Re: Lot 15 Amelia Landing


Permit #000038188

Bradley Franks

To Whom It May Concern:

The top of the finished floor elevation is found to be 117.28 feet on said lot 15. The building permit shows the Minimum finished floor to be 117.0 feet. The highest adjacent grade is found to be 116.0 feet and the lowest adjacent grade is 115.3 feet. The elevations shown hereon are based on plat datum.

Sincerely,



L. Scott Britt  
LS 5757