

67



Britt Surveying and Mapping, LLC
2086 SW Main Blvd Ste 112 • Lake City, FL 32025
386-752-7163 P • 386-752-5573 F • www.brittsurvey.com

02/13/2022

Permit # 000043061

L-28229

RJH Construction

Re: Lot 3 Sedgefield, Phase 4

To Whom It May Concern:

The top of the finished slab on Lot 3 is found to be 90.24 feet. The building permit shows the minimum floor elevation to be 89 feet. The elevations shown hereon are based on NAVD 88 datum.

Sincerely,

L. Scott Britt
LS 5757