



# NFPS



PO BOX 3823  
LAKE CITY, FL 32056



PHONE (386) 752-4675  
FAX (386) 752-4674



[www.nfps.net](http://www.nfps.net)

DATE: Tuesday, May 18, 2022

TO: Columbia County Building Department

FROM: James B. Smith, PSM – North Florida Professional Services

CC: Keith Eaker

RE: Finished Floor Elevation – 366 SW Jewel Lake Dr., Lake City FL 32024

This is to certify that the following elevations of were obtained on the finished floor of a building constructed on Parcel # 33-3S-16-02439-225 at the address of 366 SW Jewel Lake Dr., Lake City, FL 32024

**Permit # 43225 FFE: 125.38'**

The required elevation is 122.50'

James B. Smith, PSM  
Florida Certification No. 7355

