

CAROL CHADWICK, P.E.

*Civil Engineer*

1208 S.W. Fairfax Glen

Lake City, FL 32025

307.680.1772

ccpewyo@gmail.com

www.carolchadwickpe.com

September 12, 2023

re: BUSY BEE FFE LETTER

In my professional opinion, the finished floor elevation shown on the "Slab Asbuilt Survey" by Affine Engineering and Surveying, Inc. dated April 14, 2023 is sufficient to protect the structure from water damage in a base flood event. The as-built elevations vary from 175.99 and 176.05. The minimum finished floor elevation shown on the site plan was 176.08.

I certify that the finished floor elevation will protect the structure against water damage from a base flood event, as defined in Article 8 of the Land Development Regulations.

Please contact me at 307.680.1772 if you have any questions.

Respectfully,



Digitally signed by  
Carol Chadwick  
DN: c=US,  
o=Florida,  
dnQualifier=A0141  
0D0000017EB6D9  
24CE0005954C,  
cn=Carol  
Chadwick  
Date: 2023.09.12  
13:37:04 -04'00'

Carol Chadwick, P.E.