

**December 14, 2022**

Aaron Simque Homes  
333 SW Rosemary Drive  
Lake City, FL 32025

**Subject: Parcel # 02731-061 - Lot 62 & part of Lot 61, Preserve at Laurel Lake, Unit 1**

Dear Aaron:

Daniel & Gore, LLC has performed a vertical survey on Parcel 02731-061 – Lot 62 and part of Lot 61, Preserve at Laurel Lake, Unit 1, Columbia County, Florida from a benchmark being a 60d nail at the common lot line between Lots 8 & 9 (elevation – 116.12', NGVD 1929) and have determined the following:

- The Subdivision plat requires the minimum finish floor elevation to be 118.6'.
- The elevation of the top of the stem wall of the main residence is at 119.0', being 0.4' above the minimum finish floor requirement.
- The elevation of the top of the stem wall of the Mother-in-law suite is at 119.0', being 0.4' above the minimum finish floor requirement.

If you have any questions, please call me.

Sincerely,

Scott Daniel, PSM

Digitally  
signed by  
Brian S Daniel  
Date:  
2022.12.14  
11:12:33  
-05'00'

