COLUMBIA COUNTY BUILDING DEPARTMENT RESIDENTIAL CHECK LIST REQUIRMENTS

6-25-09

MINIMUM PLAN REQUIREMENTS FOR THE FLORIDA BUILDING CODE RESIDENTIAL 2007 EFFECTIVE 1 MARCH 2009 & 2009 SUPPLEMENTS EFFECTIVE 1 MARCH 2009, ONE (1) AND TWO (2) FAMILY DWELLINGS with Supplements and Revision, OF THE NATIONAL ELECTRICAL 2008

ALL REQUIREMENTS ARE SUBJECT TO CHANGE

ALL BUILDING PLANS MUST INDICATE COMPLIANCE with the Current 2007 FLORIDA BUILDING CODES RESIDENTIAL EFFECTIVE 1 MARCH 2009 & 2009 SUPPLEMENTS EFFECTIVE 1 MARCH 2009. ALL PLANS OR DRAWINGS SHALL PROVIDE CALCULATIONS AND DETAILS THAT HAVE THE SEAL AND SIGNATURE OF A CERTIFIED ARCHITECT OR ENGINEER REGISTERED IN THE STATE OF FLORIDA, OR ALTERNATE METHODOLOGIES, APPROVED BY THE STATE OF FLORIDA BUILDING COMMISSION FOR ONE-AND-TWO FAMILY DWELLINGS.

FOR DESIGN PURPOSES THE FOLLOWING BASIC WIND SPEEDS ARE PER FIGURE R301.2(4) of the FLORIDA BUILDING CODES RESIDENTIAL (Florida Wind speed map) SHALL BE USED.

WIND SPEED LINE SHALL BE DEFINED AS FOLLOWS: THE CENTERLINE OF INTERSTATE 75.

ALL BUILDINGS CONSTRUCTED EAST OF SAID LINE SHALL BE ------ 100 MPH ALL BUILDINGS CONSTRUCTED WEST OF SAID LINE SHALL BE ------110 MPH NO AREA IN COLUMBIA COUNTY IS IN A WIND BORNE DEBRIS REGION

APPLICANT DI FACE CHECK ALL APPLICADI E DOVEC DEFODE CH

GENERAL REQUIREMENTS:

	ALL EICHTET	EASE CHECK ALL	ATTEICABLE BOXES BEFORE SUBMITTAL	1	Applicable Yes No N	
				Yes	No	N/A
1	Two (2) complete sets of	plans containing the fo	ollowing:	/		
2	All drawings must be clea	ar, concise, drawn to so	cale, details that are not used shall be marked void	/		
3	Condition space (Sq. Ft.)	3273	Total (Sq. Ft.) under roof	ШШШ	ШШП	Ш

Designers name and signature shall be on all documents and a licensed architect or engineer, signature and official embossed seal shall be affixed to the plans and documents as per the FLORIDA BUILDING CODES RESIDENTIAL R101.2.1

Site Plan information including:

4 Dimensions of lot or parcel of land

5 Dimensions of all building set backs

6 Location of all other structures (include square footage of structures) on parcel, existing or proposed well and septic tank and all utility easements.

7 Provide a full legal description of property.

Items to Include-Each Box shall be

Circled as

Wind-load Engineering Summary, calculations and any details required

GENERAL REQUIREMENTS: APPLICANT – PLEASE CHECK ALL APPLICABLE BOXES BEFORE SUBMITTAL		Items to Include- Each Box shall be Circled as Applicable		
8	Plans or specifications must show compliance with FBCR Chapter 3	ШШ	IIIII	ШШ
		YES	NO	N/A
9	Basic wind speed (3-second gust), miles per hour			
10	(Wind exposure – if more than one wind exposure is used, the wind exposure and applicable wind direction shall be indicated)	/		
11	Wind importance factor and nature of occupancy	/		
12	The applicable internal pressure coefficient, Components and Cladding			
13	The design wind pressure in terms of psf (kN/m²), to be used for the design of exterior component, cladding materials not specifally designed by the registered design professional.	/		

Elevations Drawing including:

14	All side views of the structure	
15	Roof pitch	
16	Overhang dimensions and detail with attic ventilation	
17	Location, size and height above roof of chimneys	
18	Location and size of skylights with Florida Product Approval	
18	Number of stories	
20A	Building height from the established grade to the roofs highest peak	

Floor Plan including:

	Dimensioned area plan showing rooms, attached garage, breeze ways, covered porches, deck,		
20	balconies	/	
21	Raised floor surfaces located more than 30 inches above the floor or grade		
22	All exterior and interior shear walls indicated		
23	Shear wall opening shown (Windows, Doors and Garage doors)		
24	Show compliance with Section FBCR 310 Emergency escape and rescue opening shown in each bedroom (net clear opening shown) and Show compliance with Section FBCR 613.2 where the opening of an operable window is located more than 72 inches above the finished grade or surface below, the lowest part of the clear opening of the window shall be a minimum of 24 inches above the finished floor of the room in which the window is located. Glazing between the floor and 24 inches shall be fixed or have openings through which a 4-inch-diameter sphere cannot pass.	/	
25	Safety glazing of glass where needed		
26	Fireplaces types (gas appliance) (vented or non-vented) or wood burning with Hearth (see chapter 10 of FBCR)	/	
27	Show stairs with dimensions (width, tread and riser and total run) details of guardrails, Handrails		/
28	Identify accessibility of bathroom (see FBCR SECTION 322)		

All materials placed within opening or onto/into exterior walls, soffits or roofs shall have Florida product approval number and mfg. installation information submitted with the plans (see Florida product approval form)

GENERAL REQUIREMENTS: APPLICANT – PLEASE CHECK ALL APPLICABLE BOXES BEFORE SUBMITTAL			Items to Include- Each Box shall be Circled as Applicable		
FBCR 403: Foundation Plans	YES	NO	N/A		
29 Location of all load-bearing walls footings indicated as standard, monolithic, dimensions, size	163	INO	IN/A		
and type of reinforcing.	/		1		
30 All posts and/or column footing including size and reinforcing	1				
Any special support required by soil analysis such as piling.	/				
Assumed load-bearing valve of soil Pound Per Square Foot	1		1		
Location of horizontal and vertical steel, for foundation or walls (include # size and type) For structur with foundation which establish new electrical utility companies service connection a Concrete Encased Electrode will be required within the foundation to serve as an grounding electrode system. Per the National Electrical Code article 250.52.3	res				
FBCR 506: CONCRETE SLAB ON GRADE					
Show Vapor retarder (6mil. Polyethylene with joints lapped 6 inches and sealed)	/		1		
Show control joints, synthetic fiber reinforcement or welded fire fabric reinforcement and Supports	-		1		
Indicate on the foundation plan if soil treatment is used for subterranean termite prevention or					
Sub mit other approved termite protection methods. Protection shall be provided by registered termiticides	/				
36 Sub mit other approved termite protection methods. Protection shall be provided by registered	/				
Sub mit other approved termite protection methods. Protection shall be provided by registered termiticides FBCR 606: Masonry Walls and Stem walls (load bearing & shear Walls)	/				
Sub mit other approved termite protection methods. Protection shall be provided by registered termiticides FBCR 606: Masonry Walls and Stem walls (load bearing & shear Walls) Show all materials making up walls, wall height, and Block size, mortar type	/				
Sub mit other approved termite protection methods. Protection shall be provided by registered termiticides FBCR 606: Masonry Walls and Stem walls (load bearing & shear Walls) Show all materials making up walls, wall height, and Block size, mortar type	rida Pro	of. En	ginee		
Sub mit other approved termite protection methods. Protection shall be provided by registered termiticides FBCR 606: Masonry Walls and Stem walls (load bearing & shear Walls) Show all materials making up walls, wall height, and Block size, mortar type Show all Lintel sizes, type, spans and tie-beam sizes and spacing of reinforcement Metal frame shear wall and roof systems shall be designed, signed and sealed by Floarchitect Floor Framing System: First and/or second story Floor truss package shall including layout and details, signed and sealed by Florida Registered		of. En	ginee		
Sub mit other approved termite protection methods. Protection shall be provided by registered termiticides FBCR 606: Masonry Walls and Stem walls (load bearing & shear Walls) Show all materials making up walls, wall height, and Block size, mortar type Show all Lintel sizes, type, spans and tie-beam sizes and spacing of reinforcement Metal frame shear wall and roof systems shall be designed, signed and sealed by Floarchitect Floor Framing System: First and/or second story Floor truss package shall including layout and details, signed and sealed by Florida Registered Professional Engineer Show conventional floor joist type, size, span, spacing and attachment to load bearing walls,	orida Pro	of. En	ginee		
Sub mit other approved termite protection methods. Protection shall be provided by registered termiticides FBCR 606: Masonry Walls and Stem walls (load bearing & shear Walls) Show all materials making up walls, wall height, and Block size, mortar type Show all Lintel sizes, type, spans and tie-beam sizes and spacing of reinforcement Metal frame shear wall and roof systems shall be designed, signed and sealed by Floarchitect Floor Framing System: First and/or second story Floor truss package shall including layout and details, signed and sealed by Florida Registered Professional Engineer Show conventional floor joist type, size, span, spacing and attachment to load bearing walls, stem walls and/or priers		of. En	ginee		
Sub mit other approved termite protection methods. Protection shall be provided by registered termiticides FBCR 606: Masonry Walls and Stem walls (load bearing & shear Walls) Show all materials making up walls, wall height, and Block size, mortar type Show all Lintel sizes, type, spans and tie-beam sizes and spacing of reinforcement Metal frame shear wall and roof systems shall be designed, signed and sealed by Floarchitect Floor Framing System: First and/or second story Floor truss package shall including layout and details, signed and sealed by Florida Registered Professional Engineer Show conventional floor joist type, size, span, spacing and attachment to load bearing walls, stem walls and/or priers Girder type, size and spacing to load bearing walls, stem wall and/or priers		of. En	ginee		
Sub mit other approved termite protection methods. Protection shall be provided by registered termiticides FBCR 606: Masonry Walls and Stem walls (load bearing & shear Walls) Show all materials making up walls, wall height, and Block size, mortar type Show all Lintel sizes, type, spans and tie-beam sizes and spacing of reinforcement Metal frame shear wall and roof systems shall be designed, signed and sealed by Floarchitect Floor Framing System: First and/or second story Floor truss package shall including layout and details, signed and sealed by Florida Registered Professional Engineer Show conventional floor joist type, size, span, spacing and attachment to load bearing walls, stem walls and/or priers		of. En	ginee		

45	Show required amount of ventilation opening for under-floor spaces	
46	Show required covering of ventilation opening	1/
47	Show the required access opening to access to under-floor spaces	
48	Show the sub-floor structural panel sheathing type, thickness and fastener schedule on the edges & interest of the areas structural panel sheathing	
49	Show Draftstopping, Fire caulking and Fire blocking	//
50	Show fireproofing requirements for garages attached to living spaces, per FBCR section 309	
51	Provide live and dead load rating of floor framing systems (psf).	

FBCR CHAPTER 6 WOOD WALL FRAMING CONSTRUCTION

	GENERAL REQUIREMENTS: APPLICANT – PLEASE CHECK ALL APPLICABLE BOXES BEFORE SUBMITTAL	Each C	to Inclu Box sha ircled as pplicabl	ll be
		YES	NO	N/A
52	Stud type, grade, size, wall height and oc spacing for all load bearing or shear walls			1
53	Fastener schedule for structural members per table FBCR 602.3 are to be shown	/		
54	Show Wood structural panel's sheathing attachment to studs, joist, trusses, rafters and structural members, showing fastener schedule attachment on the edges & intermediate of the areas structural panel sheathing	/		
55	Show all required connectors with a max uplift rating and required number of connectors and oc spacing for continuous connection of structural walls to foundation and roof trusses or rafter systems	/		
56	Show sizes, type, span lengths and required number of support jack studs, king studs for shear wall opening and girder or header per FBCR Table 502.5 (1)	/		
57	Indicate where pressure treated wood will be placed	-		
58	Show all wall structural panel sheathing, grade, thickness and show fastener schedule for structural panel sheathing edges & intermediate areas	/		
59	A detail showing gable truss bracing, wall balloon framing details or/ and wall hinge bracing detail	/		

FBCR :ROOF SYSTEMS:

60	Truss design drawing shall meet section FBCR 802.10 Wood trusses	1	
61	Include a layout and truss details, signed and sealed by Florida Professional Engineer		
62	Show types of connector's assemblies' and resistance uplift rating for all trusses and rafters		
63	Show gable ends with rake beams showing reinforcement or gable truss and wall bracing details		
64	Provide dead load rating of trusses	/	

FBCR 802: Conventional Roof Framing Layout

65	Rafter and ridge beams sizes, span, species and spacing	
66	Connectors to wall assemblies' include assemblies' resistance to uplift rating	
67	Valley framing and support details	
68	Provide dead load rating of rafter system	

FBCR Table 602,3(2) &	FBCR 803	ROOF	SHEATHIN	G
-------------------	------	-----------------	------	----------	---

	Include all materials which will make up the roof decking, identification of structural panel sheathing, grade, thickness		
70	Show fastener Size and schedule for structural panel sheathing on the edges & intermediate areas	/	
70	one rusterier of the and senedate for structural paner shearing on the edges to intermediate areas		

FBCR ROOF ASSEMBLIES FRC Chapter 9

71	Include all materials which will make up the roof assembles covering		
72	Submit Florida Product Approval numbers for each component of the roof assembles covering		

FBCR Chapter 11 Energy Efficiency Code for residential building

Residential construction shall comply with this code by using the following compliance methods in the FBCR chapter 11 Residential buildings compliance methods. Two of the required forms are to be submitted, N1100.1.1.1 As an alternative to the computerized Compliance Method A, the Alternate Residential Point System Method hand calculation, Alternate Form 600A, may be used. All requirements specific to this calculation are located in Sub appendix C to Appendix G. Buildings complying by this alternative shall meet all mandatory requirements of this chapter. Computerized versions of the Alternate Residential Point System Method shall not be acceptable for code compliance.

GENERAL REQUIREMENTS: APPLICANT – PLEASE CHECK ALL APPLICABLE BOXES BEFORE SUBMITTAL	Items to Include- Each Box shall be Circled as Applicable		
	YES	NO N	V/A
73 Show the insulation R value for the following areas of the structure			
74 Attic space			
75 Exterior wall cavity	1/		/
76 Crawl space		-	
77 Submit two copies of a Manual J sizing equipment or equivalent computation study 78 Exhaust fans shown in bathrooms Mechanical exhaust capacity of 50 cfm intermittent or			
20 cfm continuous required Show clothes dryer route and total run of exhaust duct	-		
Plumbing Fixture layout shown 80 All fixtures waste water lines shall be shown on the foundation plan 81 Show the location of water heater			
Private Potable Water	/		
82 Pump motor horse power			
83 Reservoir pressure tank gallon capacity	/		
83 Reservoir pressure tank ganon capacity	/ /		

Electrical layout shown including

Show Switches, receptacles outlets, lighting fixtures and Ceiling fans		
Show all 120-volt, single phase, 15- and 20-ampere branch circuits outlets required to be protected	/	
by Ground-Fault Circuit Interrupter (GFCI) Article 210.8 A		
Show the location of smoke detectors & Carbon monoxide detectors		
Show service panel, sub-panel, location(s) and total ampere ratings	/	
On the electrical plans identify the electrical service overcurrent protection device for the main electrical service. This device shall be installed on the exterior of structures to serve as a disconnecting means for the utility company electrical service. Conductors used from the exterior disconnecting means to a panel or sub panel shall have four-wire conductors, of which one conductor shall be used as an equipment ground. Indicate if the utility company service entrance cable will be of the overhead or underground type. For structures with foundation which establish new electrical utility companies service connection a Concrete Encased Electrode will be required within the foundation to serve as an		
Grounding electrode system. Per the National Electrical Code article 250.52.3		
		_
in dwelling unit family rooms, dining rooms, living rooms, parlors, libraries, dens, bedrooms, sunrooms, recreation rooms, closets, hallways, or similar rooms or areas shall be protected by a listed Combination arc-fault circuit interrupter , Protection device.		
	Show all 120-volt, single phase, 15- and 20-ampere branch circuits outlets required to be protected by Ground-Fault Circuit Interrupter (GFCI) Article 210.8 A Show the location of smoke detectors & Carbon monoxide detectors Show service panel, sub-panel, location(s) and total ampere ratings On the electrical plans identify the electrical service overcurrent protection device for the main electrical service. This device shall be installed on the exterior of structures to serve as a disconnecting means for the utility company electrical service. Conductors used from the exterior disconnecting means to a panel or sub panel shall have four-wire conductors, of which one conductor shall be used as an equipment ground. Indicate if the utility company service entrance cable will be of the overhead or underground type. For structures with foundation which establish new electrical utility companies service connection a Concrete Encased Electrode will be required within the foundation to serve as an Grounding electrode system. Per the National Electrical Code article 250.52.3 Appliances and HVAC equipment and disconnects Show all 120-volt, single phase, 15- and 20-ampere branch circuits supplying outlets installed in dwelling unit family rooms, dining rooms, living rooms, parlors, libraries, dens, bedrooms,	Show all 120-volt, single phase, 15- and 20-ampere branch circuits outlets required to be protected by Ground-Fault Circuit Interrupter (GFCI) Article 210.8 A Show the location of smoke detectors & Carbon monoxide detectors Show service panel, sub-panel, location(s) and total ampere ratings On the electrical plans identify the electrical service overcurrent protection device for the main electrical service. This device shall be installed on the exterior of structures to serve as a disconnecting means for the utility company electrical service. Conductors used from the exterior disconnecting means to a panel or sub panel shall have four-wire conductors, of which one conductor shall be used as an equipment ground. Indicate if the utility company service entrance cable will be of the overhead or underground type. For structures with foundation which establish new electrical utility companies service connection a Concrete Encased Electrode will be required within the foundation to serve as an Grounding electrode system. Per the National Electrical Code article 250.52.3 Appliances and HVAC equipment and disconnects Show all 120-volt, single phase, 15- and 20-ampere branch circuits supplying outlets installed in dwelling unit family rooms, dining rooms, living rooms, parlors, libraries, dens, bedrooms,

<u>Disclosure Statement for Owner Builders</u> If you as the applicant will be acting as an owner/builder under section 489.103(7) of the Florida Statutes, submit the required owner builder disclosure statement form.

Notice Of Commencement

A notice of commencement form **recorded** in the Columbia County Clerk Office is required to be filed with the building department Before Any Inspections can be preformed.

	Items to Include-
GENERAL REQUIREMENTS: APPLICANT – PLEASE CHECK ALL APPLICABLE BOXES BEFORE SUBMITTAL	Each Box shall be Circled as
	Applicable

THE FOLLOWING ITEMS MUST BE SUBMITTED WITH BUILDING PLANS

co	Building Permit Application A current Building Permit Application form is to be completed and submitted for all residential projects	/	1	
93 Pa				
	Parcel Number The parcel number (Tax ID number) from the Property Appraiser 386) 758-1084 is required. A copy of property deed is also requested	/		
94 E	Environmental Health Permit or Sewer Tap Approval A copy of a approved Columbia County Environmental Health (386) 758-1058	1	-	
95 C	City of Lake City A permit showing an approved waste water sewer tap			/
	Coilet facilities shall be provided for all construction sites	-		
97 To	Town of Fort White (386) 497-2321 If the parcel in the application for building permit is within the Corporate city limits of Fort White an approval land use development letter issued by the Yown of Fort is required to be submitted with the application for a building permit.			/

98	Flood Information: All projects within the Floodway of the Suwannee or Santa Fe Rivers shall require permitting through the Suwannee River Water Management District, before submitting a application to this office. Any project located within a flood zone where the base flood elevation (100 year flood) has been established shall meet the requirements of Section 8.5.2 of the Columbia County Land Development Regulations. Any project located within a flood zone where the base flood elevation has not been established (Zone A) shall meet the requirements of Section 8.5.3 of the Columbia County Land Development Regulations		
99	CERTIFIED FINISHED FLOOR ELEVATIONS will be required on any project where the base flood elevation (100 year flood) has been established		
100	A development permit will also be required. Development permit cost is \$50.00	/	/
101	Driveway Connection: If the property does not have an existing access to a public road, then an application for a culvert permit (\$25.00) must be made. If the applicant feels that a culvert is not needed, they may apply for a culvert waiver (\$50.00). All culvert waivers are sent to the Columbia County Public Works Department for approval or denial.		
102	911 Address: If the project is located in an area where a 911 address has not been issued, then application for a 911 address must be applied for and received through the Columbia County Emergency Management Office of 911 Addressing Department (386) 758-1125		

Section R101.2.1 of the Florida Building Code Residential:

The provisions of Chapter 1, Florida Building Code, Building shall govern the administration and enforcement of the Florida Building Code, Residential.

Section 105 of the Florida Building Code defines the:

Time limitation of application.

An application for a permit for any proposed work shall be deemed to have been abandoned 180 days after the date of filing, unless such application has been pursued in good faith or a permit has been issued; except that the building official is authorized to grant one or more extensions of time for additional periods not exceeding 90 days each. The extension shall be requested in writing and justifiable cause demonstrated.

Single-family residential dwelling.

Section 105.3.4 A building permit for a single-family residential dwelling must be issued within 30 working days of application therefor unless unusual circumstances require a longer time for processing the application or unless the permit application fails to satisfy the Florida Building Code or the enforcing agency's laws or ordinances.

Permit intent.

Section 105.4.1: A permit issued shall be constructed to be a license to proceed with the work and not as authority to violate, cancel, alter or set aside any of the provisions of the technical codes, nor shall issuance of a permit prevent the building official from thereafter requiring a correction of errors in plans, construction or violations of this code. Every permit issued shall become invalid unless the work authorized by such permit is commenced within six months after its issuance, or if the work authorized by such permit is suspended or abandoned for a period of six months after the time the work is commenced.