



SCALE: 1/2" = 1'-0"

BOTTOM OF EXTERIOR FOOTINGS SHALL BE A MINIMUM OF 12" BELOW UNDISTURBED SOIL OR ENGINEERED FILL

AC1030 1/2 Section	Specific Requirements
1.4A Compressive strength	8" block bearing walls Fm = 1500 psi
2.1 Mortar	ASTM 720 Type N, UNO
2.2 Grout	ASTM C 476, admixture for concrete approval
3 CM standard	ASTM C 90-02. Normal weight, hollow, medium surface finish, 8"x8"x16" running bond and 12"x12" or 16"x16" column block
2.3 Clay brick standard	ASTM C 216-02. Grade SW, Type FBS, S-292 (20 lbs)
2.4 Reinforcing bars, #11 - #15	ASTM B15, Grade 40, Fy = 40ksi, lap splices min 40 bar dia. (25" for #5)
2.4F Coating for corrosion protection	Anchor, steel sheet metal ties completely embedded in mortar or grout. ASTM A925, Class G60, 0.60 oz/ctf or 304SS
2.4F Coating for corrosion protection	Joint reinforcement in walls exposed to moisture or salt ties, anchors, steel metal ties not completely embedded in mortar or grout. ASTM A153, Class B2, 1.50 oz/ctf or 304SS
3.3 E.2 Pipes, conduits, and accessories	Any not shown on the project drawings require engineering approval.
3.3 E.7 Movement joints	Contractor assumes responsibility for type and location of movement joints if not detailed on project drawings.

F1
S-2

2

