



Britt Surveying and Mapping, LLC
2086 SW Main Blvd Ste 112 • Lake City, FL 32025
386-752-7163 P • 386-752-5573 F • www.brittsurvey.com

1/20/2020

L-26293

Permit # 39030

Re: Lot 27 Cannon Creek Place

Bradley Franks Construction

To Whom It May Concern:

The slab on Lot 27 is found to be 99.92 feet. The lowest adjacent grade is determined to be 99.0 feet and the highest adjacent grade is determined to be 99.8 feet. The building permit shows the minimum floor elevation is 99.00 feet. All elevations are shown in plat datum (NGVD 29 datum).

Sincerely,



L. Scott Britt
LS 5757