

December 20, 2022

David Wyers
289 SW Grant Glen
Lake City, FL 32024

Subject: Parcel # 09477-203

Dear Elouise:

Daniel & Gore, LLC has performed a vertical survey on Parcel # 09477-203, Columbia County, Florida from a benchmark being a NGS concrete monument (BC45 Reset 1953) on the West right of way of SR-25 (elevation – 139.65', NAVD 1988) and have determined the following:

- The Elevation Letter by Carol Chadwick, P.E. requires the minimum finish floor elevation to be 82.50'
- The finish floor of the residence is at 83.4', being 0.9' above the minimum finish floor requirement per Carol Chadwick's letter.

If you have any questions, please call me.

Sincerely,

Scott Daniel, PSM

Digitally
signed by
Brian S Daniel
Date:
2022.12.21
13:06:40[®]
-05'00'

