



Building Analysis
Entire House
Hart

Job: HART
Date: May 13, 2020
By: ENERGYCALCS.NET INC

ENERGYCALCS.NET INC 267 DELEON RD, DEBARY, FL 32713 Phone: 386-775-0908 Email: MAGGIE@ENERGYCALCS.NET Web: ENERGYCALCS.NET

Project Information


For: HART
SW MAPLETON ST, FORT WHITE, FL 32038

Design Conditions

Location: Jacksonville/Intl., FL, US Elevation: 33 ft Latitude: 30°N		Indoor: Indoor temperature (°F) Design TD (°F) Relative humidity (%) Moisture difference (gr/lb)		Heating 70 38 50 33.1	Cooling 75 18 50 50.3
Outdoor: Dry bulb (°F) Daily range (°F) Wet bulb (°F) Wind speed (mph)		Heating 33 - - 15.0	Cooling 93 18 (M) 77 7.5	Infiltration: Method: Blower door Shielding / stories: 3 (partial) / 1 Pressure / AVF: 50 Pa / 2613 cfm	


Heating

Component	Btuh/ft²	Btuh	% of load
Walls	2.6	4784	13.6
Glazing	12.4	3329	9.5
Doors	14.6	351	1.0
Ceilings	1.0	2357	6.7
Floors	4.3	10443	29.7
Infiltration	3.9	8424	24.0
Ducts		5439	15.5
Piping		0	0
Humidification		0	0
Ventilation		0	0
Adjustments		0	0
Total		35127	100.0



Cooling

Component	Btuh/ft²	Btuh	% of load
Walls	1.4	2692	10.1
Glazing	14.1	3782	14.2
Doors	11.8	283	1.1
Ceilings	1.1	2746	10.3
Floors	0	0	0
Infiltration	1.0	2235	8.4
Ducts		5688	21.4
Ventilation		0	0
Internal gains		9170	34.5
Blower		0	0
Adjustments		0	0
Total		26596	100.0



Latent Cooling Load = 6081 Btuh
Overall U-value = 0.081 Btuh/ft²·°F

Data entries checked.



Project Summary

Entire House

Hart

Job: HART

Date: May 13, 2020

By: ENERGYCALCS.NET INC

ENERGYCALCS.NET INC 267 DELEON RD, DEBARY, FL 32713 Phone: 386-775-0908 Email: MAGGIE@ENERGYCALCS.NET Web: ENERGYCALCS.NET

Project Information

For: HART
SW MAPLETON ST, FORT WHITE, FL 32038

Notes:

Design Information

Weather: Jacksonville/Intl., FL, US

Winter Design Conditions

Outside db	33 °F
Inside db	70 °F
Design TD	38 °F

Summer Design Conditions

Outside db	93 °F
Inside db	75 °F
Design TD	18 °F
Daily range	M
Relative humidity	50 %
Moisture difference	50 gr/lb

Heating Summary

Structure	29687 Btuh
Ducts	5439 Btuh
Central vent (0 cfm)	0 Btuh
(none)	
Humidification	0 Btuh
Piping	0 Btuh
Equipment load	35127 Btuh

Sensible Cooling Equipment Load Sizing

Structure	20908 Btuh
Ducts	5688 Btuh
Central vent (0 cfm)	0 Btuh
(none)	
Blower	0 Btuh
Use manufacturer's data	y
Rate/swing multiplier	1.00
Equipment sensible load	26596 Btuh

Infiltration

Method	Blower door
Shielding / stories	3 (partial) / 1
Pressure / AVF	50 Pa / 2613 cfm

Latent Cooling Equipment Load Sizing

Structure	4707 Btuh
Ducts	1374 Btuh
Central vent (0 cfm)	0 Btuh
(none)	
Equipment latent load	6081 Btuh

	Heating	Cooling
Area (ft²)	2417	2417
Volume (ft³)	22393	22393
Air changes/hour	0.55	0.31
Equiv. AVF (cfm)	204	114

Equipment Total Load (Sen+Lat)	32677 Btuh
Req. total capacity at 0.74 SHR	3.0 ton

Heating Equipment Summary

Make	Generic
Trade	
Model	SEER 15.0, HSPF 8.5
AHRI ref	
Efficiency	8.5 HSPF
Heating input	
Heating output	36000 Btuh @ 47°F
Temperature rise	30 °F
Actual air flow	1100 cfm
Air flow factor	0.031 cfm/Btuh
Static pressure	0.40 in H2O
Space thermostat	
Capacity balance point = 33 °F	

Cooling Equipment Summary

Make	Generic
Trade	
Cond	SEER 15.0, HSPF 8.5
Coil	
AHRI ref	
Efficiency	12.8 EER, 15 SEER
Sensible cooling	26640 Btuh
Latent cooling	9360 Btuh
Total cooling	36000 Btuh
Actual air flow	1100 cfm
Air flow factor	0.041 cfm/Btuh
Static pressure	0.40 in H2O
Load sensible heat ratio	0.81

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



wrightsoft

Right-Suite® Universal 2019 19.0.18 RSU19927


2020-May-13 16:52:34

Page 1

...are\Downloads\EL WOOD CONSTRUCTION HART-rvd.rup Calc = MJ8 Front Door faces: S



Level 1



Job #: HART
Performed by ENERGYCALCS.NET INC for:
HART
SW MAPLETON ST
FORT WHITE, FL 32038

Hart
ENERGYCALCS.NET INC 267 DELEON RD
DEBARY, FL 32713
Phone: 386-775-0908
ENERGYCALCS.NET MAGGIE@ENERGYCALCS.NET

Scale: 1 : 97
Page 1
Right-Suite® Universal 2019
19.0.18 RSU19927
2020-May-13 16:53:10
...ELWOOD CONSTRUCTION HART-...



Manual S Compliance Report
Entire House
Hart

Job: HART
Date: May 13, 2020
By: ENERGYCALCS.NET INC

ENERGYCALCS.NET INC 267 DELEON RD, DEBARY, FL 32713 Phone: 386-775-0908 Email: MAGGIE@ENERGYCALCS.NET Web: ENERGYCALCS.NET

Project Information

For: HART
SW MAPLETON ST, FORT WHITE, FL 32038

Cooling Equipment

Design Conditions

Outdoor design DB:	92.8°F	Sensible gain:	26596 Btuh	Entering coil DB:	76.4°F
Outdoor design WB:	77.0°F	Latent gain:	6081 Btuh	Entering coil WB:	63.2°F
Indoor design DB:	75.0°F	Total gain:	32677 Btuh		
Indoor RH:	50%	Estimated airflow:	1100 cfm		

Manufacturer's Performance Data at Actual Design Conditions

Equipment type:	Split ASHP		
Manufacturer:	Generic	Model:	SEER 15.0, HSPF 8.5
Actual airflow:	1100 cfm		
Sensible capacity:	29900 Btuh		112% of load
Latent capacity:	6100 Btuh		100% of load
Total capacity:	36000 Btuh		110% of load SHR: 83%

Heating Equipment

Design Conditions

Outdoor design DB:	32.5°F	Heat loss:	35127 Btuh	Entering coil DB:	69.2°F
Indoor design DB:	70.0°F				

Manufacturer's Performance Data at Actual Design Conditions

Equipment type:	Split ASHP		
Manufacturer:	Generic	Model:	SEER 15.0, HSPF 8.5
Actual airflow:	1100 cfm		
Output capacity:	36000 Btuh		102% of load
Supplemental heat required:	0 Btuh		
		Capacity balance:	33 °F
		Economic balance:	-99 °F

Meets all requirements of ACCA Manual S.



Right-Suite® Universal 2019 19.0.18 RSU19927

2020-May-13 16:52:34

Page 1

...are\Downloads\LELWOOD CONSTRUCTION HART-rvd.rup Calc = MJ8 Front Door faces: S



Duct System Summary

Entire House

Hart

Job: HART
Date: May 13, 2020
By: ENERGYCALCS.NET INC

ENERGYCALCS.NET INC 267 DELEON RD, DEBARY, FL 32713 Phone: 386-775-0908 Email: MAGGIE@ENERGYCALCS.NET Web: ENERGYCALCS.NET

Project Information

For: HART
SW MAPLETON ST, FORT WHITE, FL 32038

	Heating	Cooling
External static pressure	0.40 in H2O	0.40 in H2O
Pressure losses	0 in H2O	0 in H2O
Available static pressure	0.40 in H2O	0.40 in H2O
Supply / return available pressure	0.299 / 0.101 in H2O	0.299 / 0.101 in H2O
Lowest friction rate	0.161 in/100ft	0.161 in/100ft
Actual air flow	1100 cfm	1100 cfm
Total effective length (TEL)	249 ft	

Supply Branch Detail Table

Name	Design (Btuh)	Htg (cfm)	Clg (cfm)	Design FR	Diam (in)	H x W (in)	Duct Matl	Actual Ln (ft)	Ftg.Eqv Ln (ft)	Trunk
b	909	28	25	0.174	4.0	0x0	VFx	51.5	120.0	st3
ba	671	21	9	0.175	4.0	0x0	VFx	51.1	120.0	st3
br2	3489	142	144	0.177	7.0	0x0	VFx	49.1	120.0	st3
br3	6106	191	108	0.161	8.0	0x0	VFx	61.2	125.0	st3
grt	2339	70	97	0.269	6.0	0x0	VFx	21.4	90.0	st2
grt-A	2339	70	97	0.174	6.0	0x0	VFx	51.5	120.0	st3
kit.dng	3129	68	129	0.272	7.0	0x0	VFx	20.1	90.0	st2
kit.dng-A	3129	68	129	0.173	7.0	0x0	VFx	52.7	120.0	st3
laun	3619	113	100	0.243	6.0	0x0	VFx	28.2	95.0	st2
mba	1596	50	27	0.285	5.0	0x0	VFx	15.0	90.0	st1
mbr	6628	208	193	0.270	8.0	0x0	VFx	20.8	90.0	st1
p	794	25	10	0.270	4.0	0x0	VFx	20.8	90.0	st2
t	1412	44	15	0.277	5.0	0x0	VFx	17.8	90.0	st1
wf	416	3	17	0.278	4.0	0x0	VFx	17.6	90.0	st1

Supply Trunk Detail Table

Name	Trunk Type	Htg (cfm)	Clg (cfm)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Duct Material	Trunk
st3	Peak AVF	520	512	0.161	662	12.0	0 x 0	VnIFix	st2
st2	Peak AVF	796	849	0.161	794	14.0	0 x 0	VnIFix	
st1	Peak AVF	304	251	0.270	558	10.0	0 x 0	VnIFix	

Bold/italic values have been manually overridden



Right-Suite® Universal 2019 19.0.18 RSU19927

2020-May-13 16:52:34

Page 1

...retDownloads\ELWOOD CONSTRUCTION HART-rvd.rup Calc = MJ8 Front Door faces: S

Return Branch Detail Table

Name	Grille Size (in)	Htg (cfm)	Clg (cfm)	TEL (ft)	Design FR	Veloc (fpm)	Diam (in)	H xW (in)	Stud/Joist Opening (in)	Duct Matl	Trunk
rb1	0x0	1100	1100	62.7	0.161	504	20.0	0x 0		VFX	rst3

Return Trunk Detail Table

Name	Trunk Type	Htg (cfm)	Clg (cfm)	Design FR	Veloc (fpm)	Diam (in)	H xW (in)	Duct Material	Trunk
rst3	Peak AVF	1100	1100	0.161	788	16.0	0 x 0	MnIFix	

Bold/italic values have been manually overridden