



Manual S Compliance Report

Entire House

E-Calcs Plus, Inc

Job: SFH - 285 Riverside Ave
Date: Apr 09, 2025
By: E-Calcs Plus, Inc

Serving all of Florida Phone: 833.322.5271 Email: eric@ecalcsplus.com Web: www.ecalcsplus.com License: HERS Rater ID# 0757810

Project Information

For: SFH - 285 Riverside Ave, High Springs Electric & Air
285 Riverside Ave, Fort White, FL 32038

Cooling Equipment

Design Conditions

Outdoor design DB:	91.9°F	Sensible gain:	24809	Btuh	Entering coil DB:	76.3°F
Outdoor design WB:	76.2°F	Latent gain:	5161	Btuh	Entering coil WB:	63.8°F
Indoor design DB:	75.0°F	Total gain:	29970	Btuh		
Indoor RH:	50%	Estimated airflow:	1093	cfm		

Manufacturer's Performance Data at Actual Design Conditions

Equipment type:	Split ASHP			
Manufacturer:	Trane	Model:	5TWX5036A1+5TEMCB03AV31++TDR+TSTAT	
Actual airflow:	1093	cfm		
Sensible capacity:	25125	Btuh	101% of load	
Latent capacity:	5369	Btuh	104% of load	
Total capacity:	30494	Btuh	102% of load	SHR: 82%

Heating Equipment

Design Conditions

Outdoor design DB:	33.0°F	Heat loss:	25995	Btuh	Entering coil DB:	70.0°F
Indoor design DB:	70.0°F					

Manufacturer's Performance Data at Actual Design Conditions

Equipment type:	Split ASHP				
Manufacturer:	Trane	Model:	5TWX5036A1+5TEMCB03AV31++TDR+TSTAT		
Actual airflow:	0	cfm			
Output capacity:	32400	Btuh	125% of load	Capacity balance:	27 °F
Supplemental heat required:	0	Btuh		Economic balance:	-95 °F

Backup equipment type:	Elec strip			
Manufacturer:	Trane	Model:	AFUE 100	
Actual airflow:	0	cfm		
Output capacity:	7.5	kW	98% of load	Temp. rise: 21 °F

Meets all requirements of ACCA Manual S.



Right-Suite® Universal 2025 25.0.01 RSU28254

...erside Ave\SFH - 285 Riverside Ave 4.9.2025.rup Calc = MJ8 Front Door faces: SW

2025-Apr-09 15:25:03

Page 1



Project Summary

Entire House

E-Calcs Plus, Inc

Job: SFH - 285 Riverside Ave
Date: Apr 09, 2025
By: E-Calcs Plus, Inc

Serving all of Florida Phone: 833.322.5271 Email: eric@ecalcsplus.com Web: www.ecalcsplus.com License: HERS Rater ID# 0757810

Project Information

For: SFH - 285 Riverside Ave, High Springs Electric & Air
285 Riverside Ave, Fort White, FL 32038

Notes:

Design Information

Weather: Gainesville Rgnl, FL, US

Winter Design Conditions

Outside db	33 °F
Inside db	70 °F
Design TD	37 °F

Ventilation Method ASHRAE 62.2-2010

Heating Summary

Structure	21507 Btuh
Ducts (R-6.0)	2608 Btuh
Central vent (46 cfm)	1880 Btuh
Outside air	
Humidification	0 Btuh
Piping	0 Btuh
Equipment load	25995 Btuh

Infiltration

Method	Simplified
Construction quality	Semi-tight
Fireplaces	0

	Heating	Cooling
Area (ft ²)	1646	1646
Volume (ft ³)	16460	16460
Air changes/hour	0.26	0.14
Equiv. AVF (cfm)	71	38

Heating Equipment Summary

Make	Trane
Trade	TRANE
Model	5TWX5036A1
AHRI ref	215863974

Efficiency	8.1 HSPF2
Heating input	
Heating output	32400 Btuh @ 47°F
Temperature rise	0 °F
Actual air flow	0 cfm
Air flow factor	0 cfm/Btuh
Static pressure	0.50 in H2O
Space thermostat	
Capacity balance point = 27 °F	

Backup: Trane AFUE 100
Input = 8 kW, Output = 25591 Btuh, 100 AFUE

Summer Design Conditions

Outside db	92 °F
Inside db	75 °F
Design TD	17 °F
Daily range	M
Relative humidity	50 %
Moisture difference	47 gr/lb

Sensible Cooling Equipment Load Sizing

Structure	20354 Btuh
Ducts (R-6.0)	3596 Btuh
Central vent (46 cfm)	859 Btuh
Outside air	
Blower	0 Btuh
Use manufacturer's data	y
Rate/swing multiplier	1.00
Equipment sensible load	24809 Btuh

Latent Cooling Equipment Load Sizing

Structure	1818 Btuh
Ducts	1869 Btuh
Central vent (46 cfm)	1473 Btuh
Outside air	
Equipment latent load	5161 Btuh

Equipment Total Load (Sen+Lat)	29970 Btuh
Req. total capacity at 0.75 SHR	2.8 ton

Cooling Equipment Summary

Make	Trane
Trade	TRANE
Cond	5TWX5036A1
Coil	5TEMCB03AV31++TDR+TSTAT
AHRI ref	215863974
Efficiency	12.0 EER2, 15.2 SEER2
Sensible cooling	24600 Btuh
Latent cooling	8200 Btuh
Total cooling	32800 Btuh
Actual air flow	1093 cfm
Air flow factor	0.046 cfm/Btuh
Static pressure	0.50 in H2O
Load sensible heat ratio	0.83

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



Right-Suite® Universal 2025 25.0.01 RSU28254

...erside Ave/SFH - 285 Riverside Ave 4.9.2025.rup Calc = MJ3 Front Door faces: SW

2025-Apr-09 15:25:03

Page 1



Load Short Form Entire House E-Calcs Plus, Inc

Job: SFH - 285 Riverside Ave
Date: Apr 09, 2025
By: E-Calcs Plus, Inc

Serving all of Florida Phone: 833.322.5271 Email: eric@ecalcsplus.com Web: www.ecalcsplus.com License: HERS Rater ID# 0757810

Project Information

For: SFH - 285 Riverside Ave, High Springs Electric & Air
285 Riverside Ave, Fort White, FL 32038

Design Information

	Htg	Clg	Infiltration	
Outside db (°F)	33	92	Method	Simplified
Inside db (°F)	70	75	Construction quality	Semi-tight
Design TD (°F)	37	17	Fireplaces	0
Daily range	-	M		
Inside humidity (%)	50	50		
Moisture difference (gr/lb)	33	47		

HEATING EQUIPMENT

Make Trane
Trade TRANE
Model 5TWX5036A1
AHRI ref 215863974

Efficiency 8.1 HSPF2
Heating input
Heating output 32400 Btuh @ 47°F
Temperature rise 0 °F
Actual air flow 0 cfm
Air flow factor 0 cfm/Btuh
Static pressure 0.50 in H2O
Space thermostat
Capacity balance point = 27 °F

Backup: Trane AFUE 100

Input = 8 kW, Output = 25591 Btuh, 100 AFUE

COOLING EQUIPMENT

Make Trane
Trade TRANE
Cond 5TWX5036A1
Coil 5TEMCB03AV31++TDR+TSTAT
AHRI ref 215863974

Efficiency 12.0 EER2, 15.2 SEER2
Sensible cooling 24600 Btuh
Latent cooling 8200 Btuh
Total cooling 32800 Btuh
Actual air flow 1093 cfm
Air flow factor 0.046 cfm/Btuh
Static pressure 0.50 in H2O
Load sensible heat ratio 0.83

ROOM NAME	Area (ft²)	Htg load (Btuh)	Clg load (Btuh)	Htg AVF (cfm)	Clg AVF (cfm)
MBR	154	2259	2493	0	114
MBA	91	2188	1033	0	47
MWIC	104	971	358	0	16
Utility	117	1238	1071	0	49
Studio	143	3580	4005	0	183
BA2	48	729	336	0	15
Vest	30	0	0	0	0
BR2	169	2946	1662	0	76
Kitchen	247	2318	880	0	40
Liv Din	543	7886	12113	0	553

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



Right-Suite® Universal 2025 25.0.01 RSU28254

...erside Ave\SFH - 285 Riverside Ave 4.9.2025.rup Calc = MJ8 Front Door faces: SW

2025-Apr-09 15:25:03

Page 1

Entire House	p	1646	24115	23951	0	1093
Other equip loads			1880	859		
Equip. @ 1.00 RSM				24809		
Latent cooling				5161		
TOTALS		1646	25995	29970	0	1093

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



Right-Suite® Universal 2025 25.0.01 RSU28254

...erside Ave\SFH - 285 Riverside Ave 4.9.2025.rup Calc = MJ8 Front Door faces: SW

2025-Apr-09 15:25:03

Page 2



Building Analysis Entire House E-Calcs Plus, Inc

Job: SFH - 285 Riverside Ave
Date: Apr 09, 2025
By: E-Calcs Plus, Inc

Serving all of Florida Phone: 833.322.5271 Email: eric@ecalcsplus.com Web: www.ecalcsplus.com License: HERS Rater ID# 0757810

Project Information

For: SFH - 285 Riverside Ave, High Springs Electric & Air
285 Riverside Ave, Fort White, FL 32038

Design Conditions

Location:

Gainesville Rgnl, FL, US
Elevation: 164 ft
Latitude: 30°N

Outdoor:

Drybulb (°F)
Daily range (°F)
Wet bulb (°F)
Wind speed (mph)

Heating

33
-
-
15.0

Cooling

92
18 (M)
76
7.5

Indoor:

Indoor temperature (°F)
Design TD (°F)
Relative humidity (%)
Moisture difference (gr/lb)

Heating

70
37
50
32.8

Cooling

75
17
50
46.9


Infiltration:

Method
Construction quality
Fireplaces

Simplified
Semi-tight
0


Heating

Component	Btuh/ft²	Btuh	% of load
Walls	2.4	2904	11.2
Glazing	9.8	5414	20.8
Doors	0	0	0
Ceilings	1.6	2619	10.1
Floors	4.7	7684	29.6
Infiltration	1.6	2886	11.1
Ducts		2608	10.0
Piping		0	0
Humidification		0	0
Ventilation		1880	7.2
Adjustments		0	0
Total		25995	100.0



Cooling

Component	Btuh/ft²	Btuh	% of load
Walls	1.2	1425	5.7
Glazing	22.7	12555	50.6
Doors	0	0	0
Ceilings	1.4	2325	9.4
Floors	0	0	0
Infiltration	0.4	710	2.9
Ducts		3596	14.5
Ventilation		859	3.5
Internal gains		3340	13.5
Blower		0	0
Adjustments		0	0
Total		24809	100.0




Latent Cooling Load = 5161 Btuh

Overall U-value = 0.100 Btuh/ft²-°F, Window / Floor Area = 33.6 %

WARNING: window to floor area ratio = 33.6% - more than 25%.



First Floor



Job #: SFH - 285 Riverside Ave
Performed by E-Calcs Plus, Inc for:

SFH - 285 Riverside Ave
285 Riverside Ave
Fort White, FL 32038

E-Calcs Plus, Inc

Serving all of Florida

Phone: 833.322.5271 License: HERS Rater ID# 075781
www.ecalcsplus.com eric@ecalcsplus.com

Scale: 1 : 93

Page 1

Right-Suite@Universal 2025

25.0.01 RSU28254

2025-Apr-09 15:25:27

...- 285 Riverside Ave 4.9.2025.rup



Duct System Summary

Entire House

E-Calcs Plus, Inc

Job: SFH - 285 Riverside Ave
Date: Apr 09, 2025
By: E-Calcs Plus, Inc

Serving all of Florida Phone: 833.322.5271 Email: eric@ecalcsplus.com Web: www.ecalcsplus.com License: HERS Rater ID# 0757810

Project Information

For: SFH - 285 Riverside Ave, High Springs Electric & Air
285 Riverside Ave, Fort White, FL 32038

	Heating	Cooling
External static pressure	0.50 in H ₂ O	0.50 in H ₂ O
Pressure losses	0.16 in H ₂ O	0.16 in H ₂ O
Available static pressure	0.34 in H ₂ O	0.34 in H ₂ O
Supply / return available pressure	0.216 / 0.124 in H ₂ O	0.216 / 0.124 in H ₂ O
Lowest friction rate	0.148 in/100ft	0.148 in/100ft
Actual air flow	0 cfm	1093 cfm
Total effective length (TEL)	230 ft	

Supply Branch Detail Table

Name	Design (Btuh)	Htg (cfm)	Clg (cfm)	Design FR	Diam (in)	H x W (in)	Duct Matl	Actual Ln (ft)	Ftg.Eqv Ln (ft)	Trunk
BA2	c 336	0	15	0.150	4.0	0x0	VIFx	29.0	115.0	st2
BR2	c 1662	0	76	0.148	6.0	0x0	VIFx	30.7	115.0	st2
Kitchen	c 880	0	40	0.154	5.0	0x0	VIFx	25.0	115.0	st2
Liv Din	c 4038	0	184	0.159	8.0	0x0	VIFx	20.4	115.0	st1
Liv Din-A	c 4038	0	184	0.168	8.0	0x0	VIFx	13.0	115.0	st1
Liv Din-B	c 4038	0	184	0.159	8.0	0x0	VIFx	20.4	115.0	st1
MBA	c 1033	0	47	0.162	5.0	0x0	VIFx	18.3	115.0	st3
MBR	c 2493	0	114	0.159	7.0	0x0	VIFx	20.3	115.0	st3
MWIC	c 358	0	16	0.163	4.0	0x0	VIFx	17.6	115.0	st3
Studio	c 4005	0	183	0.152	8.0	0x0	VIFx	26.6	115.0	st2
Utility	c 1071	0	49	0.150	5.0	0x0	VIFx	28.4	115.0	st3

Supply Trunk Detail Table

Name	Trunk Type	Htg (cfm)	Clg (cfm)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Duct Material	Trunk
st1	Peak AVF	0	553	0.159	704	12.0	0 x 0	VinIFlx	
st2	Peak AVF	0	314	0.148	576	10.0	0 x 0	VinIFlx	
st3	Peak AVF	0	226	0.150	512	9.0	0 x 0	VinIFlx	



Right-Suite® Universal 2025 25.0.01 RSU28254

...erside Ave\SFH - 285 Riverside Ave 4.9.2025.rup Calc = MJ8 Front Door faces: SW

2025-Apr-09 15:25:03

Page 1

Return Branch Detail Table

Name	Grille Size (in)	Htg (cfm)	Clg (cfm)	TEL (ft)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Stud/Joist Opening (in)	Duct Matl	Trunk
rb2	0x 0	0	177	73.5	0.169	508	8.0	0x 0		VIFx	
rb3	0x 0	0	91	84.0	0.148	464	6.0	0x 0		VIFx	
rb1	0x 0	0	825	63.0	0.197	591	16.0	0x 0		VIFx	



Static Pressure and Friction Rate

Entire House

E-Calcs Plus, Inc

Job: SFH - 285 Riverside Ave
Date: Apr 09, 2025
By: E-Calcs Plus, Inc

Serving all of Florida Phone: 833.322.5271 Email: eric@ecalcsplus.com Web: www.ecalcsplus.com License: HERS Rater ID# 0757810

Project Information

For: SFH - 285 Riverside Ave, High Springs Electric & Air
285 Riverside Ave, Fort White, FL 32038

Available Static Pressure

	Heating (in H2O)	Cooling (in H2O)
External static pressure	0.50	0.50
Pressure losses		
Coil	0	0
Heat exchanger	0	0
Supply diffusers	0.03	0.03
Return grilles	0.03	0.03
Filter	0.10	0.10
Humidifier	0	0
Balancing damper	0	0
Other device	0	0
Available static pressure	0.34	0.34

Total Effective Length

	Supply (ft)	Return (ft)
Measured length of run-out	18	24
Measured length of trunk	13	0
Equivalent length of fittings	115	60
Total length	146	84
Total effective length		230

Friction Rate

	Heating (in/100ft)		Cooling (in/100ft)	
Supply Ducts	0.148	OK	0.148	OK
Return Ducts	0.148	OK	0.148	OK

Fitting Equivalent Length Details

Supply 4AD=60, 11A=20, 1A=35: TotalEL=115

Return 6M=20, 5D=40: TotalEL=60