

FLORIDA ENERGY EFFICIENCY CODE FOR BUILDING CONSTRUCTION

Florida Department of Business and Professional Regulation - Residential Performance Method

Project Name: Will Robinson Residence
 Street: SW Little Road
 City, State, Zip: Lake City, FL, 32055-
 Owner: Will Robinson
 Design Location: FL, Gainesville

Builder Name: Ronnie Robinson
 Permit Office: Columbia Co
 Permit Number:
 Jurisdiction: 221000

1. New construction or existing New (From Plans)
 2. Single family or multiple family Single-family
 3. Number of units, if multiple family 1
 4. Number of Bedrooms 3
 5. Is this a worst case? No
 6. Conditioned floor area above grade (ft²) 1715
 Conditioned floor area below grade (ft²) 0

7. Windows (149.7 sqft.) Description Area
 a. U-Factor: Dbl, U=0.55 149.72 ft²
 SHGC: SHGC=0.60
 b. U-Factor: N/A ft²
 SHGC:
 c. U-Factor: N/A ft²
 SHGC:
 d. U-Factor: N/A ft²
 SHGC:

Area Weighted Average Overhang Depth: 4.509 ft.
 Area Weighted Average SHGC: 0.600

8. Floor Types (1715.0 sqft.) Insulation Area
 a. Slab-On-Grade Edge Insulation R=0.0 1715.00 ft²
 b. N/A R= ft²
 c. N/A R= ft²

9. Wall Types (1465.3 sqft.) Insulation Area
 a. Frame - Wood, Exterior R=13.0 1289.30 ft²
 b. Frame - Wood, Adjacent R=13.0 176.00 ft²
 c. N/A R= ft²
 d. N/A R= ft²

10. Ceiling Types (1715.0 sqft.) Insulation Area
 a. Under Attic (Vented) R=30.0 1715.00 ft²
 b. N/A R= ft²
 c. N/A R= ft²

11. Ducts R ft²
 a. Sup: Attic, Ret: Attic, AH: Main 6 428

12. Cooling systems kBtu/hr Efficiency
 a. Central Unit 35.0 SEER:14.00

13. Heating systems kBtu/hr Efficiency
 a. Electric Heat Pump 35.0 HSPF:7.70

14. Hot water systems
 a. Electric Cap: 40 gallons
 b. Conservation features EF: 0.920
 None

15. Credits Pstat

Glass/Floor Area: 0.087

Total Proposed Modified Loads: 29.74

Total Standard Reference Loads: 37.48

PASS

I hereby certify that the plans and specifications covered by this calculation are in compliance with the Florida Energy Code.

PREPARED BY: T. O. O'BrienDATE: 8/13/12

I hereby certify that this building, as designed, is in compliance with the Florida Energy Code.

OWNER/AGENT: _____

DATE: _____


Review of the plans and specifications covered by this calculation indicates compliance with the Florida Energy Code. Before construction is completed this building will be inspected for compliance with Section 553.908 Florida Statutes.

BUILDING OFFICIAL: _____

DATE: _____



- Compliance requires completion of a Florida Air Barrier and Insulation Inspection Checklist



PROJECT

Title: Will Robinson Residence	Bedrooms: 3	Address Type: Street Address
Building Type: User	Conditioned Area: 1715	Lot #
Owner: Will Robinson	Total Stories: 1	Block/SubDivision:
# of Units: 1	Worst Case: No	PlatBook:
Builder Name: Ronnie Robinson	Rotate Angle: 0	Street: SW Little Road
Permit Office: Columbia Co	Cross Ventilation:	County: Columbia
Jurisdiction: 221000	Whole House Fan:	City, State, Zip: Lake City , FL , 32055-
Family Type: Single-family		
New/Existing: New (From Plans)		
Comment:		

CLIMATE

✓	Design Location	TMY Site	IECC Zone	Design Temp 97.5 %	Design Temp 2.5 %	Int Design Temp Winter	Int Design Temp Summer	Heating Degree Days	Design Moisture	Daily Temp Range
_____	FL, Gainesville	FL_GAINESVILLE_REGI	2	32	92	70	75	1305.5	51	Medium

BLOCKS

Number	Name	Area	Volume
1	Block1	1715	13720

SPACES

Number	Name	Area	Volume	Kitchen	Occupants	Bedrooms	Infil ID	Finished	Cooled	Heated
1	Main	1715	13720	Yes	2	3	1	Yes	Yes	Yes

FLOORS

✓	#	Floor Type	Space	Perimeter	R-Value	Area	Tile	Wood	Carpet	
	1	Slab-On-Grade Edge Insulatio	Main	192.4 ft	0	1715 ft²	----	0.4	0.4	0.2

ROOF

✓	#	Type	Materials	Roof Area	Gable Area	Roof Color	Solar Absor.	SA Tested	Emitt	Emitt Tested	Deck Insul.	Pitch (deg)
_____	1	Gable or shed	Composition shingles	1918 ft²	430 ft²	Medium	0.96	No	0.9	No	0	26.6

ATTIC

✓	#	Type	Ventilation	Vent Ratio (1 in)	Area	RBS	IRCC
_____	1	Full attic	Vented	300	1715 ft²	N	N

CEILING

✓	#	Ceiling Type	Space	R-Value	Area	Framing Frac	Truss Type
_____	1	Under Attic (Vented)	Main	30	1715 ft²	0.11	Wood

WALLS

✓ #	Ornt	Adjacent To	Wall Type	Space	Cavity R-Value	Width Ft	In	Height Ft	In	Area	Sheathing R-Value	Framing Fraction	Solar Absor.	Below Grade%
1	N	Exterior	Frame - Wood	Main	13	25	0	8	0	200 ft²		0.23	0.75	0
2	E	Exterior	Frame - Wood	Main	13	60	8	8	0	485.3333		0.23	0.75	0
3	S	Exterior	Frame - Wood	Main	13	35	6	8	0	284 ft²		0.23	0.75	0
4	W	Exterior	Frame - Wood	Main	13	40	0	8	0	320 ft²		0.23	0.75	0
5	W	Garage	Frame - Wood	Main	13	22	0	8	0	176 ft²		0.23	0.75	0

DOORS

✓ #	Ornt	Door Type	Space	Storms	U-Value	Width Ft	In	Height Ft	In	Area
1	W	Insulated	Main	None	0.460000	3	0	6	8	20 ft²
2	W	Insulated	Main	None	0.460000	3	0	6	8	15.55555
3	W	Insulated	Main	None	0.460000	3	0	6	8	20 ft²

WINDOWS

Orientation shown is the entered, Proposed orientation.

✓ #	Ornt	Wall ID	Frame	Panes	NFRC	U-Factor	SHGC	Area	Overhang Depth	Separation	Int Shade	Screening
1	N	1	Vinyl	Low-E Double	Yes	0.55	0.6	4.444444	2 ft 0 in	8 ft 4 in	Drapes/blinds	None
2	N	1	Vinyl	Low-E Double	Yes	0.55	0.6	7.111111	2 ft 0 in	0 ft 4 in	Drapes/blinds	None
3	E	2	Vinyl	Low-E Double	Yes	0.55	0.6	7.111111	2 ft 0 in	0 ft 4 in	Drapes/blinds	None
4	E	2	Vinyl	Low-E Double	Yes	0.55	0.6	37.33333	2 ft 0 in	0 ft 4 in	Drapes/blinds	None
5	E	2	Vinyl	Low-E Double	Yes	0.55	0.6	7.111111	7 ft 0 in	0 ft 4 in	Drapes/blinds	None
6	E	2	Vinyl	Low-E Double	Yes	0.55	0.6	34.83333	7 ft 0 in	0 ft 4 in	Drapes/blinds	None
7	S	3	Vinyl	Low-E Double	Yes	0.55	0.6	2 ft²	2 ft 0 in	8 ft 4 in	Drapes/blinds	None
8	W	4	Vinyl	Low-E Double	Yes	0.55	0.6	12.44444	2 ft 0 in	0 ft 4 in	Drapes/blinds	None
9	W	4	Vinyl	Low-E Double	Yes	0.55	0.6	24.88888	8 ft 8 in	0 ft 4 in	Drapes/blinds	None
10	W	4	Vinyl	Low-E Double	Yes	0.55	0.6	12.44444	2 ft 0 in	0 ft 4 in	Drapes/blinds	None

GARAGE

✓ #	Floor Area	Ceiling Area	Exposed Wall Perimeter	Avg. Wall Height	Exposed Wall Insulation
1	454.74 ft²	454.74 ft²	58.9 ft	8 ft	1

INFILTRATION

#	Scope	Method	SLA	CFM 50	ELA	EqLA	ACH	ACH 50
1	Wholehouse	Best Guess	0.000500	2249.2	123.48	232.22	0.3850	9.8363

HEATING SYSTEM

✓	#	System Type	Subtype	Efficiency	Capacity	Block	Ducts
✓	1	Electric Heat Pump	None	HSPF: 7.7	35 kBtu/hr	1	sys#1

COOLING SYSTEM

✓	#	System Type	Subtype	Efficiency	Capacity	Air Flow	SHR	Block	Ducts
✓	1	Central Unit	Split	SEER: 14	35 kBtu/hr	1050 cfm	0.75	1	sys#1

HOT WATER SYSTEM

✓	#	System Type	SubType	Location	EF	Cap	Use	SetPnt	Conservation
✓	1	Electric	None	Main	0.92	40 gal	60 gal	120 deg	None

SOLAR HOT WATER SYSTEM

✓	FSEC Cert #	Company Name	System Model #	Collector Model #	Collector Area	Storage Volume	FEF
✓	None	None			ft²		

DUCTS

✓	#	Location	Supply R-Value	Area	Location	Return Area	Leakage Type	Air Handler	CFM 25	Percent Leakage	QN	RLF	HVAC # Heat	Cool
✓	1	Attic	6	428 ft²	Attic	85.75 ft	Default Leakage	Main	(Default)	(Default) %			1	1

TEMPERATURES

Programable Thermostat: Y														Ceiling Fans:													
Cooling	<input checked="" type="checkbox"/>	Jan	<input checked="" type="checkbox"/>	Feb	<input checked="" type="checkbox"/>	Mar	<input type="checkbox"/>	Apr	<input type="checkbox"/>	May	<input checked="" type="checkbox"/>	Jun	<input checked="" type="checkbox"/>	Jul	<input checked="" type="checkbox"/>	Aug	<input checked="" type="checkbox"/>	Sep	<input type="checkbox"/>	Oct	<input type="checkbox"/>	Nov	<input checked="" type="checkbox"/>	Dec			
Heating	<input checked="" type="checkbox"/>	Jan	<input checked="" type="checkbox"/>	Feb	<input checked="" type="checkbox"/>	Mar	<input type="checkbox"/>	Apr	<input type="checkbox"/>	May	<input checked="" type="checkbox"/>	Jun	<input checked="" type="checkbox"/>	Jul	<input checked="" type="checkbox"/>	Aug	<input checked="" type="checkbox"/>	Sep	<input type="checkbox"/>	Oct	<input type="checkbox"/>	Nov	<input checked="" type="checkbox"/>	Dec			
Venting	<input checked="" type="checkbox"/>	Jan	<input checked="" type="checkbox"/>	Feb	<input checked="" type="checkbox"/>	Mar	<input type="checkbox"/>	Apr	<input type="checkbox"/>	May	<input checked="" type="checkbox"/>	Jun	<input checked="" type="checkbox"/>	Jul	<input checked="" type="checkbox"/>	Aug	<input checked="" type="checkbox"/>	Sep	<input type="checkbox"/>	Oct	<input type="checkbox"/>	Nov	<input checked="" type="checkbox"/>	Dec			
Thermostat Schedule: HERS 2006 Reference														Hours													
Schedule Type			1	2	3	4	5	6	7	8	9	10	11	12													
Cooling (WD)		AM	78	78	78	78	78	78	78	78	78	78	78	78													
		PM	80	80	78	78	78	78	78	78	78	78	78	78													
Cooling (WEH)		AM	78	78	78	78	78	78	78	78	78	78	78	78													
		PM	78	78	78	78	78	78	78	78	78	78	78	78													
Heating (WD)		AM	66	66	66	66	66	68	68	68	68	68	68	68													
		PM	68	68	68	68	68	68	68	68	68	68	68	68													
Heating (WEH)		AM	66	66	66	66	66	68	68	68	68	68	68	68													
		PM	68	68	68	68	68	68	68	68	68	68	68	68													

MECHANICAL VENTILATION

Type	Supply CFM	Exhaust CFM	Fan Watts	HRV	Heating System	Run Time	Cooling System
None	0	0		0		0%	

Florida Code Compliance Checklist

Florida Department of Business and Professional Regulations
Residential Whole Building Performance Method

ADDRESS: SW Little Road
Lake City, FL, 32055-

PERMIT #:

MANDATORY REQUIREMENTS SUMMARY - See individual code sections for full details.

COMPONENT	SECTION	SUMMARY OF REQUIREMENT(S)	CHECK
Air leakage	402.4	To be caulked, gasketed, weatherstripped or otherwise sealed. Recessed lighting IC-rated as meeting ASTM E 283. Windows and doors = 0.30 cfm/sq.ft. Testing or visual inspection required. Fireplaces: gasketed doors & outdoor combustion air. Must complete envelope leakage report or visually verify Table 402.4.2.	✓
Thermostat & controls	403.1	At least one thermostat shall be provided for each separate heating and cooling system. Where forced-air furnace is primary system, programmable thermostat is required. Heat pumps with supplemental electric heat must prevent supplemental heat when compressor can meet the load.	✓
Ducts	403.2.2	All ducts, air handlers, filter boxes and building cavities which form the primary air containment passageways for air distribution systems shall be considered ducts or plenum chambers, shall be constructed and sealed in accordance with Section 503.2.7.2 of this code.	✓
	403.3.3	Building framing cavities shall not be used as supply ducts.	
Water heaters	403.4	Heat trap required for vertical pipe risers. Comply with efficiencies in Table 403.4.3.2. Provide switch or clearly marked circuit breaker (electric) or shutoff (gas). Circulating system pipes insulated to = R-2 + accessible manual OFF switch.	✓
Mechanical ventilation	403.5	Homes designed to operate at positive pressure or with mechanical ventilation systems shall not exceed the minimum ASHRAE 62 level. No make-up air from attics, crawlspaces, garages or outdoors adjacent to pools or spas.	✓
Swimming Pools & Spas	403.9	Pool pumps and pool pump motors with a total horsepower (HP) of = 1 HP shall have the capability of operating at two or more speeds. Spas and heated pools must have vapor-retardant covers or a liquid cover or other means proven to reduce heat loss except if 70% of heat from site-recovered energy. Off/timer switch required. Gas heaters minimum thermal efficiency=78% (82% after 4/16/13). Heat pump pool heaters minimum COP= 4.0.	N/A
Cooling/heating equipment	403.6	Sizing calculation performed & attached. Minimum efficiencies per Tables 503.2.3. Equipment efficiency verification required. Special occasion cooling or heating capacity requires separate system or variable capacity system. Electric heat >10kW must be divided into two or more stages.	✓
Ceilings/knee walls	405.2.1	R-19 space permitting.	