



**E.C. CASTLEBERRY**  
**LAND SURVEYING — MAPPING — LAND PLANNING**  
PROFESSIONAL LAND SURVEYOR FLORIDA  
REGISTRATION NO. 4226  
723 N.W. BALTIC ROAD  
MAYO, FLORIDA 32066 PHONE 407 508-8147  
email: ECCSURVEYING@outlook.com

January 28, 2023

RE: Finished Floor Elevation Parcel ID No. 12-6S-17-09651-000  
2263 SE October Road  
Lake City, Florida 32025

TO: Brandon D. & Tonya M. King

On December 19, 2022 I performed a Foundation Survey for the home under construction located at the above referenced address. On January 28, 2023 I returned to the site to determine the Finished Floor Elevation of the concrete foundation for the home. Below is the Datum and Benchmark information utilized to determine the vertical measurements and the results of those measurements:

Published Benchmark Used	— FDOT Point Name 2918002BM3
Published Elevation of Benchmark	— 84.97 feet North American Vertical Datum of 1988
Finished Floor Elevation	— 74.57 feet North American Vertical Datum of 1988

The measurements shown above meet or exceed the requirements for the Standards of Practice as established by the Florida Board of Professional Surveyors and Mappers as set forth in Chapter 5J-17, Florida Administrative Code.



Carol E. Castleberry, PLS  
Florida Professional Land Surveyor No. 4226