

CAROL CHADWICK, P.E.

Civil Engineer

1208 S.W. Fairfax Glen

Lake City, FL 32025

307.680.1772

ccpewyo@gmail.com

www.carolchadwickpe.com

December 15, 2020

Isaiah Cully

IC Construction LLC

386.867.0086

isaiahc@bellsouth.net

re: ELEVATION LETTER – 451 NW COUNTRY LAKE DRIVE, LAKE CITY, FL

As requested, I inspected the building site for the proposed construction at the above referenced site. The foundation walls for the home has been constructed at the time of the inspection. Based on the LIDAR on the Columbia County website, the existing road centerline elevation is 135.0 +/- . The finished floor elevation of the structure is 135.16. The finished floor of the home will be below the required elevation of 136.0. The topography of the site drainage away from the proposed structure in all directions.



Photo 1. Building site

I certify that the minimum finished floor elevation listed above will protect the structure against water damage from a base flood event, as defined in Article 8 of the Land Development Regulations.

Should you have any questions, please don't hesitate to contact me.

Respectfully,



Carol Chadwick, PE
cn=Carol Chadwick, PE, o=This
item has been electronically
signed and sealed by Carol
Chadwick, PE using a digital
signature., ou,
email=ccpewyo@gmail.com,
c=US
2020.12.15 21:37:56 -05'00'

Carol Chadwick, P.E.



NW LAKE VALLEY TER

NW COUNTRY LAKE DR