

**March 27, 2018**

Thomas Bulock  
1582 Drury Court  
St. Augustine, FL 32092

**Subject: Lot 25 Oaks of Lake City, Phase 1 - Elevation Letter**

Dear Thomas:

Daniel & Gore, LLC has performed a vertical survey on Lot 25, Oaks of Lake City Phase 1, Columbia County, Florida from a benchmark being a concrete monument (P.R.M.) at the P.C. of Lot 75, Oaks of Lake City Phase 2 (elevation – 91.745', NAVD 1988) and have determined the following:

- The Subdivision plat requires the minimum finish floor elevation to be 88.0'.
- The top of the foundation is at 91.4', being 3.4' above the minimum finish floor requirement.

If you have any questions, please call me.

Sincerely,



Scott Daniel, PSM