

CAROL CHADWICK, P.E.

Civil Engineer

1208 S.W. Fairfax Glen

Lake City, FL 32025

307.680.1772

ccpewyo@gmail.com

www.carolchadwickpe.com


February 11, 2025

re: ENGINEER'S REPORT – 161 SW COVEY COURT, LAKE CITY, FL

I have reviewed foundation construction and plumbing rough-in. Steel reinforcement in the footing was installed per plan. Fiber mesh concrete was installed in lieu of woven wire mesh.

In my professional opinion, this foundation meets the specifications in the 2023 Florida Building Code - Residential, 8th Edition. Should you have any questions, please don't hesitate to contact me.

Respectfully,

 Digitally signed by
Carol Chadwick
DN: c=US,
o=Florida,
dnQualifier=A0141
0D000018D463B
4E7500032FEE,
cn=Carol
Chadwick
Date: 2025.02.11
13:45:02 -05'00'

Carol Chadwick, P.E.

This item has been digitally signed and sealed by Carol Chadwick, P.E. on the date adjacent to the seal. Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.
CC Job FL24618



