

FIELD DENSITY WORKSHEET

CLIENT America Home Place DATE 12-17-21
 PROJECT NAME Don Cook Way (ft White) PROJECT NO. _____
 EARTH CONTRACTOR _____ PERMIT NO. 000043345
 COMPACTION REQUIREMENT (%) 95 ☐ Standard Proctor TESTED BY 15
☒ Modified Proctor FIELD CONTACT _____
 TOTAL ON-SITE TIME _____ MILES FROM OFFICE _____
☐ Limerock ☐ Subgrade ☐ Pipe Backfill ☒ Building Pad ☐ Building Footing ☐ Other _____

TEST LOCATION	LAB PROCTOR		TEST DEPTH	PROBE DEPTH	% MOIST.	WET DENSITY (PCF)	DRY DENSITY (PCF)	% COMP.
	DENS.	OMC						
App 10' NW of SE corner	105.1	11.7	F/G	12"	5.6	106.9	101.2	96.3
App center area of pad	↓	↓	↓	↓	4.9	105.4	100.5	95.6
App 10' SE of NW pad corner	↓	↓	↓	↓	5.1	105.0	99.9	95.1

REMARKS _____

* Density failed to meet minimum project requirement
 ** Retest indicates minimum density requirement was obtained.
 () Client is aware of unsatisfactory test results.