



Britt Surveying and Mapping, LLC
2086 SW Main Blvd Ste 112 • Lake City, FL 32025
386-752-7163 P • 386-752-5573 F • www.brittsurvey.com

04/23/2021

Permit # 000041493

L-27504

Lipscomb & Eagle

Re: Lot 18 Turkey Creek

To Whom It May Concern:

The top of the finished slab on said Lot 18 is 159.79 feet. The minimum floor elevation is 159.25 feet per the building permit. The elevations shown hereon are based on NAVD 88 datum.

Sincerely,

A handwritten signature in blue ink, appearing to read "L. Scott Britt", is written over a faint, circular, textured background.

L. Scott Britt
LS 5757