

Notice of Prevention for Subterranean Termites
(As required by Florida Building Code (FBC) 104.2.6)



A locally owned
company serving
you since 1972

17856 U.S. 129 • McALPIN, FLORIDA 32062
(386) 362-3887 • 1-800-771-3887 • Fax: (386) 364-3529

613 SE ROSEWOOD CIRCLE LAKE CITY FL.

Address of Treatment or Lot/Block of Treatment

1-25-74

8:30 AM

OTTO #84

Date

Time

Applicator

PRIMISE

IMIRAC/APRO

215.7 gal

Product Used

Chemical used (active ingredient)

Number of gallons applied

1.9%

1970

354

Percent Concentration

Area treated (square feet)

Linear feet treated

SUPPORTED SLAB

Stage of treatment (Horizontal, Vertical, Adjoining Slab, retreat of disturbed area)

As per 104.2.6 - If soil chemical barrier method for Subterranean termite prevention is used, final exterior treatment shall be completed prior to final building approval.

The building has received a complete treatment for the prevention of subterranean termites. Treatment is in accordance with rules & laws established by the Florida Department of Agriculture & Consumer Services. Initial and date this line.

If this notice is for the final exterior treatment initial and date this line. _____