From: Matt Forath
To: Columbia County Building and Zoning Info
Subject: Compaction test permit number 54, 541
Date: Friday, December 5, 2025 10:52:12 AM

GEO-TECH, INC.

Engineering Consultants in Geotechnical • Environmental • Construction Materials Testing

FIELD DENSITY WORKSHEET

#54541

CLIENT Dwarring Home Plaza

DATE 12-3-25

PROJECT NAME 242 SW Coldwater Lake City

PROJECT NO.

EARTH CONTRACTOR

PERMIT NO.

TESTED BY LC

COMPACTION REQUIREMENT (%) 95

☐ Standard Proctor
☑ Modified Proctor

FIELD CONTACT

TOTAL ON-SITE TIME

MILES FROM OFFICE

☐ Limerock ☐ Subgrade ☐ Pipe Backfill ☑ Building Pad ☑ Building Footing ☐ Other

TEST LOCATION	LAB PROCTOR DENS.	LAB PROCTOR OMC	TEST DEPTH	PROBE DEPTH	% MOIST.	WET DENSITY (PCF)	DRY DENSITY (PCF)	% COMP.
Approx 15 ft off SW corner	108.3	9.5	FG	12"	4.9	112.6	107.3	99.1
15 SW of NE corner					4.0	109.9	105.7	97.6
6 ft off South footing					4.6	111.5	106.6	98.4

REMARKS

* Density failed to meet minimum project requirement

** Retest indicates minimum density requirement was obtained.

( ) Client is aware of unsatisfactory test results.

1016 S.E. 3RD AVENUE • OCALA, FLORIDA 34471 • (352) 694-7711

Sent from my iPhone