



---

**Britt Surveying and Mapping, LLC**  
2086 SW Main Blvd Ste 112 • Lake City, FL 32025  
386-752-7163 P • 386-752-5573 F • [www.brittsurvey.com](http://www.brittsurvey.com)

07/08/2021

Permit # 000042027

L-27746

Cornerstone Development

Re: Lot 92 Emerald Cove

To Whom It May Concern:

The top of the finished slab on said Lot 92 is 111.26 feet. The centerline of SW Timberland Court is 110.44 feet. The building permit requires the minimum floor to be 110 feet. The elevations shown hereon are based on NAVD 88 datum.

Sincerely,

  
L. Scott Britt  
LS 5757

