

October 8, 2025

Mr. Nick Aparo
Permitting & Warranty Coordinator
Adams Homes of Northwest FL, Inc.
100 SW 75th Street, Suite 107
Gainesville, FL 32607

Re: Elevation Certification – PL038 581 Bellflower

Dear Nick:

LJA Engineering has reviewed the approved drainage calculations, engineering plans and the plat for the Preserve at Laurel Lake, Unit 1 for lot 38 (PL038). Lot 38 is not located within wetlands or a floodplain. It is located with Zone X.

Lot 38 is located within the drainage area of Basin 6 which has a 100-year flood elevation of 103.84'. Based on the plat, the minimum finished floor elevation for lot 38 is 106.9'. The minimum finished floor elevation of the house shall not be lower than 105.75'. The structure will comply with Article 8 of the Land Development Regulations at this finished floor elevation.

Please do not hesitate to contact me with any questions or comments.

Sincerely,

A handwritten signature in blue ink that reads 'Christopher Potts'.

Christopher A. Potts P.E.
Vice President
LJA Engineering