

**October 26, 2020**

David Simque  
Simque Construction  
Lake City, FL 32025

**Subject: Permit #40342 - Lot 3, Emerald Cove - Elevation Letter**

Dear Aaron:

Daniel & Gore, LLC has performed a vertical survey on Lot 3, Emerald Cove, Columbia County, Florida from a benchmark being a FDOT concrete monument 2901003 BM32 (elevation – 159.61', NAVD 1988) and have determined the following:

- The Elevation Letter per Carol Chadwick, P.E. requires the minimum finish floor elevation to be 103.0'.
- The finish floor elevation of the foundation is at 104.7', being the 1.7' above the minimum finish floor requirement.

If you have any questions, please call me.

Sincerely,



Scott Daniel, PSM