

June 29, 2022

Morgan Balree
352-745-8228

Subject: Elevation Letter – 845 SW Loncala Loop, Fort White

Dear Morgan:

Daniel & Gore, LLC has performed a vertical survey on Parcel #00502-225, Columbia County, Florida from a benchmark being a FDOT benchmark (3703001 BM10) on a concrete monument with an elevation of 39.27' (NAVD 1988) and have determined the following:

- We have set a TBM (60d nail) in a 10" Live Oak near the SW corner of the home site with an elevation of 60.3' (NAVD 1988), being 1 foot above the base flood elevation.
- We have determine that the finish floor elevation of the residence to be 60.68' (NAVD 1988).

If you have any questions, please call me.

Sincerely,



Scott Daniel, PSM