



NFPS



PO BOX 3823
LAKE CITY, FL 32056



PHONE (386) 752-4675
FAX (386) 752-4674



www.nfps.net

DATE: Thursday, August 18, 2022

TO: Columbia County Building Department

FROM: James B. Smith, PSM – North Florida Professional Services

CC: Milton Smith

RE: Finished Floor Elevation – 151 SW White Ash Gln., Lake City FL 32024

This is to certify that the following elevations of were obtained on the finished floor of a building constructed on Parcel # 04-4S-16-02439-114 at the address of 151 SW White Ash Gln., Lake City, FL 32024

Permit # 44716 FFE: 118.40'

The required elevation is 118.00'

James B. Smith, PSM
Florida Certification No. 7355

