







December 12, 2024

Troy Crews Building Official Columbia County Building Department 135 NE Hernando Ave Ste 21 Lake City, FL 32055

RE: DESIGN FINISHED FLOOR ELEVATION (FFE) vs ACTUAL FINISHED FLOOR ELEVATION; BETHLEHEM COMMUNITY CENTER

Mr. Crews,

The design FFE of the Bethlehem Community Center, as stated on the construction plans, was to be 104.25'. The actual FFE, as determined by field survey, was 104.20'. This difference is less than 5/8" and is within allowable construction tolerances for this project and doesn't adversely impact the use and function of the facility.

If you have any questions, do not hesitate to contact me.

Sincerely,

Digitally signed by Robert P Blahop

DN: Un-Mobiler P Blance,
DN: Un-Mo

R. P. (Phil) Bishop, Jr., P.E. Director of Construction Services North Florida Professional Services, Inc.