


31666



**Britt Surveying and Mapping, LLC**  
2086 SW Main Blvd Ste 112 • Lake City, FL 32025  
386-752-7163 P • 386-752-5573 F • [www.brittsurvey.com](http://www.brittsurvey.com)

OK  
BLK  
1 May 2014

1-15-14

L-22930

Re: Lot 8 of May-Fair Unit 3

To Whom It May Concern:

The elevation of the finished floor of the stem wall on Lot 8 is found to be 162.05 feet. The minimum floor elevation per the plat of record is 161.00 feet. The elevation of the lowest adjacent grade is 159.3 feet. The elevation of the highest adjacent grade is 160.5 feet. All elevations shown hereon are on plat datum, NGVD 29.

Sincerely,

L. Scott Britt  
LS 5757