

CAROL CHADWICK, P.E.

Civil Engineer

1208 S.W. Fairfax Glen

Lake City, FL 32025

307.680.1772

ccpewyo@gmail.com

www.carolchadwickpe.com

May 4, 2024

Bryan Zecher

Bryan Zecher Construction

386.752.8653

bzzecher@comcast.net

re: ELEVATION LETTER – 292 SW GREENWOOD TERRACE, FORT WHITE, FL

As requested, I inspected the building site for the proposed construction at the above referenced site. The foundation was constructed. The attached flood report shows no floodplains or wetlands.



The minimum finished floor elevation shall be 1' above the adjacent ground for the entire perimeter of the foundation, except driveways, sidewalks and thresholds. The finished floor

elevation will be below the required 1' above the adjacent road; however, it is sufficient to protect the home from water damage in a base flood event.

I certify that the minimum finished floor elevation will protect the structure against water damage from a base flood event, as defined in Article 8 of the Land Development Regulations.

Should you have any questions, please don't hesitate to contact me.

Respectfully,

 Digitally signed by
Carol Chadwick
DN: c=US,
o=Florida,
dnQualifier=A0141
0D0000018D463B4
E7500032FEE,
cn=Carol Chadwick
Date: 2024.05.04
20:00:25 -04'00'

Carol Chadwick, P.E.

attachment: site plan by others & SRWMD Flood Report

This item has been digitally signed and sealed by Carol Chadwick, P.E. on the date adjacent to the seal. Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.
CC Job #FL24221

