

ES/DP

FIELD DENSITY WORKSHEET

CLIENT Red 1000 homes DATE 12-77-22
4344 SE CR 245 Lake City
 PROJECT NAME _____ PROJECT NO. _____
 EARTH CONTRACTOR _____ PERMIT NO. _____
 COMPACTION REQUIREMENT (%) 95 ☐ Standard Proctor TESTED BY BTS
☒ Modified Proctor FIELD CONTACT _____
 TOTAL ON-SITE TIME _____ MILES FROM OFFICE _____
☐ Limerock ☐ Subgrade ☐ Pipe Backfill ☒ Building Pad ☐ Building Footing ☐ Other _____

TEST LOCATION	LAB PROCTOR		TEST DEPTH	PROBE DEPTH	% MOIST.	WET DENSITY (PCF)	DRY DENSITY (PCF)	% COMP.
	DENS.	OMC						
APX 15' SE of NW corner	108.8	9.9	FC"	12"	4.1	104.3	103.7	95.3
APX 15' NE of SW corner	2	6	5	5	6.3	110.0	103.5	95.1
APX 15' W of E corner					5.7	109.1	103.2	95

REMARKS copy left in permit box
photo sent to client

* Density failed to meet minimum project requirement
 ** Retest indicates minimum density requirement was obtained.
 () Client is aware of unsatisfactory test results.