

DATE . 09/02/2009

Columbia County Building Permit

This Permit Must Be Prominently Posted on Premises During Construction

PERMIT

000028050

APPLICANT WENDY GRENNELL PHONE 497-2311
ADDRESS PO BOX 39 FORT WHITE FL 32038
OWNER TIMOTHY & YVONNE PARKER PHONE 758-1736
ADDRESS 551 SW ARCHIE GLEN LAKE CITY FL 32024
CONTRACTOR WALTER MEDFORD PHONE 352-339-0478
LOCATION OF PROPERTY 90 W, L (CR 252-A) KOONVILLE RD, L ARCHIE GLEN,
TO END ON LEFT
TYPE DEVELOPMENT MH,UTILITY ESTIMATED COST OF CONSTRUCTION 0.00
HEATED FLOOR AREA TOTAL AREA HEIGHT STORIES
FOUNDATION WALLS ROOF PITCH FLOOR
LAND USE & ZONING AG-3 MAX. HEIGHT 35
Minimum Set Back Requirments: STREET-FRONT 30.00 REAR 25.00 SIDE 25.00
NO. EX.D.U. 1 FLOOD ZONE X DEVELOPMENT PERMIT NO.

PARCEL ID 26-3S-15-00270-109 SUBDIVISION CEDAR HILLS
LOT 9 BLOCK PHASE UNIT TOTAL ACRES 4.18

IH0000056
Culvert Permit No. Culvert Waiver Contractor's License Number Applicant/Owner/Contractor Wendy Grennell
EXISTING 09-0462-E CS WR N
Driveway Connection Septic Tank Number LU & Zoning checked by Approved for Issuance New Resident

COMMENTS: FLOOR ONE FOOT ABOVE THE ROAD
EXISTING MH TO BE REMOVED
 Check # or Cash 5341

FOR BUILDING & ZONING DEPARTMENT ONLY

(footer/Slab)

Temporary Power Foundation Monolithic
 date/app. by date/app. by date/app. by
Under slab rough-in plumbing Slab Sheathing/Nailing
 date/app. by date/app. by date/app. by
Framing Insulation
 date/app. by date/app. by
Rough-in plumbing above slab and below wood floor Electrical rough-in
 date/app. by date/app. by
Heat & Air Duct Peri. beam (Lintel) Pool
 date/app. by date/app. by date/app. by
Permanent power C.O. Final Culvert
 date/app. by date/app. by date/app. by
Pump pole Utility Pole M/H tie downs, blocking, electricity and plumbing
 date/app. by date/app. by date/app. by
Reconnection RV Re-roof
 date/app. by date/app. by date/app. by

BUILDING PERMIT FEE \$ 0.00 CERTIFICATION FEE \$ 0.00 SURCHARGE FEE \$ 0.00
MISC. FEES \$ 300.00 ZONING CERT. FEE \$ 50.00 FIRE FEE \$ 0.00 WASTE FEE \$
FLOOD DEVELOPMENT FEE \$ FLOOD ZONE FEE \$ 25.00 CULVERT FEE \$ TOTAL FEE 375.00
INSPECTORS OFFICE Z. H. CLERKS OFFICE CH

NOTICE: IN ADDITION TO THE REQUIREMENTS OF THIS PERMIT, THERE MAY BE ADDITIONAL RESTRICTIONS APPLICABLE TO THIS PROPERTY THAT MAY BE FOUND IN THE PUBLIC RECORDS OF THIS COUNTY. AND THERE MAY BE ADDITIONAL PERMITS REQUIRED FROM OTHER GOVERNMENTAL ENTITIES SUCH AS WATER MANAGEMENT DISTRICTS, STATE AGENCIES, OR FEDERAL AGENCIES.

"WARNING TO OWNER: YOUR FAILURE TO RECORD A NOTICE OF COMMENCEMENT MAY RESULT IN YOUR PAYING TWICE FOR IMPROVEMENTS TO YOUR PROPERTY. IF YOU INTEND TO OBTAIN FINANCING, CONSULT WITH YOUR LENDER OR AN ATTORNEY BEFORE RECORDING YOUR NOTICE OF COMMENCEMENT."

EVERY PERMIT ISSUED SHALL BECOME INVALID UNLESS THE WORK AUTHORIZED BY SUCH PERMIT IS COMMENCED WITHIN 180 DAYS AFTER ITS ISSUANCE, OR IF THE WORK AUTHORIZED BY SUCH PERMIT IS SUSPENDED OR ABANDONED FOR A PERIOD OF 180 DAYS AFTER THE TIME THE WORK IS COMMENCED. A VALID PERMIT RECIEVES AN APPROVED INSPECTION EVERY 180 DAYS. WORK SHALL BE CONSIDERED NOT SUSPENDED, ABANDONED OR INVALID WHEN THE PERMIT HAS RECIEVED AN APPROVED INSPECTION WITHIN 180 DAYS OT THE PREVIOUS INSPECTION.

The Issuance of this Permit Does Not Waive Compliance by Permittee with Deed Restrictions.

Clt# 5341

PERMIT APPLICATION / MANUFACTURED HOME INSTALLATION APPLICATION

For Office Use Only (Revised 1-10-08)		Zoning Official <u>aps 9/1/09</u>		Building Official <u>we 8/31/09</u>	
AP# <u>0908-52</u>	Date Received <u>8/28/09</u>	By <u>G</u>	Permit # <u>28050</u>		
Flood Zone <u>X</u>	Development Permit <u>—</u>	Zoning <u>A-3</u>	Land Use Plan Map Category <u>A-3</u>		
Comments <u>Existing MH to be removed.</u>					
FEMA Map# <u>—</u>	Elevation <u>—</u>	Finished Floor <u>—</u>	River <u>—</u>	In Floodway <u>—</u>	
☒ Site Plan with Setbacks Shown	☒ EH # <u>09-0462E</u>	☐ EH Release	☐ Well letter	☒ Existing well	
☒ Recorded Deed or Affidavit from land owner	☐ Letter of Auth. from installer	☐ State Road Access			
☐ Parent Parcel # <u>—</u>	☐ STUP-MH <u>—</u>	☐ F W Comp. letter			
IMPACT FEES: EMS <u>—</u>		Fire <u>—</u>	Corr <u>—</u>	Road/Code <u>—</u>	
School <u>—</u>		= TOTAL <u>—</u>			

Property ID # 26-35-15-00270-109 Subdivision Cedar Hills Lot 9

- New Mobile Home ☒ Used Mobile Home — MH Size 28x72 Year 2010
- Applicant Wendy Grennell Dale Breed or Rocky Ford Phone # 386-497-2311
- Address PO Box 39 Ft White FL 32038
- Name of Property Owner Timothy + Yvonne Parker Phone# 386-758-1736
- 911 Address 551 SW Archie Glen Lake City 32024
- Circle the correct power company - FL Power & Light - Clay Electric
 (Circle One) - Suwannee Valley Electric - Progress Energy
- Name of Owner of Mobile Home Timothy + Yvonne Parker Phone # 386-758-1736
 Address 551 SW Archie Glen Lake City FL 32024
- Relationship to Property Owner same
- Current Number of Dwellings on Property 1 - to be replaced - same location
- Lot Size — Total Acreage 4.18
- Do you : Have Existing Drive or Private Drive or need Culvert Permit or Culvert Waiver (Circle one)
 (Currently using) (Blue Road Sign) (Putting in a Culvert) (Not existing but do not need a Culvert)
- Is this Mobile Home Replacing an Existing Mobile Home Yes (pd)
- Driving Directions to the Property Hwy 90 West to Koonville Rd (CR 252A) turn (L) to Archie Glen turn (L) to end on (L)
- Name of Licensed Dealer/Installer Walter Medford Phone # 352-339-0478
- Installers Address 11924 NW 39th Ave Gainesville FL 32606
- License Number JH0000056 Installation Decal # 303995

AUG-17-2009 07:57A FROM: A & B CONSTRUCTION 3864974866

TO: 3523327050

P.2

page 1 of 2

COLUMBIA COUNTY PERMIT WORKSHEET

These worksheets must be completed and signed by the installer.
Submit the originals with the permit.

Installer Walter Medford License # IH-0000056

911 Address where home is being installed 551 SW Archie Glenbox


Manufacturer Nobility Length x width 72 X 28

NOTE: If home is a single with fill out one half of the blocking plan
If home is a triple or quad wide sketch in remainder of home

I understand Lateral Arm Systems cannot be used on any home (new or used)
where the sidewall rise exceeds 5 ft 4 in.

Installer's initials W.R.N.

Typical pier spacing 2' 8 1/2"
Show locations of Longitudinal and Lateral Systems
(Use dark lines to show these locations)



New Home ☒ Used Home ☐
Home installed to the Manufacturer's Installation Manual ☒

Home is installed in accordance with Rule 15-C

Single wide ☐ Wind Zone # ☒ Wind Zone ☐

Double wide ☒ Installation Detail # 303995

Title/Quad ☐ Serial # N1-

PIER SPACING TABLE FOR USED HOMES

Load bearing capacity	Footer size (sq in)	16" x 16" (256)	18 1/2" x 18 1/2" (342)	20" x 20" (400)	22" x 22" (484)	24" x 24" (576)	26" x 26" (676)
1000 lbs	3"	4"	4"	5"	5"	6"	6"
1500 lbs	4"	5"	5"	6"	6"	7"	7"
2000 lbs	5"	6"	6"	7"	7"	8"	8"
2500 lbs	6"	7"	7"	8"	8"	9"	9"
3000 lbs	7"	8"	8"	9"	9"	10"	10"
3500 lbs	8"	9"	9"	10"	10"	11"	11"

* Interpolated from Rule 15C-1 pier spacing table.

PIER PAD SIZES

I-beam pier pad size 21 X 27
Perimeter pier pad size Per Diagram
Other pier pad sizes (required by the mfg.) See Attached

Draw the approximate locations of marriage wall openings 4 foot or greater. Use this symbol to show the piers.

List all marriage wall openings greater than 4 foot and their pier pad sizes below.

Opening See Attached Pier pad size See Attached

ANCHORS 4 ft X 6 ft

FRAME TIES

within 2' of end of home spaced at 5' 4" oc

TIEDOWN COMPONENTS

Longitudinal Stabilizing Device (LSD)

Manufacturer Oliver Tech. (101-V)

Longitudinal Stabilizing Device w/ Lateral Arms

OTHER TIES

Sidewall

Longitudinal

Marriage wall

Shearwall

Number Every 5-4"

Per Housers

On Home

COLUMBIA COUNTY PERMIT WORKSHEET

page 2 of 2

POCKET PENETROMETER TEST

The pocket penetrometer tests are rounded down to _____ psi or check here to declare 1000 lb. soil _____ without testing.

x 1000 x 1000 x 1000

POCKET PENETROMETER TESTING METHOD

- 1. Test the perimeter of the home at 8 locations.
- 2. Take the reading at the depth of the footer.
- 3. Using 500 lb. increments, take the lowest reading and round down to that increment.

x 1000 x 1000 x 1000

TORQUE PROBE TEST

The results of the torque probe test is 280 inch pounds or check here if you are declaring 5' anchors without testing. A test showing 275 inch pounds or less will require 5 foot anchors.

Note: A state approved lateral arm system is being used and 4 ft. anchors are allowed at this sidewall locations. I understand 5 ft anchors are required at all corners/ends the points where the torque test reading is 275 or less and where the mobile home manufacturer may require anchors with 4000 lb holding capacity.

Installer's Initials

ALL TESTS MUST BE PERFORMED BY A LICENSED INSTALLER

Installer Name Walter Medford
Date Tested 8/17/09

Electrical

Connect electrical conductors between multi-wide units, but not to the main power source. This includes the bonding wire between multi-wide units. Pg. 43

Plumbing

Connect all sewer drains to an existing sewer tap or septic tank. Pg. 55
Connect all potable water supply piping to an existing water meter, water tap, or other independent water supply systems. Pg. 44

Site Preparation

Debris and organic material removed ☒ Pad ☒ Other _____
Water drainage: Natural _____ Swale _____

Fastening multi-wide units

Floor: Type Fastener: 3/8 Lags Length: 5" Spacing: 24" OC
Water: Type Fastener: 3/8" Length: 4" Spacing: 24" OC
Roof: Type Fastener: 2.5" 30 Gauge Length: 12" Spacing: 8" OC
For used homes a min. 30 gauge, 5" wide, galvanized metal strip will be centered over the peak of the roof and fastened with gbk. roofing nails at 2' on center on both sides of the centerline.

Gasket (weatherstripping) requirements

I understand a properly installed gasket is a requirement of all new and used homes and that contamination, mold, mildew and buckled marriage walls are a result of a poorly installed or no gasket being installed. I understand a strip of tape will not serve as a gasket.

Installer's Initials WRH

Type gasket Foam Installed: ☒
Pg. 14 Between Floors Yes ☒
Between Walls Yes ☒
Bottom of ridgebeam Yes ☒

Weatherstripping

The bottomboard will be repaired and/or taped. Yes ☒
Siding on units is installed to manufacturer's specifications. Yes ☒
Fireplace chimney installed so as not to allow intrusion of rain water. Yes ☒

Miscellaneous

Skirting to be installed. Yes ☒ No ☒
Over vent installed outside of skirting. Yes ☒ N/A ☒
Range downflow vent installed outside of skirting. Yes ☒ N/A ☒
Drain lines supported at 4 foot intervals. Yes ☒
Electrical crossovers protected. Yes ☒
Other: _____


Installer verifies all information given with this permit worksheet is accurate and true based on the

Installer Signature Walter Medford Date 8/17/09

AUG/17/2009/MON 08:03 AM Nobility Homes, Inc.


FAX No. 352 732 4203

P. 002



NOBILITY HOMES, INC.

ADDENDUM TO INSTALLATION MANUAL



APPROVED
NEW
 OCT 16 2006
 Federal Manufactured
 Home Construction
 And Safety Standards
APPROVED

APPROVED
NEW
 FEB 10 2007
 Federal Manufactured
 Home Construction
 And Safety Standards
APPROVED




DRAWING VALID FOR CONTINUOUS
 RIDGE BEAM CONSTRUCTION WITH
 UPLIFT ANCHORS INSTALLED TO
 PREVENT UPLIFT WIND FROM
 BEING SUPPORTED BY P.T. JOISTS
 AT MATE LINE IN PORCH AREA


SU-67

NH
 NOBILITY HOMES, INC.
 BUCKLE UP, FLORIDA

SITE PLAN EXAMPLE / WORKSHEET



Use this example to draw your own site plan. Show all existing buildings and any other homes on this property and show the distances between them, Also show where the roads or roads are around the property. This site plan can also be used for the 911 Addressing department if you include the distance from the driveway to the nearest property line.



Columbia County Property Appraiser

DB Last Updated: 7/22/2009

Parcel: 26-3S-15-00270-109 HX VX

2009 Preliminary Values[Tax Record](#)[Property Card](#)[Interactive GIS Map](#)[Print](#)**Owner & Property Info**

Owner's Name	PARKER TIMOTHY A & YVONNE M		
Site Address	ARCHIE		
Mailing Address	551 SW ARCHIE GLN LAKE CITY, FL 32024		
Use Desc. (code)	MOBILE HOM (000200)		
Neighborhood	026315.01	Tax District	3
UD Codes	MKTA01	Market Area	01
Total Land Area	0.000 ACRES		
Description	LOT 9 CEDAR HILLS S/D. ORB 783-2098, 857-672. WD 1156-103(REORG OF GRANTOR) QC 1167-1332		

<< Prev Search Result: 59 of 64 Next >>

GIS Aerial**Property & Assessment Values**

Mkt Land Value	cnt: (3)	\$35,150.00
Ag Land Value	cnt: (0)	\$0.00
Building Value	cnt: (1)	\$15,314.00
XFOB Value	cnt: (2)	\$1,300.00
Total Appraised Value		\$51,764.00

Just Value	\$51,764.00
Class Value	\$0.00
Assessed Value	\$45,711.00
Exemptions	(code: HX VX) \$30,000.00
Total Taxable Value	County: \$15,711.00 City: \$15,711.00 Other: \$15,711.00 School: \$15,711.00

Sales History

Sale Date	Book/Page	Inst. Type	Sale VImp	Sale Qual	Sale RCode	Sale Price
7/31/2008	1156/103	WD	I	U	02	\$100.00
9/3/1992	783/2098	CD	I	U	13	\$21,500.00
3/13/1991	0/	CD	V	U	13	\$21,500.00

Building Characteristics

Bldg Item	Bldg Desc	Year Blt	Ext. Walls	Heated S.F.	Actual S.F.	Bldg Value
1	MOBILE HME (000800)	1992	Below Avg. (03)	1064	1264	\$15,314.00
Note: All S.F. calculations are based on exterior building dimensions.						

Extra Features & Out Buildings

Code	Desc	Year Blt	Value	Units	Dims	Condition (% Good)
0296	SHED METAL	1996	\$800.00	0000001.000	10 x 28 x 0	(000.00)
0285	SALVAGE	2005	\$500.00	0000001.000	0 x 0 x 0	(000.00)

Land Breakdown

Lnd Code	Desc	Units	Adjustments	Eff Rate	Lnd Value
000200	MBL HM (MKT)	0000001.000 LT - (00000000.000AC)	1.00/1.00/1.00/1.00	\$32,400.00	\$32,400.00

MOBILE HOME INSTALLER AFFIDAVIT

As per Florida Statutes Section 320.8249 Mobile Home Installers License

Any person who engages in mobile home installation shall obtain a mobile home installer's license from the Bureau of Mobile Home and Recreational Vehicle Construction, of the Department of Highway Safety and Motor Vehicles pursuant to this section. Said license shall be renewed annually, and each licensee shall pay a fee of \$150

I, Walter Medford, license number I H-0000056
Walter Medford
states that the installation of the manufactured home for


Timothy & Yvonne Parker at 911 Address:
551 SW Archie Bl City Lake City
will be done under my supervision.

Signed: Walter Medford
Mobile Home Installer

Sworn to and described before me this 13 day of Aug 2009

[Signature]
Notary public


Notary Name



Personally known _____

DL ID FL 02

1. "Used 4"



WINDOW SCHEDULE									
NO.	TYPE	SIZE	UNIT	QTY	NO.	TYPE	SIZE	UNIT	QTY
1	6" x 8"	1.33	S.H.	1	2	6" x 8"	1.33	S.H.	1
2	6" x 8"	1.33	S.H.	1	3	6" x 8"	1.33	S.H.	1
3	6" x 8"	1.33	S.H.	1	4	6" x 8"	1.33	S.H.	1
4	6" x 8"	1.33	S.H.	1	5	6" x 8"	1.33	S.H.	1
5	6" x 8"	1.33	S.H.	1	6	6" x 8"	1.33	S.H.	1
6	6" x 8"	1.33	S.H.	1	7	6" x 8"	1.33	S.H.	1
7	6" x 8"	1.33	S.H.	1	8	6" x 8"	1.33	S.H.	1
8	6" x 8"	1.33	S.H.	1	9	6" x 8"	1.33	S.H.	1
9	6" x 8"	1.33	S.H.	1	10	6" x 8"	1.33	S.H.	1
10	6" x 8"	1.33	S.H.	1	11	6" x 8"	1.33	S.H.	1
11	6" x 8"	1.33	S.H.	1	12	6" x 8"	1.33	S.H.	1
12	6" x 8"	1.33	S.H.	1	13	6" x 8"	1.33	S.H.	1
13	6" x 8"	1.33	S.H.	1	14	6" x 8"	1.33	S.H.	1
14	6" x 8"	1.33	S.H.	1	15	6" x 8"	1.33	S.H.	1
15	6" x 8"	1.33	S.H.	1	16	6" x 8"	1.33	S.H.	1
16	6" x 8"	1.33	S.H.	1	17	6" x 8"	1.33	S.H.	1
17	6" x 8"	1.33	S.H.	1	18	6" x 8"	1.33	S.H.	1
18	6" x 8"	1.33	S.H.	1	19	6" x 8"	1.33	S.H.	1
19	6" x 8"	1.33	S.H.	1	20	6" x 8"	1.33	S.H.	1
20	6" x 8"	1.33	S.H.	1	21	6" x 8"	1.33	S.H.	1
21	6" x 8"	1.33	S.H.	1	22	6" x 8"	1.33	S.H.	1
22	6" x 8"	1.33	S.H.	1	23	6" x 8"	1.33	S.H.	1
23	6" x 8"	1.33	S.H.	1	24	6" x 8"	1.33	S.H.	1
24	6" x 8"	1.33	S.H.	1	25	6" x 8"	1.33	S.H.	1
25	6" x 8"	1.33	S.H.	1	26	6" x 8"	1.33	S.H.	1
26	6" x 8"	1.33	S.H.	1	27	6" x 8"	1.33	S.H.	1
27	6" x 8"	1.33	S.H.	1	28	6" x 8"	1.33	S.H.	1
28	6" x 8"	1.33	S.H.	1	29	6" x 8"	1.33	S.H.	1
29	6" x 8"	1.33	S.H.	1	30	6" x 8"	1.33	S.H.	1
30	6" x 8"	1.33	S.H.	1	31	6" x 8"	1.33	S.H.	1
31	6" x 8"	1.33	S.H.	1	32	6" x 8"	1.33	S.H.	1
32	6" x 8"	1.33	S.H.	1	33	6" x 8"	1.33	S.H.	1
33	6" x 8"	1.33	S.H.	1	34	6" x 8"	1.33	S.H.	1
34	6" x 8"	1.33	S.H.	1	35	6" x 8"	1.33	S.H.	1
35	6" x 8"	1.33	S.H.	1	36	6" x 8"	1.33	S.H.	1
36	6" x 8"	1.33	S.H.	1	37	6" x 8"	1.33	S.H.	1
37	6" x 8"	1.33	S.H.	1	38	6" x 8"	1.33	S.H.	1
38	6" x 8"	1.33	S.H.	1	39	6" x 8"	1.33	S.H.	1
39	6" x 8"	1.33	S.H.	1	40	6" x 8"	1.33	S.H.	1
40	6" x 8"	1.33	S.H.	1	41	6" x 8"	1.33	S.H.	1
41	6" x 8"	1.33	S.H.	1	42	6" x 8"	1.33	S.H.	1
42	6" x 8"	1.33	S.H.	1	43	6" x 8"	1.33	S.H.	1
43	6" x 8"	1.33	S.H.	1	44	6" x 8"	1.33	S.H.	1
44	6" x 8"	1.33	S.H.	1	45	6" x 8"	1.33	S.H.	1
45	6" x 8"	1.33	S.H.	1	46	6" x 8"	1.33	S.H.	1
46	6" x 8"	1.33	S.H.	1	47	6" x 8"	1.33	S.H.	1
47	6" x 8"	1.33	S.H.	1	48	6" x 8"	1.33	S.H.	1
48	6" x 8"	1.33	S.H.	1	49	6" x 8"	1.33	S.H.	1
49	6" x 8"	1.33	S.H.	1	50	6" x 8"	1.33	S.H.	1
50	6" x 8"	1.33	S.H.	1	51	6" x 8"	1.33	S.H.	1
51	6" x 8"	1.33	S.H.	1	52	6" x 8"	1.33	S.H.	1
52	6" x 8"	1.33	S.H.	1	53	6" x 8"	1.33	S.H.	1
53	6" x 8"	1.33	S.H.	1	54	6" x 8"	1.33	S.H.	1
54	6" x 8"	1.33	S.H.	1	55	6" x 8"	1.33	S.H.	1
55	6" x 8"	1.33	S.H.	1	56	6" x 8"	1.33	S.H.	1
56	6" x 8"	1.33	S.H.	1	57	6" x 8"	1.33	S.H.	1
57	6" x 8"	1.33	S.H.	1	58	6" x 8"	1.33	S.H.	1
58	6" x 8"	1.33	S.H.	1	59	6" x 8"	1.33	S.H.	1
59	6" x 8"	1.33	S.H.	1	60	6" x 8"	1.33	S.H.	1
60	6" x 8"	1.33	S.H.	1	61	6" x 8"	1.33	S.H.	1
61	6" x 8"	1.33	S.H.	1	62	6" x 8"	1.33	S.H.	1
62	6" x 8"	1.33	S.H.	1	63	6" x 8"	1.33	S.H.	1
63	6" x 8"	1.33	S.H.	1	64	6" x 8"	1.33	S.H.	1
64	6" x 8"	1.33	S.H.	1	65	6" x 8"	1.33	S.H.	1
65	6" x 8"	1.33	S.H.	1	66	6" x 8"	1.33	S.H.	1
66	6" x 8"	1.33	S.H.	1	67	6" x 8"	1.33	S.H.	1
67	6" x 8"	1.33	S.H.	1	68	6" x 8"	1.33	S.H.	1
68	6" x 8"	1.33	S.H.	1	69	6" x 8"	1.33	S.H.	1
69	6" x 8"	1.33	S.H.	1	70	6" x 8"	1.33	S.H.	1
70	6" x 8"	1.33	S.H.	1	71	6" x 8"	1.33	S.H.	1
71	6" x 8"	1.33	S.H.	1	72	6" x 8"	1.33	S.H.	1
72	6" x 8"	1.33	S.H.	1	73	6" x 8"	1.33	S.H.	1
73	6" x 8"	1.33	S.H.	1	74	6" x 8"	1.33	S.H.	1
74	6" x 8"	1.33	S.H.	1	75	6" x 8"	1.33	S.H.	1
75	6" x 8"	1.33	S.H.	1	76	6" x 8"	1.33	S.H.	1
76	6" x 8"	1.33	S.H.	1	77	6" x 8"	1.33	S.H.	1
77	6" x 8"	1.33	S.H.	1	78	6" x 8"	1.33	S.H.	1
78	6" x 8"	1.33	S.H.	1	79	6" x 8"	1.33	S.H.	1
79	6" x 8"	1.33	S.H.	1	80	6" x 8"	1.33	S.H.	1
80	6" x 8"	1.33	S.H.	1	81	6" x 8"	1.33	S.H.	1
81	6" x 8"	1.33	S.H.	1	82	6" x 8"	1.33	S.H.	1
82	6" x 8"	1.33	S.H.	1	83	6" x 8"	1.33	S.H.	1
83	6" x 8"	1.33	S.H.	1	84	6" x 8"	1.33	S.H.	1
84	6" x 8"	1.33	S.H.	1	85	6" x 8"	1.33	S.H.	1
85	6" x 8"	1.33	S.H.	1	86	6" x 8"	1.33	S.H.	1
86	6" x 8"	1.33	S.H.	1	87	6" x 8"	1.33	S.H.	1
87	6" x 8"	1.33	S.H.	1	88	6" x 8"	1.33	S.H.	1
88	6" x 8"	1.33	S.H.	1	89	6" x 8"	1.33	S.H.	1
89	6" x 8"	1.33	S.H.	1	90	6" x 8"	1.33	S.H.	1
90	6" x 8"	1.33	S.H.	1	91	6" x 8"	1.33	S.H.	1
91	6" x 8"	1.33	S.H.	1	92	6" x 8"	1.33	S.H.	1
92	6" x 8"	1.33	S.H.	1	93	6" x 8"	1.33	S.H.	1
93	6" x 8"	1.33	S.H.	1	94	6" x 8"	1.33	S.H.	1
94	6" x 8"	1.33	S.H.	1	95	6" x 8"	1.33	S.H.	1
95	6" x 8"	1.33	S.H.	1	96	6" x 8"	1.33	S.H.	1
96	6" x 8"	1.33	S.H.	1	97	6" x 8"	1.33	S.H.	1
97	6" x 8"	1.33	S.H.	1	98	6" x 8"	1.33	S.H.	1
98	6" x 8"	1.33	S.H.	1	99	6" x 8"	1.33	S.H.	1
99	6" x 8"	1.33	S.H.	1	100	6" x 8"	1.33	S.H.	1

CUSTOMER FOR PARKER
84230(9)


STATE OF FLORIDA
DEPARTMENT OF HEALTH
APPLICATION FOR ONSITE SEWAGE DISPOSAL SYSTEM CONSTRUCTION PERMIT

Permit Application Number 09-04628E

Parker

Scale: 1 inch = ¹⁰⁰~~20~~ feet.

app. # 0908-52



Notes: Archie Glen

Site Plan submitted by: Arch D MASTER CONTRACTOR
Plan Approved X Not Approved _____ Date 9-1-09
By Salhi Ford Director - Columbia County Health Department

ALL CHANGES MUST BE APPROVED BY THE COUNTY HEALTH DEPARTMENT



COLUMBIA COUNTY BUILDING DEPARTMENT
135 NE Hernando Ave, Suite B-21, Lake City, FL 32055
Phone: 386-758-1008 Fax: 386-758-2160

MOBILE HOME INSTALLERS AGENT AUTHORIZATION

I, Walter Medford, give this authority and I do certify that the below
Installers Name
referenced person(s) listed on this form is/are under my direct supervision and control and
is/are authorized to purchase permits, call for inspections and sign on my behalf.

Printed Name of Authorized Person	Signature of Authorized Person	Agents Company Name
Wendy Grennell	<i>Wendy Grennell</i>	A+B Construction
Dale Burd	<i>Dale Burd</i>	A+B Construction
Rocky Ford	<i>Rocky Ford</i>	A+B Construction

I, the license holder, realize that I am responsible for all permits purchased, and all work done
under my license and I am fully responsible for compliance with all Florida Statutes, Codes, and
Local Ordinances.

I understand that the State Licensing Board has the power and authority to discipline a license
holder for violations committed by him/her or by his/her authorized person(s) through this
document and that I have full responsibility for compliance granted by issuance of such permits.


Walter Medford License Holders Signature (Notarized) IH-000056 License Number 8/13/09 Date

NOTARY INFORMATION:

STATE OF: Florida COUNTY OF: Columbia

The above license holder, whose name is Walter Medford,
personally appeared before me and is known by me or has produced identification
(type of I.D.) FL DL on this 13 day of Aug, 2009.

[Signature]
NOTARY'S SIGNATURE



**COLUMBIA COUNTY
OFFICE
CLERK**

M/H OCCUPANCY

COLUMBIA COUNTY, FLORIDA

Department of Building and Zoning Inspection

This Certificate of Occupancy is issued to the below named permit holder for the building and premises at the below named location, and certifies that the work has been completed in accordance with the Columbia County Building Code.

Parcel Number 26-3S-15-00270-109

Building permit No. 000028050

Permit Holder WALTER MEDFORD

Owner of Building TIMOTHY & YVONNE PARKER

Location: 551 SW ARCHIE GLEN, LAKE CITY, FL

Date: 09/30/2009



Wayne A. Riva

Building Inspector

POST IN A CONSPICUOUS PLACE
(Business Places Only)