



COLUMBIA COUNTY FIRE RESCUE

Life Safety Services

P.O. BOX 1529 Lake City, Florida 32056
Office (386) 758-2120 Fax (386) 754-7064

Fire Inspector
Chief Jeffery Crawford

02 November 2020

TO: Troy Crews
Columbia County Building and Zoning

FROM: Chief Jeffery Crawford
Fire Inspector #136416

RE: New Construction: Belmont Academy

A plan review was performed on the proposed new construction for Belmont Academy, located at 1476 SW Walters Ave, Lake City Florida 32024. This building was classified under Chapter 14 New Educational Occupancies, of the Florida Fire Prevention Code, 2012 Fifth Edition.

I recommend Approval of the building with the following conditions:

Pending:

- Light Weight Truss Marking
 - Florida Statue, Section 633.027, (2008) requires the owner of any commercial, industrial, or multi-unit residential structure of three units or more constructed of light-frame trusses, to install a symbol adopted by the rule of the State Fire Marshal's Office. This rule establishes the dimensions, color, and location of the symbol to be applied to every commercial, industrial, and multi-unit residential structure of three units or more constructed of light-frame trusses.



Detection, Alarm, and Communications System

14.3.4.1.1 Educational occupancies shall be provided with alarm system in accordance with Section 9.6

- Emergency Lighting/Exit signs
 - NFPA 101 Life Safety Code, Chapter 42.2.9 emergency lighting shall be provided in normally occupied storage occupancies in accordance with section 7.9, except for spaces occupied only during daylight hours with natural illumination in accordance with 42.2.8.2.
 - Fire Extinguishers – ABC Fire extinguisher per exit door and K extinguisher in kitchen

Sincerely,

A handwritten signature in cursive script, reading "Jeffrey Crawford". The signature is written in a dark ink and is positioned below the "Sincerely," text.