Mark D. Duren and Associates, Inc. Professional Surveyor and Mapper

1604 SW SISTERS WELCOME ROAD Lake City, FL 32025 386-758-9831 Phone 386-758-8010 Fax mddpsm@markduren.com |ldmddpsm@gmall.com

October 3, 2023

IE. Floor Elevation of dwelling on tax Parcel No.15-4S-16-03011-127.

10/3/2023

To Whom It May Concern,

A minimum floor elevation of 105.0 feet, the datum is not specified on the plat, is established for the parcel on site plan of "Rose Pointe", according to a copy of the site plan provided to this office.

The elevation of the top of the concrete slab of the main floor of the dwelling is 106.0 feet, NAVD 1988 datum, 106.8 feet, NGVD 1929 datum, based on elevations derived from Benchmark "Steinried AZ MK", NGS PID BD1035. The published elevation is 140.93 feet, NAVD 1988 datum. The published NGVD 1929 datum elevation for this benchmark is 141.74 feet.

Mark D. Duren LS 4708