


Scope of work: Like for like replacement of burnt 200amp meter main underground service and like for like replacement of interior 200 amp main breaker panel with arc fault breakers


Beeth

EC13008384


Not Used
 Conduit type: _____
 Conduit size: _____
 Wire size/
 quantity: _____
 Not Used



Existing
 Conduit type: PVC
 Conduit size: 2"
 Wire size/
 quantity: 2/0 4 wires
 Copper
 EGC size #4
 Copper



Not Used
 Conduit type: _____
 Conduit size: _____
 Wire size/
 quantity: _____
 Not Used
 EGC size _____
 Not Used



Replace
 Conduit type: PVC
 Conduit size: 2.5"
 Wire size/
 quantity: 4/0 3 wires
 Aluminum



Main Grounding System
 Replace
 Wire Size: #4

