

# 24733



GENERAL CONTRACTORS

CONSTRUCTION MANAGERS

## FAX TRANSMITTAL

**Date:** 9/20/06

**To:** Randy Jones @ (386) 758-2160

**From:** Jim Railey

**Subject:** Simpson Hardware on Edwards Residence

**Pages including cover:** 2

Randy, here is the letter you ask for from Engineer to substitute Simpson hardware. I will have this corrected as soon as possible and let you know for reinspection. If you need sealed copy just let me know and I will mail to you. Again, Thank you for your help. Jim

500 N Main, Trenton, Florida 32693-3442

(352)463-9060

Fax (352)463-0031 E-mail: [grayconst@AOL.com](mailto:grayconst@AOL.com)

State of Florida Certified General Contractor's License No.: CGC037553

Providing Quality Construction Service Since 1975

# TR Engineering LLC

PO Box 1369  
Chiefland, FL 32644  
(352) 463-8155

Laura A. Tropeano, P.E.  
Gregory P. Rivers, P.E.



September 20, 2006

Mr. Tom Edwards  
Tri-County Home Designs  
PO Box 285  
Trenton, FL 32693

Re: Edwards Residence  
Addendum No. 1

Dear Mr. Edwards:

The following alternate fastening methods are acceptable:

Stud to Bottom Plate Connection: Simpson SP1 Stud Plate Ties on each stud may be substituted for the Simpson SPH6 Stud Ties at every other stud.

Porch Post/Beam Connection: Simpson CS16 x 24" Coiled Strap may be substituted for MSTA 24 Strap Ties.

Please contact me if you have any questions.

Sincerely,

A handwritten signature in black ink, appearing to read 'Gregory P. Rivers', is located below the word 'Sincerely,'.

Gregory P. Rivers, P.E.  
Fla. Cert. #35800