

29

**CONSULTING
ENGINEERING
GROUP, INC.**

Allstate Business Centers, 104 E. Fowler Avenue, Suite 200, Tampa, Florida 33612

Tel: 813.936.0796

June 14, 2013

via email

Mr. Jim Zuber
All Seasons Planning, Inc.
P.O. Box 1530
Lake City, Florida 32056

Re: Mountaintop Ministries, 5037 County Rd. 240, Lake City, FL 32024
CEGI #12.321

Dear Mr. Zuber:

Please see Plan Sheet No. E-5 submitted to the Building Department, Delta No. 1, dated January 1, 2013.
Aluminum conductors are acceptable for the project. See attachment.

The original chiller plant drawings submitted to your office is acceptable by our office to also use
aluminum conductors.

Respectfully,



For James F. Kill, President

cc: JFK/File/Ken Zuber via email

Attachment (1)



**SUWANNEE
RIVER
WATER
MANAGEMENT
DISTRICT**

9225 CR 49
LIVE OAK, FLORIDA 32060
TELEPHONE: (386) 362-1001
TELEPHONE: 800-226-1066
FAX (386) 362-1056

GENERAL PERMIT

PERMITTEE:
MOUNTAINTOP MINISTRIES
PO BOX 3092
LAKE CITY, FL 32056

PERMIT NUMBER: ERP92-0155M2
DATE ISSUED: 07/10/2012
DATE EXPIRES: 07/10/2015
COUNTY: COLUMBIA
TRS: S11/T5S/R16E

PROJECT: MOUNTAINTOP MINISTRIES BUILDING ADDITION (FKA MEADE)-APR

Approved entity to whom operation and maintenance may be transferred pursuant to rule 40B-4.1130, Florida Administrative Code (F.A.C.):

JIM ZUBER
MOUNTAINTOP MINISTRIES
PO BOX 3092
LAKE CITY, FL 32056

Based on information provided, the Suwannee River Water Management District's (District) rules have been adhered to and an environmental resource general permit is in effect for the permitted activity description below:

Previous permit issued for 6.15 acres of impervious surface on 47.61 acres. Modification consists of construction and operation of a surfacewater management system serving a combined total of 39.59 acres of impervious surface on a total project area of 47.61 acres in a manner consistent with the application package submitted by Winsberg, Inc., certified on July 6, 2012.

It is your responsibility to ensure that adverse off-site impacts do not occur either during or after construction. Any additional construction or alterations not authorized by this permit may result in flood control or water quality problems both on and off site and will be a violation of District rule.

You or any other substantially affected persons are entitled to request an administrative hearing or mediation. Please refer to enclosed notice of rights.