

Columbia County Building Department
135 NE Hernando Ave.
Lake City, FL 32056
Attn Permits Reviewer:

ADDENDUM LETTER

HAMPTON CARPORT PLANS
COLUMBIA COUNTY, FL
Signed and sealed on 8 MAR 2018

Review:

I have reviewed the plans referenced above and found them to be in compliance with the Florida Building Code 7th Edition (2020). Amended below:

1. Structure to be modified from 32'x36' to a 32'x40' with post spacing changed from 9' to 10'.
2. Beams shall be 2 - 1.75" x 9.25" LVL (1.9E 2850 Fb) min.
3. Install Simpson CCQ46SDS2.5 at each column to beam connection.
(ECCQ46SDS2.5 may be installed at end columns)

Christopher Q. Dicks, P.E.
P.E. License No. 64766
4037 SE CR 252
Lake City, FL 32025



*Sealed
copy
on
file*