

PERMIT APPLICATION / MANUFACTURED HOME INSTALLATION APPLICATION

Employee
W.C.
9.17.11

For Office Use Only (Revised 1-11)		Zoning Official <u>BLK 28 Oct 2011</u>	Building Official <u>W.C. 10/31/11</u>
AP# <u>1110-07</u>	Date Received <u>10/5/11</u>	By <u>W</u>	Permit # <u>29776</u>
Flood Zone <u>X</u>	Development Permit <u>N/A</u>	Zoning <u>A-3</u>	Land Use Plan Map Category <u>A-3</u>
Comments <u>See memo concerning setup of mobile home</u>			
FEMA Map# <u>N/A</u>	Elevation <u>N/A</u>	Finished Floor <u>A</u>	River <u>N/A</u> In Floodway <u>N/A</u>
☒ Site Plan with Setbacks Shown	☒ EH # <u>11-0399</u>	☐ EH Release	☒ Well letter ☐ Existing well
☒ Recorded Deed or Affidavit from land owner	☒ Installer Authorization	☒ State Road Access	☒ 911 Sheet
☐ Parent Parcel #	☐ STUP-MH	☒ F W Comp. letter	☒ VF Form
IMPACT FEES: EMS		Fire	Corr
Road/Code		School	= TOTAL Impact Fees Suspended March 2009

Property ID # 04-75-17-09888-001 Subdivision N/A

▪ New Mobile Home ☒ Used Mobile Home ☐ MH Size 32x80 Year 2012

▪ Applicant Wendy Grennell Phone # 386-288-2428

▪ Address 3104 SW Old Wire Rd Ft White FL 32038

▪ Name of Property Owner Clifton & Sandra Maxwell Phone # 352-815-0747

▪ 911 Address 641 SW Old Bellamy Rd High Springs FL

▪ Circle the correct power company - FL Power & Light - Clay Electric 32643
(Circle One) - Suwannee Valley Electric - Progress Energy

▪ Name of Owner of Mobile Home Clifton & Sandra Maxwell Phone # 352-815-0747
Address 1019 Pine Tree Dr. Eustis FL 32725

▪ Relationship to Property Owner same

▪ Current Number of Dwellings on Property 0

▪ Lot Size _____ Total Acreage 12.25

▪ Do you : Have Existing Drive or Private Drive or need Culvert Permit or Culvert Waiver (Circle one)
(Currently using) (Blue Road Sign) (Putting in a Culvert) (Not existing but do not need a Culvert)

▪ Is this Mobile Home Replacing an Existing Mobile Home No

▪ Driving Directions to the Property 441 South to Old Bellamy Rd.
Cross over Old Lake City Terrace to 2nd lot on (R)

▪ Name of Licensed Dealer/Installer Busty Knowles Phone # 386-397-0886


▪ Installers Address 1349 SE Alfred Markham Rd Lake City

▪ License Number IH 1038219 Installation Decal # 8313 32025

Spoke to Wendy 10/31/11

693.97

- Site Plan -



Columbia County Property Appraiser
J. Doyle Crews - Lake City, Florida 32055 | 386-758-1083

PARCEL: 04-7S-17-09888-001 - TIMBERLAND (005500)
BEG NE COR OF S1/2 OF NE1/4 OF NW1/4, RUN W 349.50 FT, S 1474.54 FT, SE 364.92 FT, N 1578.25 FT TO POB. ORB 554-192, 877-2287,

Name: MAXWELL CLIFTON L & SANDRA
Site: ---
Mail: 1019 PINE TREE DR
EUTIS, FL 32725
Sales Info: 3/1/1999 \$0.00 V / U

2010 Certified Values
Land \$0.00
Bldg \$0.00
Assd \$2,952.00
Exmpt \$0.00
Taxbl Cnty: \$2,952
Other: \$2,952 | Schl: \$2,952


NOTES:

This information, GIS Map Updated: 6/22/2011, was derived from data which was compiled by the Columbia County Property Appraiser Office solely for the governmental purpose of property assessment. This information should not be relied upon by anyone as a determination of the ownership of property or market value. No warranties, expressed or implied, are provided for the accuracy of the data herein, it's use, or it's interpretation. Although it is periodically updated, this information may not reflect the data currently on file in the Property Appraiser's office. The assessed values are NOT certified values and therefore are subject to change before being finalized for ad valorem assessment purposes.

powered by:
GrizzlyLogic.com

Application for Onsite Sewage Disposal System
Construction Permit. Part II Site Plan
Permit Application Number: 11-0399

ALL CHANGES MUST BE APPROVED BY THE COUNTY HEALTH UNIT



Site Plan Submitted By Paul Leys Date 9/22/11
Plan Approved ✓ Not Approved Date 9.26.11

By Sallie Ford Env. Health Director. Columbia CPHU

Notes: See attached for full property dimensions. 1A of 12.25 shown

>> [Print as PDF](#) <<

BEG NE COR OF S1/2 OF NE1/4 OF OF NW1/4, RUN W 349.50 FT, S 1474.54 FT, SE 364.92 FT, N 1578.25 FT TO POB.				MAXWELL CLIFTON L & SANDRA 1019 PINE TREE DR EUTIS, FL 32725				04-7S-17-09888-001				Columbia County 2011 R CARD 001 of 001 BY JEFF				PRINTED 6/20/2011 12:51 APPR 7/20/2005 DF			
BUSE		AE?		HTD AREA		.000 INDEX		4717.00 DIST 3		PUSE		005500		TIMBERLAND 80-8					
MOD		BATH		EFF AREA		61.456 E-RATE		.000 INDX		STR 4- 7S- 17									
EXW		FIXT		RCN				AYB		MKT AREA 02				0 BLDG					
%		BDRM		%GOOD		BLDG VAL		EYB		(PUD1				0 XFOB					
RSTR		RMS								AC		12.250		0 LAND					
RCVR		UNTS		FIELD CK:						NTCD				3,062 CLAS					
%		C-W%		LOC: ---						APPR CD				45,812 MKTUSE					
INTW		HGHT								CNDO				45,812 JUST					
%		PMTR								SUBD				3,062 APPR					
FLOR		STYS								BLK									
%		ECON								LOT				0 SOHD					
HTTP		FUNC								MAP#				0 ASSD					
A/C		SPCD												0 EXPT					
QUAL		DEPR								TXDT		003		0 COTXBL					
FNDN		UD-1																	
SIZE		UD-2																	
CEIL		UD-3																	
ARCH		UD-4																	
FRME		UD-5																	
KTCH		UD-6																	
WNDO		UD-7																	
CLAS		UD-8																	
OCC		UD-9																	
COND		%																	
SUB		A-AREA		%		E-AREA		SUB VALUE											
										NUMBER		DESC		AMT					
														ISSUED					

LAND	DESC	ZONE	ROAD	{UD1	{UD3	FRONT	DEPTH	FIELD CK:					UNITS	UT	PRICE	ADJ	UT	PR	LAND	VALUE
AE	CODE	TOPO	UTIL	{UD2	{UD4	BACK	DT	ADJUSTMENTS												
N	005500	TIMBER 2	A-1	0002				1.00	1.00	1.00	1.00		12.250	AC	250.000			250.00		3,062AG
				0002	0003															
N	009910	MKT.VAL.AG	A-1	0002				1.00	1.00	1.00	1.00		12.250	AC						
				0002	0003										3739.770			3739.77		45,812MK

COLUMBIA COUNTY 9-1-1 ADDRESSING

P. O. Box 1787, Lake City, FL 32056-1787
PHONE: (386) 758-1125 * FAX: (386) 758-1365 * Email: ron_croft@columbiacountyfla.com

Addressing Maintenance

To maintain the Countywide Addressing Policy you must make application for a 9-1-1 Address at the time you apply for a building permit. The established standards for assigning and posting numbers to all principal buildings, dwellings, businesses and industries are contained in Columbia County Ordinance 2001-9. The addressing system is to enable Emergency Service Agencies to locate you in an emergency, and to assist the United States Postal Service and the public in the timely and efficient provision of services to residents and businesses of Columbia County.

DATE REQUESTED: 9/2/2011 DATE ISSUED: 9/15/2011

ENHANCED 9-1-1 ADDRESS:

641 SW OLD BELLAMY RD
HIGH SPRINGS FL 32643

PROPERTY APPRAISER PARCEL NUMBER:

04-7S-17-09888-001

Remarks:

ADDRESS FOR PROPOSED NEW STRUCTURE ON PARCEL.

Address Issued By: SIGNED: / RONAL N. CROFT
Columbia County 9-1-1 Addressing / GIS Department

NOTICE: THIS ADDRESS WAS ISSUED BASED ON LOCATION INFORMATION RECEIVED FROM THE REQUESTER. SHOULD, AT A LATER DATE, THE LOCATION INFORMATION BE FOUND TO BE IN ERROR, THIS ADDRESS IS SUBJECT TO CHANGE.

PERMIT NUMBER

PERMIT WORKSHEET



Installer Rusty Kravitz License # TH 1038819
Address of home being installed 641 SW Old Bellamy Rd
Manufacturer Live Oak Length x width 32x76 Box

New Home ☒ Used Home ☐
Home installed to the Manufacturer's Installation Manual ☐
Home is installed in accordance with Rule 15-C ☐
Single wide ☐ Wind Zone II ☒ Wind Zone III ☐
Double wide ☒ Installation Decal # 8313
Triple/Quad ☐ Serial # ordered

NOTE: If home is a single wide fill out one half of the blocking plan
If home is a triple or quad wide sketch in remainder of home

I understand Lateral Arm Systems cannot be used on any home (new or used) where the sidewall ties exceed 5 ft 4 in.

Installer's initials RJK



PIER SPACING TABLE FOR USED HOMES

Load bearing capacity (sq in)	16' x 16' (256)	18 1/2' x 18 1/2' (342)	20' x 20' (400)	22' x 22' (484)*	24' x 24' (576)*	26' x 26' (576)
1000 psi	3'	4'	5'	6'	7'	8'
1500 psi	4'	6'	7'	8'	8'	8'
2000 psi	6'	8'	8'	8'	8'	8'
2500 psi	7'	8'	8'	8'	8'	8'
3000 psi	8'	8'	8'	8'	8'	8'
3500 psi	8'	8'	8'	8'	8'	8'

* Interpolated from Rule 15C-1 pier spacing table.

PIER PAD SIZES

I-beam pier pad size 23 1/4 x 3 1/4
Perimeter pier pad size NA
Other pier pad sizes (required by the mfg.) 16x16

Draw the approximate locations of marriage wall openings 4 foot or greater. Use this symbol to show the piers.

List all marriage wall openings greater than 4 foot and their pier pad sizes below.

Opening 15' Pier pad size 23 1/4 x 3 1/4
ANCHORS ☒ 4 ft ☒ 5 ft

FRAME TIES ☐ within 2' of end of home spaced at 5' 4" oc

TIEDOWN COMPONENTS

Longitudinal Stabilizing Device (LSD)
Manufacturer Oliver Technology
Number 30
Longitudinal Marriage wall Shearwall 2x4w
OTHER TIES ☐

PERMIT NUMBER

POCKET PENETROMETER TEST

The pocket penetrometer tests are rounded down to _____ psf or check here to declare 1000 lb. soil ☒ without testing.

X 1.0 X 1.0 X 1.0

POCKET PENETROMETER TESTING METHOD

1. Test the perimeter of the home at 6 locations.
2. Take the reading at the depth of the footer.
3. Using 500 lb. increments, take the lowest reading and round down to that increment.

X 1.0 X 1.0 X 1.0

TORQUE PROBE TEST

The results of the torque probe test is NA using 1101V inch pounds or check here if you are declaring 5' anchors without testing _____. A test showing 275 inch pounds or less will require 5 foot anchors.

Note: A state approved lateral arm system is being used and 4 ft. anchors are allowed at the sidewall locations. I understand 5 ft anchors are required at all centerline tie points where the torque test reading is 275 or less and where the mobile home manufacturer may requires anchors with 4000 lb holding capacity.

Installer's initials

ALL TESTS MUST BE PERFORMED BY A LICENSED INSTALLER

Installer Name

Rusty L. Knowles

Date Tested

9-27-11

Electrical

Connect electrical conductors between multi-wide units, but not to the main power source. This includes the bonding wire between multi-wide units. Pg. 15C-1

Plumbing

Connect all sewer drains to an existing sewer tap or septic tank. Pg. 15C-1

Connect all potable water supply piping to an existing water meter, water tap, or other independent water supply systems. Pg. 15C-1

Site Preparation

Debris and organic material removed ☒
Water drainage: Natural ☒ Swale ☐ Pad ☒ Other ☐

Fastening multi wide units

Floor: Type Fastener: Lags Length: 6" Spacing: 18"
Walls: Type Fastener: Screws Length: 4" Spacing: 24"
Roof: Type Fastener: Staples Length: 1 3/4" Spacing: 48"
For used homes a min. 30 gauge, 8" wide, galvanized metal strip will be centered over the peak of the roof and fastened with galv. roofing nails at 2" on center on both sides of the centerline.

Gasket (weatherproofing requirement)

I understand a properly installed gasket is a requirement of all new and used homes and that condensation, mold, mildew and buckled marriage walls are a result of a poorly installed or no gasket being installed. I understand a strip of tape will not serve as a gasket.

Installer's initials

[Signature]

Installed:

Between Floors Yes ☒
Between Walls Yes ☒
Bottom of ridgebeam Yes ☒

Type gasket factory ins.
Pg. 15C-1

Weatherproofing

The bottomboard will be repaired and/or taped. Yes ☒
Siding on units is installed to manufacturer's specifications. Yes ☒
Fireplace chimney installed so as not to allow intrusion of rain water. Yes ☒

Miscellaneous

Skirting to be installed. Yes ☒ No ☐
Dryer vent installed outside of skirting. Yes ☒ N/A ☐
Range downflow vent installed outside of skirting. Yes ☒ N/A ☐
Drain lines supported at 4 foot intervals. Yes ☒
Electrical crossovers protected. Yes ☒
Other: 15C-1 may or may not have page #10

Setup Manual


Installer verifies all information given with this permit worksheet is accurate and true based on the manufacturer's installation instructions and or Rule 15C-1 & 2

Installer Signature

[Signature]

Date 9-27-11

indicates I beam pins loc. using 234x31 1/4 ABS pads assuming 1000# soil.
 indicates 6-1101V systems from Oliver Technology.





MARRIAGE LINE OPENING SUPPORT PIERTYP.
 SUPPORT PIERTYP
 FOUNDATION NOTES:
 THIS DRAWING IS DESIGNED FOR THE STANDARD WIND ZONE AND IS TO BE USED IN CONJUNCTION WITH THE INSTALLATION MANUAL AND ITS SUPPLEMENTS.
 FOOTINGS ARE SHOWN FOR EXAMPLE ONLY QUANTITY AND SPACING MAY VARY BASED ON PAD TYPE, SOIL CONDITION, ETC.
 FOOTINGS ARE REQUIRED AT SUPPORT POSTS. SEE INSTALLATION MANUAL FOR REQUIREMENTS.

- MAIN ELECTRICAL
- ELECTRICAL CROSSOVER
- WATER INLET
- WATER CROSSOVER (IF ANY)
- GAS INLET (IF ANY)
- GAS CROSSOVER (IF ANY)
- DUCT CROSSOVER
- SEWER DROPS
- RETURN AIR (WOPT. HEAT PUMP ON DUCT)
- SUPPLY AIR (WOPT. HEAT PUMP ON DUCT)

Live Oak Homes
 MODEL: S-3764B - 32 X 80
 4-BEDROOM / 2-BATH

GLADIATOR



S-3764B
5-BEDROOM / 2-BATH
32 X 80 - Approx. 2254 Sq. Ft.

Date: 8-13-2011
 * All room dimensions include closets and square footage figures are approximate.
 * Typical windows are available in optional 9'-0" wide casework only.



LETTER OF AUTHORIZATION TO PULL PERMITS


I, Rusty L. Knowles, DO HEREBY GRANT
Wendy Grenwell, AUTHORIZATION TO PULL
THE NECESSARY PERMITS REQUIRED FOR THE DELIVERY
AND SET OF A MANUFACTURED HOME IN Columbia
COUNTY, FLORIDA.


SIGNATURE

THIS FOREGOING INSTRUMENT WAS ACKNOWLEDGED BEFORE
ME THIS 27 DAY OF September, 2011
BY Rusty Knowles, WHO IS PERSONALLY
KNOWN TO ME OR HAS PRODUCED _____
AS IDENTIFICATION.

STATE OF FLORIDA
COUNTY OF Columbia




NOTARY PUBLIC

(STAMP)

MOBILE HOME INSTALLATION SUBCONTRACTOR VERIFICATION FORM

APPLICATION NUMBER 1110-07 CONTRACTOR Busty Knowles PHONE 386-397-0886

THIS FORM MUST BE SUBMITTED PRIOR TO THE ISSUANCE OF A PERMIT

In Columbia County one permit will cover all trades doing work at the permitted site. It is **REQUIRED** that we have records of the subcontractors who actually did the trade specific work under the permit. Per Florida Statute 440 and Ordinance 89-6, a contractor shall require all subcontractors to provide evidence of workers' compensation or exemption, general liability Insurance and a valid Certificate of Competency license in Columbia County.

Any changes, the permitted contractor is responsible for the corrected form being submitted to this office prior to the start of that subcontractor beginning any work. Violations will result in stop work orders and/or fines.

ELECTRICAL 234	Print Name: <u>Michael Conner</u>	Signature: <u>Michael Conner</u>
	License #: <u>ER13013192</u>	Phone #: <u>386-958-2233</u>
MECHANICAL/ A/C <u>OK</u>	Print Name: <u>Robert Grant</u>	Signature: <u>Robert Grant</u>
	License #: <u>CAC814931</u>	Phone #: <u>800-859-3708</u>
PLUMBING/ GAS <u>OK</u>	Print Name: <u>Busty Knowles</u>	Signature: <u>Busty Knowles</u>
	License #: <u>IH1038219</u>	Phone #: <u></u>

Specialty License	License Number	Sub-Contractor's Printed Name	Sub-Contractor's Signature
MASON			
CONCRETE FINISHER			

F. S. 440.103 Building permits; identification of minimum premium policy.—Every employer shall, as a condition to applying for and receiving a building permit, show proof and certify to the permit issuer that it has secured compensation for its employees under this chapter as provided in ss. 440.10 and 440.38, and shall be presented each time the employer applies for a building permit.

Contractor Form; Subcontractor Form 1/13

District No. 1 - Ronald Williams
District No. 2 - Rusty DePratter
District No. 3 - Jody DuPree
District No. 4 - Stephen E. Bailey
District No. 5 - Scarlet P. Frisina



BOARD OF COUNTY COMMISSIONERS • COLUMBIA COUNTY

MEMORANDUM

Date: 28 October 2011
To: Mobil Home Move-on Permit File
From: Brian L. Kepner, Land Development Regulation Administrator *BLK*
Re: Mobile Home Move-on Permit Application # 1110-07


The distance from the existing graded dirt road (SW Old Bellamy Road) to the proposed location of the mobile home is approximately 270 feet and the slope of the property running west to east from 70 feet to 55 feet. The proposed location of the mobile home is approximately between the 70 and 65 foot contour lines. The contour lines run north and south with little variation towards the road. The property continues to slope downward to the northeast to a depression approximately 250 feet to the 55 foot contour line and possibly a little lower. The proposed location of the mobile home has no practical relationship with requiring the mobile home to be set one (1) foot above the road in order to prevent water damage to the mobile home because of the direction of the slope and 1 foot of drop for every 20 feet towards the depression. The mobile home will be allowed standard set up and in accordance with all applicable codes.

BOARD MEETS FIRST THURSDAY AT 7:00 P.M.
AND THIRD THURSDAY AT 7:00 P.M.

P. O. BOX 1529 ▼


LAKE CITY, FLORIDA 32056-1529 ▼

PHONE (386) 755-4100



1110-07

110-07



App 1110-07
Maxwell


5673 NW Lake Jeffery Road
Lake City, FL 32055
Telephone: (386) 758-3409
Cell: (386) 623-3151
Fax: (386) 758-3410
Owner: Bruce Park

November 15, 2011

To: Columbia County Building Department

Description of Well to be installed for Customer Cliff + Sandra MaxwellLocated @ Address: 641 SW Old Bellamy Rd

1 HP 15 GPM submersible pump, 1 1/4" drop pipe, 86 gallon captive tank, and backflow prevention.
With SRWMD permit.



Sincerely,
Bruce N. Park
President

DATE 11/18/2011

Columbia County Building Permit

This Permit Must Be Prominently Posted on Premises During Construction

PERMIT

000029776

APPLICANT WENDY GRENELL PHONE 386-288-2428

ADDRESS 3104 SW OLD WIRE RD FORT WHITE FL 32038

OWNER CLIFTON & SANDRA MAXWELL PHONE 352-815-0747

ADDRESS 641 SW OLD BELLAMY RD HIGH SPRINGS FL 32643

CONTRACTOR RUSTY KNOWLES PHONE 386-397-0886

LOCATION OF PROPERTY 441 S, R OLD BELLAMY RD, CROSS OVER OLD LAKE CITY TERR,
TO 2ND LOT ON RIGHT

TYPE DEVELOPMENT MH, UTILITY ESTIMATED COST OF CONSTRUCTION 0.00

HEATED FLOOR AREA TOTAL AREA HEIGHT STORIES

FOUNDATION WALLS ROOF PITCH FLOOR

LAND USE & ZONING AG-3 MAX. HEIGHT 35

Minimum Set Back Requirments: STREET-FRONT 30.00 REAR 25.00 SIDE 25.00

NO. EX.D.U. 0 FLOOD ZONE X DEVELOPMENT PERMIT NO.

'ARCEL ID 04-7S-17-09888-001 SUBDIVISION

LOT BLOCK PHASE UNIT TOTAL ACRES 12.25

 IH1038219 Wendy Grenell

Culvert Permit No. Culvert Waiver Contractor's License Number Applicant/Owner/Contractor

EXISTING 11-0399 BK RO N

Driveway Connection Septic Tank Number LU & Zoning checked by Approved for Issuance New Resident

COMMENTS: SEE MEMO ON SET-UP INFORMATION OF THE MH, BY BK

 Check # or Cash CASH

FOR BUILDING & ZONING DEPARTMENT ONLY

(footer/Slab)

Temporary Power Foundation Monolithic

 date/app. by date/app. by date/app. by

Under slab rough-in plumbing Slab Sheathing/Nailing

 date/app. by date/app. by date/app. by

Framing Insulation

 date/app. by date/app. by

Rough-in plumbing above slab and below wood floor Electrical rough-in

 date/app. by date/app. by

Heat & Air Duct Peri. beam (Lintel) Pool

 date/app. by date/app. by

Permanent power C.O. Final Culvert

 date/app. by date/app. by

ump pole Utility Pole M/H tie downs, blocking, electricity and plumbing

 date/app. by date/app. by

Reconnection RV Re-roof

 date/app. by date/app. by

BUILDING PERMIT FEE \$ 0.00 CERTIFICATION FEE \$ 0.00 SURCHARGE FEE \$ 0.00

DISC. FEES \$ 300.00 ZONING CERT. FEE \$ 50.00 FIRE FEE \$ 134.42 WASTE FEE \$ 184.25

LOAD DEVELOPMENT FEE \$ FLOOD ZONE FEE \$ 25.00 CULVERT FEE \$ TOTAL FEE 693.67

INSPECTORS OFFICE CLERKS OFFICE

NOTICE: IN ADDITION TO THE REQUIREMENTS OF THIS PERMIT, THERE MAY BE ADDITIONAL RESTRICTIONS APPLICABLE TO THIS PROPERTY THAT MAY BE FOUND IN THE PUBLIC RECORDS OF THIS COUNTY. AND THERE MAY BE ADDITIONAL PERMITS REQUIRED FROM OTHER GOVERNMENTAL ENTITIES SUCH AS WATER MANAGEMENT DISTRICTS, STATE AGENCIES, OR FEDERAL AGENCIES.

WARNING TO OWNER: YOUR FAILURE TO RECORD A NOTICE OF COMMENCEMENT MAY RESULT IN YOUR PAYING TWICE FOR IMPROVEMENTS TO YOUR PROPERTY. IF YOU INTEND TO OBTAIN FINANCING, CONSULT WITH YOUR LENDER OR AN ATTORNEY BEFORE RECORDING YOUR NOTICE OF COMMENCEMENT."

EVERY PERMIT ISSUED SHALL BECOME INVALID UNLESS THE WORK AUTHORIZED BY SUCH PERMIT IS COMMENCED WITHIN 180 DAYS AFTER ITS ISSUANCE, OR IF THE WORK AUTHORIZED BY SUCH PERMIT IS SUSPENDED OR ABANDONED FOR A PERIOD OF 180 DAYS AFTER THE TIME THE WORK IS COMMENCED. A VALID PERMIT RECIEVES AN APPROVED INSPECTION EVERY 180 DAYS. WORK SHALL BE CONSIDERED NOT SUSPENDED, ABANDONED OR INVALID WHEN THE PERMIT HAS RECIEVED AN APPROVED INSPECTION WITHIN 180 DAYS OT THE PREVIOUS INSPECTION.

The Issuance of this Permit Does Not Waive Compliance by Permittee with Deed Restrictions.

COLUMBIA COUNTY
FLORIDA

M/H OCCUPANCY

COLUMBIA COUNTY, FLORIDA

Department of Building and Zoning Inspection

This Certificate of Occupancy is issued to the below named permit holder for the building and premises at the below named location, and certifies that the work has been completed in accordance with the Columbia County Building Code.

Parcel Number 04-7S-17-09888-001

Building permit No. 000029776

Permit Holder RUSTY KNOWLES

Owner of Building CLIFTON & SANDRA MAXWELL

Location: 641 SW OLD BELLAMY ROAD, HIGH SPRINGS, FL 32643

Date: 12/12/2011




Building Inspector

POST IN A CONSPICUOUS PLACE
(Business Places Only)