



## FLOOR PLAN

SCALE: 1/4"=1'-0"



## FOUNDATION PLAN

SCALE: 1/4"=1'-0"



Digitally signed  
by Tomas  
Ponce  
Date:

2024.07.16  
14:39:10-04'00'

This item has been digitally signed and sealed by [Tomas Ponce PE, FL # 0050068], on the date adjacent to the seal. Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.



### GENERAL NOTES:

1. MAX HEIGHT FROM TOP 1x2 TO BOTTOM OF 2x4 IS 8'-10"
2. MAX DISTANC BETWEEN 2x4POSTS IS 5'-6"
3. BUILDING STYLES MAY VARY BUT ALUMINUM SCREEN ENCLOSURES WILL BE (TYP.) FOR ALL APPLICATIONS.

THIS PLAN HAS BEEN DESIGNED WITH WIND LOADS USED FOR SCREEN & VINYL ROOMS FROM CHAPTER 20 OF FLORIDA BUILDING CODE 8TH EDITION (2023). THIS STRUCTURE IS TO BE AN ADDITION TO AN EXISTING STRUCTURE. THE LOADS ASSUME A MEAN ROOF HEIGHT OF LESS THAN 30 FT. ROOF SLOPE OF 0 DEGREES TO 20 DEGREES ALL LOADS ARE BASED ON 2020 SCREEN OR LARGER. WINDO EXPOSURE C, RISK CATEGORY II 150 MPH ULTIMATE WIND SPEED: 160 MPH ULTIMATE WIND SPEED

VASD = 116 MPH		VASD = 124 MPH	
WINDWARD SURFACE	43PSF	WINDWARD SURFACE	49 PSF
LEEWARD SURFACE	34 PSF	LEEWARD SURFACE	39 PSF
SCREEN UPLIFT	12 PSF	SCREEN UPLIFT	14 PSF
SOLID SURFACE UPLIFT	36 PSF	SOLID SURFACE UPLIFT	41 PSF


PRESSURES ARE LISTED AS STRENGTH DESIGN PRESSURES



## SIDE ELEVATIONS

SCALE: 1/4"=1'-0"

3" .024 COMPOSIT  
ROOF PANEL ATTACHED  
TO 2x4 BEAM



## REAR ELEVATION

SCALE: 1/4"=1'-0"

**DESIGN & BUILDING CONCEPTS, LLC**  
Specializing in Remodeling Residential Design & New Custom Home Designs

407.877.6696  
cell: 407.970.6974  
johnscronk@gmail.com  
Don't Relocate... Renovate!

THIS PLAN HAS BEEN DESIGNED IN ACCORDANCE WITH THE FLORIDA BUILDING CODE - RESIDENTIAL 8TH EDITION (2023)

TOMAS PONCE MSCE, PE  
FL PE #50068  
367 MEDALLION PL  
CHULUOTA, FL 32766  
PH: (407) 484-0037

07/16/2024



DESIGNED BY: All Fl Window & Screen LLC  
43 S. Charles Richard Beall Blvd  
DeBary, FL 32713

Copyright 2023 by  
ALL RIGHTS RESERVED  
NO REPRODUCTION MAY BE MADE  
WITHOUT THE EXPRESSED WRITTEN CONSENT OF  
All FL Window & Screen LLC

3 SIDED 22 x 10 ALUMINUM  
SCREEN ENCLOUSER

MARONDA HOMES  
9FC00101 FOREST COVE

TBD STREET A  
LAKE CITY, FL 32024


Sheet:

1

Of:


1

SOLID PANEL PRODUCTS




ROOF PANEL TO FASCIA DETAIL

SCALE: N.T.S.



ROOF PANEL TO WALL DETAIL


SCALE: N.T.S.





ALT. COMPOSITE ROOF PANEL TO WALL DETAIL

SCALE: N.T.S.

ROOF PANEL TO BM. DETAIL




ACRYLIC, VINYL & SCREEN RMS.



TYP. UPRIGHT DET.

SCALE: N.T.S.






BOT. TO WOOD DET.

SCALE: N.T.S.

THIS PLAN HAS BEEN DESIGNED WITH WIND LOADS USED FOR SCREEN & VINYL ROOMS FROM CHAPTER 20 OF FLORIDA BUILDING CODE 8TH EDITION (2023). THIS STRUCTURE IS TO BE AN ADDITION TO AN EXISTING STRUCTURE. THE LOADS ASSUME A MEAN ROOF HEIGHT OF LESS THAN 30 FT. ROOF SLOPE OF 0 DEGREES TO 20 DEGREES ALL LOADS ARE BASED ON 2020 SCREEN OR LARGER. WINDO EXPOSURE C, RISK CATEGORY II  
150 MPH ULTIMATE WIND SPEED: VASD = 116 MPH WINDWARD SURFACE 43PSF LEEWARD SURFACE 34 PSF SCREEN UPLIFT 12 PSF SOLID SURFACE UPLIFT 36 PSF  
160 MPH ULTIMATE WIND SPEED: VASD = 124 MPH WINDWARD SURFACE 49 PSF LEEWARD SURFACE 39 PSF SCREEN UPLIFT 14 PSF SOLID SURFACE UPLIFT 41 PSF  
PRESSURES ARE LISTED AS STRENGTH DESIGN PRESSURES

EXTRUSION


1 x 2 HOLLOW	.044
1 x 3 HOLLOW	.044
2 x 2 HOLLOW	.044
2 x 3 HOLLOW	.045
2 x 4 HOLLOW	.045
2 x 5 HOLLOW	.050



SEE PLAN FOR FOUNDATION

TYP. & ALTERNATE CORNER DET.

SCALE: N.T.S.



DESIGN & BUILDING CONCEPTS, LLC  
Specializing in Remodeling Residential Design & New Custom Home Designs  
407.877.6696  
cell: 407.970.6974  
johnstonk@gmail.com  
Don't Relocate... Renovate!

THIS PLAN HAS BEEN DESIGNED IN ACCORDANCE WITH THE FLORIDA BUILDING CODE, RESIDENTIAL 8TH EDITION (2023)\*

FL PE #50068  
367 MEDALLION PL  
CHULUOTA, FL 32766  
PH. (407) 484-0037  
07/16/2024



DESIGNED BY: All FI Window & Screen LLC  
43 S. Charles Richard Beall Blvd  
DeBary, FL 32713

Copyright 2023 by  
ALL RIGHTS RESERVED  
NO REPRODUCTION MAY BE MADE  
WITHOUT THE EXPRESSED WRITTEN CONSENT OF  
All FL Window & Screen LLC



MARONDA HOMES  
9FC00101 FOREST COVE  
TBD STREET A  
LAKE CITY, FL 32024

Plan Name:

Sheet:


Of:

3



**ALT. UPRIGHT DET.**

SCALE: N.T.S.




**KICK PLATE DET.**

SCALE: N.T.S.

THIS PLAN HAS BEEN DESIGNED WITH WIND LOADS USED FOR SCREEN & VINYL ROOMS FROM CHAPTER 20 OF FLORIDA BUILDING CODE 8TH EDITION (2023). THIS STRUCTURE IS TO BE AN ADDITION TO AN EXISTING STRUCTURE. THE LOADS ASSUME A MEAN ROOF HEIGHT OF LESS THAN 30 FT. ROOF SLOPE OF 0 DEGREES TO 20 DEGREES ALL LOADS ARE BASED ON 2020 SCREEN OR LARGER. WINDO EXPOSURE C, RISK CATEGORY II

VASD = 116 MPH	43 PSF	VASD = 124 MPH	49 PSF
WINDWARD SURFACE	34 PSF	WINDWARD SURFACE	39 PSF
LEEWARD SURFACE	12 PSF	LEEWARD SURFACE	14 PSF
SCREEN UPLIFT	36 PSF	SCREEN UPLIFT	41 PSF
SOLID SURFACE UPLIFT		SOLID SURFACE UPLIFT	

PRESSURES ARE LISTED AS STRENGTH DESIGN PRESSURES



**DESIGN & BUILDING CONCEPTS, LLC**  
Specializing in Remodeling Residential Design & New Custom Home Designs

407.877.6696  
cell: 407.970.6974  
johncronk@gmail.com

Don't Relocate... Renovate!

"THIS PLAN HAS BEEN DESIGNED IN ACCORDANCE WITH THE FLORIDA BUILDING CODE - RESIDENTIAL 8TH EDITION (2023)"

TOMAS PONC MSCE, PE  
FL PE #50068  
367 MEDALLION PL  
CHULUOTA, FL 32766  
PH. (407) 484-0037

07/16/2024



DESIGNED BY: All FI Window & Screen LLC  
43 S. Charles Richard Beall Blvd  
DeBary, FL 32713

Copyright 2023 by  
ALL RIGHTS RESERVED  
NO REPRODUCTION MAY BE MADE  
WITHOUT THE EXPRESSED WRITTEN CONSENT OF  
All FI Window & Screen LLC

DETAILS	MARONDA HOMES		TBD STREET A LAKE CITY, FL 32024
	9FC00101 FOREST COVE		
Plan Name:			
Sheet:	3.1		Of: