

Job Name

Version 2011 L

Marc Jones Construction, LLC Sunpro Solar

$$\begin{matrix} 0 \\ 0 \\ 0 \end{matrix}$$

7/1/2021 9:35

☒

14,625 VA

QTY

Total **1**

Electric Space Heat @ 65% <4, 40% >3, vs. A/C @ 100% **8,330 VA**

4,500 VA

Dryer Demand Load **5,000 VA**

Range Demand Load **10,000 VA**

Service Demand **27,980 VA**

Demand Load **117 A**

Neutral Demand 67 AMin.Service Req. 125 A

Min. Feeder size	2
-------------------------	----------

Min. Neutral size	4
-------------------	---

Eq. Grding Cond. 6

☐ Copper

Total Appliance Load 4,500 VA

Electric Clothes Dryers	5,000 VA
-------------------------	----------

Electric Ranges	10,000 W	Col C demand	8000
-----------------	----------	--------------	------

or Number of appliances

☐ Check Box for Gas Range

Cooktop	Col B demand
Cooktop	Col B demand
Oven(s)	Col B demand
Oven(s)	Col B demand

Number of appliances **0** Dem. Factor

Cooktop & Oven Demand Load

imp1jds@comcast.net

Pool Panel Feeder Calculation		(See Note)	A	B	N
Continuous Motors	0		0	0	0
Non-continuous	0		0	0	0
Spa heater 11 kVA			0	0	
Pool heater 3.5 ton			0	0	
Pool heater 5 ton			0	0	
Pool Light	select ▼	0	0	0	0
Blower	select ▼	0 ☐ 240v	0	0	0
other load		0 ☐ 240v	0	0	0
other load		0 ☐ 240v	0	0	0
☐ Min.Copper Pool Feeder		AWG	A	A	A
Minimum Panel Rating			Phase Amperes		Neut. load

Continuous Motors

select	▼	☐ 240v
select	▼	☐ 240v
select	▼	☐ 240v
select	▼	☐ 240v
select	▼	☐ 240v

Non-continuous Motors

select	▼	☐ 240v
select	▼	☐ 240v
select	▼	☐ 240v
select	▼	☐ 240v
select	▼	☐ 240v

0.0	Motor Neutral Load
-----	--------------------

Max.Unbalanced Neutral Load