

wrightsoft Load Short Form
Entire House
 Bounds Heating and Air

Job:
 Date: Jul 11, 2013
 By: Joe Mullins

26545 West Newberry Road, Newberry, FL 32669 Phone 352-472-2761 Fax: 352-472-1809 Email: joe.atbounds@yahoo.com or bounds_hvac@yahoo.com Web: www.bounds.

Project Information

For Reeves Residence, O'Neil Construction

Design Information

	Htg	Clg	Infiltration	Simplified
Outside db (°F)	33	92	Method	Tight
Inside db (°F)	68	75	Construction quality	0
Design TD (°F)	35	17	Fireplaces	
Daily range	-	M		
Inside humidity (%)	50	50		
Moisture difference (gr/lb)	29	52		

HEATING EQUIPMENT

Make n/a
 Trade n/a
 Model n/a
 AHRI ref. n/a
 Efficiency n/a
 Heating input
 Heating output 0 Btuh
 Temperature rise 0 °F
 Actual air flow 0 cfm
 Air flow factor 0 cfm/Btuh
 Static pressure 0 in H2O
 Space thermostat n/a

COOLING EQUIPMENT

Make n/a
 Trade n/a
 Cond n/a
 Coil n/a
 AHRI ref. n/a
 Efficiency n/a
 Sensible cooling 0 Btuh
 Latent cooling 0 Btuh
 Total cooling 0 Btuh
 Actual air flow 0 cfm
 Air flow factor 0 cfm/Btuh
 Static pressure 0 in H2O
 Load sensible heat ratio 0

ROOM NAME	Area (ft²)	Htg load (Btuh)	Clg load (Btuh)	Htg AVF (cfm)	Clg AVF (cfm)
Upstairs	880	11423	7215	580	580
Downstairs	1751	15327	13661	767	767
Entire House	2631	26750	20654	1347	1347
Other equip loads		0	0		
Equip. @ 0.97 RSM			20034		
Latent cooling			2832		
TOTALS	2631	26750	22867	1347	1347



Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



wrightsoft

Right-Suite® Universal 2012 12 1 04 RSU01870

Settings\Joel\My Documents\Wrightsoft HVAC\O'Neil - Reeves.rup Calc = MJ8 Front Door faces

2013-Sep-24 15:31:06

Page 1

wrightsoft **Load Short Form**
Downstairs
Bounds Heating and Air

Job:
 Date: Jul 11, 2013
 By: Joe Mullins

26545 West Newberry Road, Newberry, FL 32669 Phone: 352-472-2761 Fax 352-472-1809 Email joe@bounds@yahoo.com or bounds_hvac@yahoo.com Web: www.bounds.

Project Information

For: Reeves Residence, O'Neil Construction

Design Information

	Htg	Clg	Infiltration	Simplified
Outside db (°F)	33	92	Method	Tight
Inside db (°F)	68	75	Construction quality	0
Design TD (°F)	35	17	Fireplaces	
Daily range	-	M		
Inside humidity (%)	50	50		
Moisture difference (gr/lb)	29	52		

HEATING EQUIPMENT

Make	Carrier
Trade	BASE 13 PURON HP
Model	25HBC324(A,W)**30
AHRI ref	3699485
Efficiency	8 HSPF
Heating input	
Heating output	22600 Btuh @ 47°F
Temperature rise	27 °F
Actual air flow	767 cfm
Air flow factor	0.050 cfm/Btuh
Static pressure	1.00 in H2O
Space thermostat	

COOLING EQUIPMENT

Make	Carrier
Trade	BASE 13 PURON HP
Cond	25HBC324(A,W)**30
Coil	FB4CNF024
AHRI ref	3699485
Efficiency	11.0 EER, 13 SEER
Sensible cooling	16100 Btuh
Latent cooling	6900 Btuh
Total cooling	23000 Btuh
Actual air flow	767 cfm
Air flow factor	0.056 cfm/Btuh
Static pressure	1.00 in H2O
Load sensible heat ratio	0.89

ROOM NAME	Area (ft²)	Htg load (Btuh)	Clg load (Btuh)	Htg AVF (cfm)	Clg AVF (cfm)
guest room	208	2666	1458	133	82
guest bath	105	1241	362	62	20
1/2 bath	33	82	62	4	3
WIC	43	94	71	5	4
library	180	2398	2238	120	126
foyer	170	945	387	47	22
dining	246	3453	3541	173	199
kitchen	215	1280	2675	64	150
living	270	1991	1928	100	108
hall 2	70	0	0	0	0
pantry	49	145	109	7	6
laundry	111	1032	831	52	47
hall 1	51	0	0	0	0

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed



wrightsoft

Right-Suite® Universal 2012 12 1 04 RSU01870

Settings\Joel\My Documents\Wrightsoft HVAC\O'Neil - Reeves.rup Calc = MJ8 Front Door faces

2013-Sep-24 15:31:06

Page 2

Downstairs	d	1751	15327	13661	767	767
Other equip loads			0	0		
Equip. @ 0.97 RSM				13252		
Latent cooling				1650		
TOTALS		1751	15327	14902	767	767

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed



Wrightsoft

Right-Suite® Universal 2012 12 1.04 RSU01870

Settings\Joe\My Documents\Wrightsoft HVAC\O'Neil - Reeves.rup Calc = MJ8 Front Door faces

2013-Sep-24 15:31:06

Page 3



Load Short Form
Upstairs
Bounds Heating and Air

Job:
Date: Jul 11, 2013
By: Joe Mullins

26545 West Newberry Road, Newberry, FL 32669 Phone 352-472-2761 Fax 352-472-1809 Email joe.atbounds@yahoo.com or bounds_hvac@yahoo.com Web: www.bounds.com

Project Information

For Reeves Residence, O'Neil Construction

Design Information

	Htg	Clg	Infiltration	Simplified
Outside db (°F)	33	92	Method	Tight
Inside db (°F)	68	75	Construction quality	0
Design TD (°F)	35	17	Fireplaces	
Daily range	-	M		
Inside humidity (%)	50	50		
Moisture difference (gr/lb)	29	52		

HEATING EQUIPMENT

Make	Carrier
Trade	BASE 13 PURON HP
Model	25HBC318(A,W)**30
AHRI ref	3699493
Efficiency	8 HSPF
Heating input	
Heating output	17400 Btuh @ 47°F
Temperature rise	27 °F
Actual air flow	580 cfm
Air flow factor	0.051 cfm/Btuh
Static pressure	1.00 in H2O
Space thermostat	

COOLING EQUIPMENT

Make	Carrier
Trade	BASE 13 PURON HP
Cond	25HBC318(A,W)**30
Coil	FB4CNF018
AHRI ref	3699493
Efficiency	11.0 EER, 13 SEER
Sensible cooling	12180 Btuh
Latent cooling	5220 Btuh
Total cooling	17400 Btuh
Actual air flow	580 cfm
Air flow factor	0.080 cfm/Btuh
Static pressure	1.00 in H2O
Load sensible heat ratio	0.86

ROOM NAME	Area (ft²)	Htg load (Btuh)	Clg load (Btuh)	Htg AVF (cfm)	Clg AVF (cfm)
mech.	11	0	0	0	0
hall	82	0	0	0	0
bath 2	84	1196	418	61	34
master closet	93	1457	348	74	28
master bath	105	1619	388	82	31
master bedroom	218	2033	2507	103	202
stairs	64	715	505	36	41
bedroom 3	105	2334	2045	119	164
bedroom 2	121	2068	1004	105	81

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed



Right-Suite® Universal 2012 12 1 04 RSU01870

Settings\Joe\My Documents\Wrightsoft HVAC\O'Neil - Reeves.rup Calc = MJ8 Front Door faces

2013-Sep-24 15:31:06

Page 4

Upstairs	d	880	11423	7215	580	580
Other equip loads			0	0		
Equip @ 0.97 RSM				6998		
Latent cooling				1182		
TOTALS		880	11423	8181	580	580

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed



wrightsoft

Right-Suite® Universal 2012 12 1 04 RSU01870

Settings\Joel\My Documents\Wrightsoft HVAC\O'Neil - Reeves.rup Calc = MJ8 Front Door faces

2013-Sep-24 15:31:06

Page 5



Project Summary
Entire House
Bounds Heating and Air

Job:
Date: Jul 11, 2013
By: Joe Mullins

26545 West Newberry Road, Newberry, FL 32669 Phone: 352-472-2761 Fax: 352-472-1809 Email: joe.atbounds@yahoo.com or bounds_hvac@yahoo.com Web: www.bounds

Project Information

For: Reeves Residence, O'Neil Construction

Notes

Design Information

Weather: Gainesville, FL, US

Winter Design Conditions

Outside db	33 °F
Inside db	68 °F
Design TD	35 °F

Summer Design Conditions

Outside db	92 °F
Inside db	75 °F
Design TD	17 °F
Daily range	M
Relative humidity	50 %
Moisture difference	52 gr/lb

Heating Summary

Structure	26750 Btuh
Ducts	0 Btuh
Central vent (0 cfm)	0 Btuh
Humidification	0 Btuh
Piping	0 Btuh
Equipment load	26750 Btuh

Sensible Cooling Equipment Load Sizing

Structure	20654 Btuh
Ducts	0 Btuh
Central vent (0 cfm)	0 Btuh
Blower	0 Btuh

Use manufacturer's data	n
Rate/swing multiplier	0.97
Equipment sensible load	20034 Btuh

Infiltration

Method	Simplified
Construction quality	Tight
Fireplaces	0

	Heating	Cooling
Area (ft²)	2631	2631
Volume (ft³)	23675	23675
Air changes/hour	0.11	0.06
Equiv. AVF (cfm)	43	24

Latent Cooling Equipment Load Sizing

Structure	2832 Btuh
Ducts	0 Btuh
Central vent (0 cfm)	0 Btuh
Equipment latent load	2832 Btuh

Equipment total load	22867 Btuh
Req. total capacity at 0.70 SHR	2.4 ton

Heating Equipment Summary

Make	n/a
Trade	n/a
Model	n/a
AHRI ref	n/a

Efficiency	n/a
Heating input	
Heating output	0 Btuh
Temperature rise	0 °F
Actual air flow	0 cfm
Air flow factor	0 cfm/Btuh
Static pressure	0 in H2O
Space thermostat	n/a

Cooling Equipment Summary

Make	n/a
Trade	n/a
Cond	n/a
Coil	n/a
AHRI ref	n/a
Efficiency	n/a
Sensible cooling	0 Btuh
Latent cooling	0 Btuh
Total cooling	0 Btuh
Actual air flow	0 cfm
Air flow factor	0 cfm/Btuh
Static pressure	0 in H2O
Load sensible heat ratio	0

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



Right-Suite® Universal 2012 12 1.04 RSU01870

Settings\Joe\My Documents\Wrightsoft HVAC\O'Neil - Reeves.rup Calc = MJ8 Front Door faces

2013-Sep-24 15:31:06

Page 1

wrightsoft **Project Summary**
Downstairs
Bounds Heating and Air

Job:
 Date: Jul 11, 2013
 By: Joe Mullins

26545 West Newberry Road, Newberry, FL 32669 Phone: 352-472-2761 Fax: 352-472-1809 Email: joe.atbounds@yahoo.com or bounds_hvac@yahoo.com Web: www.bounds.

Project Information

For: Reeves Residence, O'Neil Construction

Notes

Design Information

Weather: Gainesville, FL, US

Winter Design Conditions

Outside db	33 °F
Inside db	68 °F
Design TD	35 °F

Summer Design Conditions

Outside db	92 °F
Inside db	75 °F
Design TD	17 °F
Daily range	M
Relative humidity	50 %
Moisture difference	52 gr/lb

Heating Summary

Structure	15327 Btuh
Ducts	0 Btuh
Central vent (0 cfm)	0 Btuh
Humidification	0 Btuh
Piping	0 Btuh
Equipment load	15327 Btuh

Sensible Cooling Equipment Load Sizing

Structure	13661 Btuh
Ducts	0 Btuh
Central vent (0 cfm)	0 Btuh
Blower	0 Btuh

Use manufacturer's data	n
Rate/swing multiplier	0.97
Equipment sensible load	13252 Btuh

Infiltration

Method	Simplified
Construction quality	Tight
Fireplaces	0

	Heating	Cooling
Area (ft²)	1751	1751
Volume (ft³)	15755	15755
Air changes/hour	0.09	0.05
Equiv AVF (cfm)	23	13

Latent Cooling Equipment Load Sizing

Structure	1650 Btuh
Ducts	0 Btuh
Central vent (0 cfm)	0 Btuh
Equipment latent load	1650 Btuh

Equipment total load	14902 Btuh
Req total capacity at 0.70 SHR	16 ton

Heating Equipment Summary

Make	Carrier
Trade	BASE 13 PURON HP
Model	25HBC324(A,W)**30
AHRI ref	3699485
Efficiency	8 HSPF
Heating input	22600 Btuh @ 47°F
Heating output	27 °F
Temperature rise	767 cfm
Actual air flow	0.050 cfm/Btuh
Air flow factor	1.00 in H2O
Static pressure	
Space thermostat	

Cooling Equipment Summary

Make	Carrier
Trade	BASE 13 PURON HP
Cond	25HBC324(A,W)**30
Coil	FB4CNF024
AHRI ref	3699485
Efficiency	11.0 EER, 13 SEER
Sensible cooling	16100 Btuh
Latent cooling	6900 Btuh
Total cooling	23000 Btuh
Actual air flow	767 cfm
Air flow factor	0.056 cfm/Btuh
Static pressure	1.00 in H2O
Load sensible heat ratio	0.89

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed



wrightsoft

Right-Suite® Universal 2012 12 1 04 RSU01870

Settings\Joe\My Documents\Wrightsoft HVAC\O'Neil - Reeves.rup Calc = MJ8 Front Door faces:

2013-Sep-24 15:31:06

Page 2



Project Summary Upstairs Bounds Heating and Air

Job:
Date: Jul 11, 2013
By: Joe Mullins

26545 West Newberry Road, Newberry FL 32669 Phone: 352-472-2761 Fax: 352-472-1809 Email: joe.atbounds@yahoo.com or bounds_hvac@yahoo.com Web: www.bounds

Project Information

For: Reeves Residence, O'Neil Construction

Notes

Design Information

Weather: Gainesville, FL, US

Winter Design Conditions

Outside db	33 °F
Inside db	68 °F
Design TD	35 °F

Summer Design Conditions

Outside db	92 °F
Inside db	75 °F
Design TD	17 °F
Daily range	M
Relative humidity	50 %
Moisture difference	52 gr/lb

Heating Summary

Structure	11423 Btuh
Ducts	0 Btuh
Central vent (0 cfm)	0 Btuh
Humidification	0 Btuh
Piping	0 Btuh
Equipment load	11423 Btuh

Sensible Cooling Equipment Load Sizing

Structure	7215 Btuh
Ducts	0 Btuh
Central vent (0 cfm)	0 Btuh
Blower	0 Btuh
Use manufacturer's data	n
Rate/swing multiplier	0.97
Equipment sensible load	6998 Btuh

Infiltration

Method	Simplified
Construction quality	Tight
Fireplaces	0

	Heating	Cooling
Area (ft²)	880	880
Volume (ft³)	7920	7920
Air changes/hour	0.15	0.08
Equiv. AVF (cfm)	20	11

Latent Cooling Equipment Load Sizing

Structure	1182 Btuh
Ducts	0 Btuh
Central vent (0 cfm)	0 Btuh
Equipment latent load	1182 Btuh
Equipment total load	8181 Btuh
Req. total capacity at 0.70 SHR	0.8 ton

Heating Equipment Summary

Make	Carrier
Trade	BASE 13 PURON HP
Model	25HBC318(A,W)**30
AHRI ref	3699493
Efficiency	8 HSPF
Heating input	
Heating output	17400 Btuh @ 47°F
Temperature rise	27 °F
Actual air flow	580 cfm
Air flow factor	0.051 cfm/Btuh
Static pressure	1.00 in H2O
Space thermostat	

Cooling Equipment Summary

Make	Carrier
Trade	BASE 13 PURON HP
Cond	25HBC318(A,W)**30
Coil	FB4CNF018
AHRI ref	3699493
Efficiency	11.0 EER, 13 SEER
Sensible cooling	12180 Btuh
Latent cooling	5220 Btuh
Total cooling	17400 Btuh
Actual air flow	580 cfm
Air flow factor	0.080 cfm/Btuh
Static pressure	1.00 in H2O
Load sensible heat ratio	0.86


Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.





Right-Suite® Universal 2012 12.1 04 RSU01870

Settings\Joel\My Documents\Wrightsoft HVAC\O'Neil - Reeves.rup Calc = MJ8 Front Door faces.

2013-Sep-24 15:31:06
Page 3



Level 1



Job #:
Performed by Joe Mullins for:
Reeves Residence

Bounds Heating and Air
26545 West Newberry Road
Newberry, FL 32669
Phone 352-472-2761 Fax: 352-472-1809
www.boundsvac.com joe atbounds@yahoo.com

Scale: 1 : 166
Page 1
Right-Suite® Universal 2012
12 1 04 RSU01870
2013-Sep-24 15 38 02
ghtsoft HVAC/O'Neil - Reeves rup

wrightsoft **Duct System Summary**
Downstairs
Bounds Heating and Air

Job:
Date: Jul 11, 2013
By: Joe Mullins

26545 West Newberry Road, Newberry, FL 32669 Phone: 352-472-2761 Fax: 352-472-1809 Email: joe.atbounds@yahoo.com or bounds_hvac@yahoo.com Web: www.bounds.com

Project Information

For: Reeves Residence, O'Neil Construction

	Heating	Cooling
External static pressure	1.00 in H2O	1.00 in H2O
Pressure losses	0.30 in H2O	0.30 in H2O
Available static pressure	0.70 in H2O	0.70 in H2O
Supply / return available pressure	0.39 / 0.31 in H2O	0.39 / 0.31 in H2O
Lowest friction rate	0.156 in/100ft	0.156 in/100ft
Actual air flow	767 cfm	767 cfm
Total effective length (TEL)	449 ft	

Supply Branch Detail Table

Name	Design (Btuh)	Htg (cfm)	Clg (cfm)	Design FR	Diam (in)	H x W (in)	Duct Matl	Actual Ln (ft)	Ftg. Eqv Ln (ft)	Trunk
1/2 bath	h 82	4	3	0.171	4.0	0x0	VIFx	35.5	190.0	st3
WIC	h 94	5	4	0.179	4.0	0x0	VIFx	45.5	170.0	st3
dining	c 3541	173	199	0.156	8.0	0x0	VIFx	43.0	205.0	st3
foyer	h 945	47	22	0.158	5.0	0x0	VIFx	39.0	205.0	st3
guest bath	h 1241	62	20	0.266	5.0	0x0	VIFx	40.5	105.0	st3
guest room	h 2666	133	82	0.167	6.0	0x0	VIFx	36.0	195.0	st3
kitchen	c 2675	64	150	0.162	8.0	0x0	VIFx	33.0	205.0	st3
laundry	h 1032	52	47	0.178	5.0	0x0	VIFx	12.5	205.0	st3
library	c 2238	120	126	0.164	7.0	0x0	VIFx	55.0	180.0	st3
living	c 1928	100	108	0.167	7.0	0x0	VIFx	25.8	205.0	st3
pantry	h 145	7	6	0.178	4.0	0x0	VIFx	11.5	205.0	st3

Supply Trunk Detail Table

Name	Trunk Type	Htg (cfm)	Clg (cfm)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Duct Material	Trunk
st3	Peak AVF	767	767	0.156	789	12.0	14 x 10	RectFbg	

Bold/italic values have been manually overridden



wrightsoft

Right-Suite® Universal 2012 12 1.04 RSU01870

Settings\Joel\My Documents\Wrightsoft HVAC\O'Neil - Reeves.rup Calc = MJ8 Front Door faces

2013-Sep-24 15:31:06

Page 1

Return Branch Detail Table

Name	Grill Size (in)	Htg (cfm)	Clg (cfm)	TEL (ft)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Stud/Joist Opening (in)	Duct Matl	Trunk
rb2	0x0	767	767	201.3	0 156	549	16 0	0x 0		VIFx	



wrightsoft Duct System Summary
Upstairs
Bounds Heating and Air

Job:
Date: Jul 11, 2013
By: Joe Mullins

26545 West Newberry Road Newberry, FL 32669 Phone: 352-472-2761 Fax: 352-472-1809 Email: joe.atbounds@yahoo.com or bounds_hvac@yahoo.com Web: www.bounds.com

Project Information

For: Reeves Residence, O'Neil Construction

	Heating	Cooling
External static pressure	1.00 in H2O	1.00 in H2O
Pressure losses	0.30 in H2O	0.30 in H2O
Available static pressure	0.70 in H2O	0.70 in H2O
Supply / return available pressure	0.51 / 0.19 in H2O	0.51 / 0.19 in H2O
Lowest friction rate	0.252 in/100ft	0.252 in/100ft
Actual air flow	580 cfm	580 cfm
Total effective length (TEL)	278 ft	

Supply Branch Detail Table

Name	Design (Btuh)	Htg (cfm)	Clg (cfm)	Design FR	Diam (in)	H x W (in)	Duct Matl	Actual Ln (ft)	Ftg.Eqv Ln (ft)	Trunk
bath 2	h 1196	61	34	0.270	5.0	0x0	VIFx	7.0	180.0	st1
bedroom 2	h 2068	105	81	0.258	6.0	0x0	VIFx	26.0	170.0	st2
bedroom 3	c 2045	119	164	0.389	7.0	0x0	VIFx	25.0	105.0	st2
master bath	h 1619	82	31	0.258	6.0	0x0	VIFx	26.0	170.0	st1
master bedroom	c 2507	103	202	0.252	8.0	0x0	VIFx	10.5	190.0	st1
master closet	h 1457	74	28	0.408	5.0	0x0	VIFx	19.0	105.0	st1
stairs	c 505	36	41	0.261	6.0	0x0	VIFx	14.0	180.0	st2

Supply Trunk Detail Table

Name	Trunk Type	Htg (cfm)	Clg (cfm)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Duct Material	Trunk
st1	Peak AVF	320	294	0.252	549	7.9	14 x 6	RectFbg	
st2	Peak AVF	260	286	0.258	490	7.5	14 x 6	RectFbg	

Return Branch Detail Table

Name	Grill Size (in)	Htg (cfm)	Clg (cfm)	TEL (ft)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Stud/Joist Opening (in)	Duct Matl	Trunk
rb3	0x0	580	580	77.0	0.252	543	14.0	0x0		VIFx	

Bold/italic values have been manually overridden