



Britt Surveying and Mapping, LLC

1438 SW Main Blvd • Lake City, FL 32025

386-752-7163 P • 386-752-5573 F • www.brittsurvey.com

03/12/2023

Permit # 000046385

L-29382

Re: 03081-015

Blake Construction

To Whom It May Concern:

The finished floor elevation is found to be 102.45 feet. The permit shows a minimum floor height to be 102.0 feet. All elevations are shown in NAVD 88 datum.

Sincerely,

A handwritten signature in blue ink, appearing to read "L. Scott Britt", is written over a circular professional seal.

L. Scott Britt
LS 5757

