

Project Information

For: Dicks Residence
Columbia County, FL

Notes:

Design Information

Weather: Gainesville Regional, FL, US

Winter Design Conditions

Outside db 33 °F
Inside db 70 °F
Design TD 37 °F

Summer Design Conditions

Outside db 92 °F
Inside db 75 °F
Design TD 17 °F
Daily range M
Relative humidity 50 %
Moisture difference 44 gr/lb

Heating Summary

Structure 38476 Btuh
Ducts 6747 Btuh
Central vent (0 cfm)
(none) 0 Btuh
Humidification 0 Btuh
Piping 0 Btuh
Equipment load 45223 Btuh

Sensible Cooling Equipment Load Sizing

Structure 25624 Btuh
Ducts 9829 Btuh
Central vent (0 cfm)
(none) 0 Btuh
Blower 0 Btuh
Use manufacturer's data y
Rate/swing multiplier 1.00
Equipment sensible load 35453 Btuh

Infiltration

Method Simplified
Construction quality Average
Fireplaces 0

Latent Cooling Equipment Load Sizing

Structure 3054 Btuh
Ducts 2080 Btuh
Central vent (0 cfm)
(none) 0 Btuh
Equipment latent load 5134 Btuh

	Heating	Cooling
Area (ft ²)	2653	2653
Volume (ft ³)	28511	28511
Air changes/hour	0.32	0.16
Equiv. AVF (cfm)	152	76

Equipment Total Load (Sen+Lat) 40587 Btuh
Req. total capacity at 0.80 SHR 3.7 ton

Heating Equipment Summary

Make Trane
Trade TRANE
Model 4TWR4048G1
AHRI ref 8908430
Efficiency 8.5 HSPF
Heating input
Heating output 46500 Btuh @ 47°F
Temperature rise 27 °F
Actual air flow 1550 cfm
Air flow factor 0.034 cfm/Btuh
Static pressure 0.53 in H2O
Space thermostat
Capacity balance point = 33 °F

Cooling Equipment Summary

Make Trane
Trade TRANE
Cond 4TWR4048G1
Coil TEM4A0C48S41++TDR
AHRI ref 8908430
Efficiency 11.5 EER, 14 SEER
Sensible cooling 37200 Btuh
Latent cooling 9300 Btuh
Total cooling 46500 Btuh
Actual air flow 1550 cfm
Air flow factor 0.044 cfm/Btuh
Static pressure 0.53 in H2O
Load sensible heat ratio 0.87

Backup:
Input = 13 kW, Output = 44065 Btuh, 100 AFUE

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.

Project Information

For: Dicks Residence
Columbia County, FL

Cooling Equipment

Design Conditions

Outdoor design DB:	92.2°F	Sensible gain:	35453 Btuh	Entering coil DB:	78.2°F
Outdoor design WB:	75.8°F	Latent gain:	5134 Btuh	Entering coil WB:	64.0°F
Indoor design DB:	75.0°F	Total gain:	40587 Btuh		
Indoor RH:	50%	Estimated airflow:	1550 cfm		

Manufacturer's Performance Data at Actual Design Conditions

Equipment type:	Split ASHP				
Manufacturer:	Trane	Model:	4TWR4048G1+TEM4A0C48S41++TDR		
Actual airflow:	1550 cfm				
Sensible capacity:	37200 Btuh	105% of load			
Latent capacity:	9300 Btuh	181% of load			
Total capacity:	46500 Btuh	115% of load	SHR:	80%	

Heating Equipment

Design Conditions

Outdoor design DB:	33.2°F	Heat loss:	45223 Btuh	Entering coil DB:	68.4°F
Indoor design DB:	70.0°F				

Manufacturer's Performance Data at Actual Design Conditions

Equipment type:	Split ASHP				
Manufacturer:	Trane	Model:	4TWR4048G1+TEM4A0C48S41++TDR		
Actual airflow:	1550 cfm				
Output capacity:	46500 Btuh	103% of load		Capacity balance:	33 °F
Supplemental heat required:	0 Btuh			Economic balance:	-99 °F

Backup equipment type:	Elec strip				
Manufacturer:		Model:			
Actual airflow:	1550 cfm				
Output capacity:	12.9 kW	97% of load	Temp. rise:	50 °F	

Meets all requirements of ACCA Manual S.