

**Mark D. Duren and
Associates, Inc.**
Professional Surveyor and Mapper

1604 SW SISTERS WELCOME ROAD
Lake City, FL 32025
386-758-9831 Phone
386-758-8010 Fax
mddpsm@markduren.com
jldmddpsm@gmail.com

May 27, 2020

IE. Floor Elevation of structure on Tax Parcel No. 28-3S-16-02372-026

To Whom It May Concern,

A minimum floor elevation of 163.66 feet, North American Vertical Datum (NAVD) of 1988, was established for the above referenced parcel according to the provided construction plans prepared by Affine Engineering and Surveying, Inc.

The elevation of the concrete slab floor of the structure is 163.78 feet, NAVD 1988 Datum using the Benchmark referenced on the aforementioned construction plans. The benchmark used is referenced as a "nail in pavement" at the center of the paved cul-de-sac. Reference elevation is 162.16 feet, NAVD 1988 datum.

