

70

FIELD DENSITY WORKSHEET

CLIENT Hughes Concrete

DATE 9-11-12

PROJECT NAME Beck Res. 824 SW CR 138

PROJECT NO. _____

EARTH CONTRACTOR _____

PERMIT NO. 000030360

COMPACTION REQUIREMENT (%) 95 ☐ Standard Proctor ☒ Modified Proctor

TESTED BY S.L.

TOTAL ON-SITE TIME _____

FIELD CONTACT _____

MILES FROM OFFICE _____

☐ Limerock ☐ Subgrade ☐ Pipe Backfill ☒ Building Pad ☐ Building Footing ☐ Other _____

TEST LOCATION	LAB PROCTOR		TEST DEPTH	PROBE DEPTH	% MOIST.	WET DENSITY (PCF)	DRY DENSITY (PCF)	% COMP.
	DENS.	OMC						
	108.0	10.0	96	12"				
6' NE of SW corner					5.8	111.4	105.3	97.5
6' NW of SE corner					6.1	111.4	105.0	97.2
6' SE of NW corner					5.5	111.4	105.6	97.8
6' SW of NE corner					5.7	111.2	105.2	97.4

REMARKS _____

- * Density failed to meet minimum project requirement
- ** Retest indicates minimum density requirement was obtained.
- () Client is aware of unsatisfactory test results.