

**D**  
**G** **Daniel & Gore, LLC**  
**Professional Surveying and Mapping**

P.O. Box 1501  
Lake City, Florida 32056

**August 22, 2013**

Aaron Simque Homes  
Lake City, FL 32025

**Subject: Lot 133 Preserve at Laurel Lakes Elevation Letter**

*Perm. # 31334*

*OK*

*BLK*

*22 Aug 2013*

Dear Aaron:

Daniel & Gore, LLC has performed a vertical survey on Lot 133, Preserve at Laurel Lakes, Unit 1, Columbia County, Florida from a benchmark being a 60d nail at the common lot line between Lots 8 & 9 (elevation – 116.12', NGVD 1929) and have determined the following:

- The Subdivision plat requires the minimum finish floor elevation to be 118.6'.
- The top of the slab of the foundation is at 118.8', being the 0.2' above the minimum finish floor requirement.

If you have any questions, please call me.

Sincerely,



Scott Daniel, PSM