

ADDENDUM LETTER

STRICKLAND RESIDENCE
471 SE DEFENDER DRIVE
COLUMBIA COUNTY, FL

The following substitutions may be made to the plans signed and sealed on 30 MAY 2022:

1. Substitute 4 ½" Simpson Strong Drive SDWC Truss Screw (3 per rafter to ridge beam – 2 one side, 1 opposite) for the Simpson LRUZ28 Face-Mount Rafter Hanger
2. Substitute CS16 Coil Strap (2 per post – with a min. of 5 nails per strap) for the ACE4 (MAX)

This item has been digitally
Signed and sealed by

Christopher Q Dicks

Digitally signed by Christopher Q Dicks
DN: CN=Christopher Q Dicks,
dnQualifier=A01410D000017F04A4C76A001156B7,
O=Florida, C=US
Reason: I am the author of this document
Date: 2022.06.09 11:47:19 -0400

On the date adjacent to the seal

Printed copies of this document
Are not considered signed and
Sealed and the signature must be
Verified on any electronic copies.

Christopher Q. Dicks, P.E. 64766
4037 SE County Road 252
Lake City, FL 32025

