

INSPECTION DAILY REPORT

No.: _____

PAGE: 1 OF 1

PROJECT No.: 0215.1900017.0000 DATE: 02-18-2020
PROJECT NAME: Lot 43- Rolling Meadows TIME ON SITE: N/A
PROJECT LOCATION: Lake City TRAVEL TIME: N/A
CLIENT: Spears Construction WEATHER: N/A
PERMIT AGENCY: Columbia County TEMPERATURE: N/A
PERMIT No.: 38972 UES INSPECTOR: Marshall McElroy
APPLICABLE PERSONNEL ON SITE / COMPANY: _____ APPLICABLE PLANS USED FOR INSPECTION: _____

ELEMENTS INSPECTED: WINDOW ATTACHMENT AND DRY-IN (ROOF AND WALL)

FIELD OBSERVATIONS (NUMBER EACH ITEM):

1.) WINDOW ATTACHMENT → PASS

2.) ROOF DRY-IN → PASS (AS-NOTED)

- ROOF AREA WITH 2:12 SLOPE SHALL HAVE

LOW SLOPE DRY-IN PER FBC - RESIDENTIAL

- FLASHING NOT INSTALLED AT TIME OF INSPECTION.

3.) WALL DRY-IN → PASS

BNG543



THE ABOVE REFERENCED CONSTRUCTION WAS NOTED IN PLACE IN SUBSTANTIAL CONFORMANCE TO THE PLANS AND SPECIFICATIONS, EXCEPT AS NOTED HEREIN.

Universal Engineering Sciences, Inc.

4475 SW 35th Terrace Gainesville, FL 32608

(352) 372-3392

Fax (352) 336-7914

