



CAL-TECH TESTING, INC.

ENGINEERING & TESTING LABORATORY

P.O. Box 1625, Lake City, FL 32056-1625
7540 103rd St. Suite 215 • Jacksonville, FL 32210

Lake City • (386) 755-3633

Fax • (386) 752-5456

Jacksonville • (904) 381-8901

Fax • (904) 381-8902

JOB NO.:

DATE TESTED: 3-23-22

REPORT OF IN-PLACE DENSITY TEST

ASTM METHOD: ✓ (D-2922) Nuclear (D-2937) Drive Cylinder Other

PROJECT: 251 SE Oak Ridge Ct

CLIENT: B.I. Thain

GENERAL CONTRACTOR: SAC EARTHWORK CONTRACTOR: SAC

SOIL USE (SEE NOTE): 1 SPECIFICATION REQUIREMENTS: 95%

TECHNICIAN: I. Caignan

MODIFIED (ASTM D-1557): ✓ STANDARD (ASTM D-698):

TEST NO.	TEST LOCATION	TEST:	PROCTOR NO.	WET DENS. LBS./CU.FT.	DRY DENS. LBS./CU.FT.	MOIST PERCENT	% MAX. DENS.
		✓ DEPTH ELEV. LIFT					
	20' W by 13' S from the NE Corner	12		115.7	112.1	27	103
	20' W by 15' N from the SE Corner	12		116.1	111.3	43	101

REMARKS:

PROCTOR NO.	SOIL DESCRIPTION	PROCTOR VALUE	OPT. MOIST.
		109.3	

NOTE: 1. Building Fill 2. Trench Backfill 3. Base Course 4. Subbase/Stabilized Subgrade 5. Embankment 6. Subgrade/Natural Soil 7. Other
The test results presented in this report are specific only to the samples tested at the time of testing. The tests were performed in accordance with generally accepted methods and standards. Since material conditions can vary between test location and change with time, sound judgement should be exercised with regard to the use and interpretation of the data.