

wrightsoft® **Load Short Form**
Entire House
P.O.Box 1617

Job: Bounds HVAC
 Date: Jun 13, 2012
 By: Robert Bounds

25645 W. Newberry Rd., Newberry, FL 32869 Phone: 352-472-2761 Fax: 352-472-1809 Email: robertbounds@rocketmail.com Web: www.boundshvac.com

Project Information

For: Bryant Construction, Mayo Fertilizer

Design Information

	Htg	Clg	Infiltration	Simplified
Outside db (°F)	33	92	Method	Tight
Inside db (°F)	68	75	Construction quality	0
Design TD (°F)	35	17	Fireplaces	
Daily range	-	M		
Inside humidity (%)	50	50		
Moisture difference (gr/lb)	10	50		

HEATING EQUIPMENT

Make Carrier
 Trade BASE 13 PURON HP
 Model 25HBB342A50
 AHRI ref no.3507574

Efficiency 8.2 HSPF
 Heating input
 Heating output 41500 Btuh @ 47°F
 Temperature rise 28 °F
 Actual air flow 1350 cfm
 Air flow factor 0.055 cfm/Btuh
 Static pressure 1.00 in H2O
 Space thermostat

COOLING EQUIPMENT

Make Carrier
 Trade BASE 13 PURON HP
 Cond 25HBB342A50
 Coil FY4ANF042
 AHRI ref no.3507574

Efficiency 10.4 EER, 13 SEER
 Sensible cooling 28350 Btuh
 Latent cooling 12150 Btuh
 Total cooling 40500 Btuh
 Actual air flow 1350 cfm
 Air flow factor 0.048 cfm/Btuh
 Static pressure 1.00 in H2O
 Load sensible heat ratio 0.85

ROOM NAME	Area (ft²)	Htg load (Btuh)	Clg load (Btuh)	Htg AVF (cfm)	Clg AVF (cfm)
Office 3	154	3714	3586	204	172
Office 4	154	2054	2796	113	135
Room3	112	0	0	0	0
Office 2	208	2405	3286	132	158
Main Office	224	4626	4536	254	219
Office 5	180	3883	3678	213	177
Office 6	182	2318	3198	127	154
Office 7	169	3704	3587	203	173
Room9	66	171	206	9	10
Room10	231	1725	3157	95	152

Bold/italic values have been manually overridden

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.

Entire House	d	1680	24601	28011	1350	1350
Other equip loads			0	0		
Equip. @ 0.97 RSM				27171		
Latent cooling				4914		
TOTALS		1680	24601	32085	1350	1350

Bold/italic values have been manually overridden

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



wrightsoft

Right-Suite® Universal 8.0.24 RSU01870

2012-Jun-13 09:52:52

Page 2

Project1.rup Calc = MJ8 Front Door faces: N



wrightsoft

Project Summary

Entire House

P.O.Box 1617

Job: Bounds HVAC
Date: Jun 13, 2012
By: Robert Bounds

25645 W. Newberry Rd., Newberry, FL 32669 Phone: 352-472-2781 Fax: 352-472-1809 Email: robertbounds@rocketmail.com Web: www.boundshvac.com

Project Information

For: Bryant Construction, Mayo Fertilizer

Notes:

Design Information

Weather: Gainesville, FL, US

Winter Design Conditions

Outside db 33 °F
Inside db 68 °F
Design TD 35 °F

Summer Design Conditions

Outside db 92 °F
Inside db 75 °F
Design TD 17 °F
Daily range M
Relative humidity 50 %
Moisture difference 50 gr/lb

Heating Summary

Structure 17140 Btuh
Ducts 7461 Btuh
Central vent (0 cfm) 0 Btuh
Humidification 0 Btuh
Piping 0 Btuh
Equipment load 24601 Btuh

Sensible Cooling Equipment Load Sizing

Structure 18975 Btuh
Ducts 9036 Btuh
Central vent (0 cfm) 0 Btuh
Blower 0 Btuh

Infiltration

Method Construction quality Simplified Tight
Fireplaces 0

	Heating	Cooling
Area (ft ²)	1680	1680
Volume (ft ³)	16800	16800
Air changes/hour	0.14	0.07
Equiv. AVF (cfm)	39	20

Use manufacturer's data n
Rate/swing multiplier 0.97
Equipment sensible load 27171 Btuh

Latent Cooling Equipment Load Sizing

Structure 2667 Btuh
Ducts 2247 Btuh
Central vent (0 cfm) 0 Btuh
Equipment latent load 4914 Btuh

Equipment total load 32085 Btuh
Req. total capacity at 0.70 SHR 3.2 ton

Heating Equipment Summary

Make Carrier
Trade BASE 13 PURON HP
Model 25HBB342A50
AHRI ref no.3507574
Efficiency 8.2 HSPF
Heating input 41500 Btuh @ 47°F
Heating output 28 °F
Temperature rise 1350 cfm
Actual air flow 0.055 cfm/Btuh
Air flow factor 1.00 in H2O
Static pressure
Space thermostat

Cooling Equipment Summary

Make Carrier
Trade BASE 13 PURON HP
Cond 25HBB342A50
Coil FY4ANF042
AHRI ref no.3507574
Efficiency 10.4 EER, 13 SEER
Sensible cooling 28350 Btuh
Latent cooling 12150 Btuh
Total cooling 40500 Btuh
Actual air flow 1350 cfm
Air flow factor 0.048 cfm/Btuh
Static pressure 1.00 in H2O
Load sensible heat ratio 0.85

Bold/italic values have been manually overridden

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.




wrightsoft

Right-Suite® Universal 8.0.24 RSU01870

Project1.rup Calc = MJ8 Front Door faces: N

2012-Jun-13 09:52:52

Page 1

**Level 1**



Duct System Summary

Entire House

P.O.Box 1617

Job: Bounds HVAC
Date: Jun 13, 2012
By: Robert Bounds

25845 W Newberry Rd., Newberry, FL 32669 Phone: 352-472-2761 Fax: 352-472-1809 Email: robertbounds@rocketmail.com Web: www.boundshvac.com

Project Information

For: Bryant Construction, Mayo Fertilizer

	Heating	Cooling
External static pressure	1.00 in H2O	1.00 in H2O
Pressure losses	0.30 in H2O	0.30 in H2O
Available static pressure	0.70 in H2O	0.70 in H2O
Supply / return available pressure	0.45 / 0.25 in H2O	0.45 / 0.25 in H2O
Lowest friction rate	0.100 in/100ft	0.100 in/100ft
Actual air flow	1350 cfm	1350 cfm
Total effective length (TEL)	326 ft	

Supply Branch Detail Table

Name	Design (Btuh)	Htg (cfm)	Clg (cfm)	Design FR	Diam (in)	H x W (in)	Duct Matl	Actual Ln (ft)	Ftg.Eqv Ln (ft)	Trunk
Main Office	h 2313	127	109	0.100	8.0	0x0	VIFx	30.0	170.0	st2
Main Office-A	h 2313	127	109	0.100	8.0	0x0	VIFx	36.0	170.0	st2
Office 2	c 3286	132	158	0.100	8.0	0x0	VIFx	20.0	170.0	st2
Office 3	h 3714	204	172	0.100	8.0	0x0	VIFx	27.0	180.0	st2
Office 4	c 2796	113	135	0.100	8.0	0x0	VIFx	13.0	180.0	st2
Office 5	h 3883	213	177	0.100	8.0	0x0	VIFx	20.0	160.0	st1
Office 6	c 3198	127	154	0.100	8.0	0x0	VIFx	16.0	160.0	st1
Office 7	h 3704	203	173	0.100	8.0	0x0	VIFx	30.0	160.0	st1
Room10	c 3157	95	152	0.100	8.0	0x0	VIFx	18.0	190.0	st2
Room9	c 206	9	10	0.100	4.0	0x0	VIFx	5.0	170.0	st1

Supply Trunk Detail Table

Name	Trunk Type	Htg (cfm)	Clg (cfm)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Duct Material	Trunk
st1	Peak AVF	553	514	0.100	622	11.6	8 x 16	RectFbg	
st2	Peak AVF	797	836	0.100	684	13.6	8 x 22	RectFbg	

Bold/italic values have been manually overridden



Wrightsoft

Right-Suite® Universal 8.0.24 RSU01870

2012-Jun-13 09:52:52

Project1.rup Calc = MJ8 Front Door faces: N

Page 1

Return Branch Detail Table

Name	Grill Size (in)	Htg (cfm)	Clg (cfm)	TEL (ft)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Stud/Joist Opening (in)	Duct Matl	Trunk
rb1	0x0	127	109	87.0	0.050	287	9.0	0x 0		VIFx	rt2
rb2	0x0	317	307	103.0	0.050	403	12.0	0x 0		VIFx	rt2
rb3	0x0	9	10	90.0	0.050	18	10.0	0x 0		VIFx	rt1
rb4	0x0	127	109	110.0	0.050	233	10.0	0x 0		VIFx	rt1
rb5	0x0	345	336	90.0	0.050	323	14.0	0x 0		VIFx	rt2
rb6	0x0	95	152	118.0	0.050	344	9.0	0x 0		VIFx	rt1
rb7	0x0	203	173	111.0	0.050	373	10.0	0x 0		VIFx	rt1
rb8	0x0	127	154	104.0	0.050	283	10.0	0x 0		VIFx	rt2

Return Trunk Detail Table

Name	Trunk Type	Htg (cfm)	Clg (cfm)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Duct Material	Trunk
rt1	Peak AVF	434	444	0.050	444	12.3	8 x 18	RectFbg	
rt2	Peak AVF	916	906	0.050	549	16.1	8 x 30	RectFbg	

Bold/italic values have been manually overridden