Britt Surveying and Mapping, LLC
1438 SW Main Blvd • Lake City, FL 32025
386-752-7163 P • 386-752-5573 F • www.brittsurvey.com

04/08/2024

L-30350

Permit # 000049257

Re: Lot 2 Kimberly Oaks

Exceptions Realty

To Whom It May Concern:

The finished floor elevation on Lot 2 is found to be 95.63 feet. The plat of record shows a minimum floor elevation of 95.00 feet. All elevations are shown in NAVD 88 datum.

Sincerely,

L. Scott Britt
LS 5757